

APPLICATION FOR SUBMITTAL OF POST-APPROVAL DOCUMENT

This application is for submittal of documents, after the initial approval of the project (post-approval documents), that require Division of the State Architect (DSA) review and approval. This form shall be completed by the Design Professional in General Responsible Charge of the project, in accordance with California Code of Regulations, Title 24, Part 1, Sections 4-317, 4-323 and 4-338 and in compliance with DSA IR A-6: Construction Change Document Submittal and Approval Process.

DSA documents referenced within this form are available on the [DSA Forms](#) or [DSA Publications](#) webpages.

1. SUBMITTAL TYPE: (Is this a resubmittal? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>)				
Deferred Submittal <input type="checkbox"/>	Addendum Number: 5	Revision Number:	CCD Number:	Category A <input type="checkbox"/> or B <input type="checkbox"/>
2. PROJECT INFORMATION:				
School District/Owner: San Mateo-Foster City School District			DSA File Number: 41-26	
Project Name/School: LEAD Elementary School New Multi-Purpose Building			DSA Application Number 01 120062	
3. APPLICANT INFORMATION:				
Date Submitted: 04/12/23		Attached Pages? No <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Number of pages? 4		
Firm Name: HKIT Architects		Contact Name: Jeffery Evans		
Work Email: jevans@hkit.com		Work Phone: (510) 625-9800		
Firm Address: 538 Ninth St. Suite 240		City: Oakland	State: CA	Zip Code: 94607
4. REASON FOR SUBMITTAL: (Check applicable boxes)				
<input checked="" type="checkbox"/> For revision or addendum prior to construction.			<input type="checkbox"/> For a project currently under construction.	
<input type="checkbox"/> For a project that has a form <i>DSA 301-N: Notification of Requirement for Certification</i> , <i>DSA 301-P: Posted Notification of Requirement for Certification</i> or a 90-Day Letter issued.				
<input type="checkbox"/> To obtain DSA approval of an existing uncertified building or buildings.				
<input type="checkbox"/> For Category B CCD this is: <input type="checkbox"/> a voluntary submittal, <input type="checkbox"/> a DSA required submittal (attach DSA notice requiring submission).				
5. DESIGN PROFESSIONAL IN GENERAL RESPONSIBLE CHARGE:				
Name of the Design Professional In General Responsible Charge: Jeffery Evans				
Professional License Number: 32430			Discipline: Architect	
Design Professional in General Responsible Charge Statement: The attached post-approval documents have been examined by me for design intent and appear to meet the appropriate requirements of Title 24, California Code of Regulations and the project specifications. They are acceptable for incorporation into the construction of the project.				
Signature: _____ <i>Jeffery Evans</i> DESIGN PROFESSIONAL IN GENERAL RESPONSIBLE CHARGE				
6. CONFIRMATION, DESCRIPTION AND LISTING OF DOCUMENTS:				
For addenda, revisions, or CCDs: CHECK THIS BOX <input checked="" type="checkbox"/> to confirm that <i>all</i> post-approval documents have been stamped and signed by the Responsible Design Professional listed on form <i>DSA 1: Application for Approval of Plans and Specifications</i> for this project. (For <i>Deferred Submittals</i> , refer to <i>IR A-18: Use of Construction Documents Prepared by Other Professionals</i> , and <i>IR A-19: Design Professional's Signature and Seal (Stamp) on Construction Documents</i> , when applicable, for signature and seal requirements.)				
Provide a brief description of construction scope for this post-approval document (attach additional sheets if needed): Updating the following specification sections to have consistent language with the INC 2 sections, as corrected/modified as part of Increment #2 - Addendum 1. No changes to the scope of work or scope of the specifications.				
List of DSA-approved drawings affected by this post-approval document: N/A				

DSA USE ONLY		
	Returned	DSA STAMP
SSS _____ Date _____ <input type="checkbox"/> Approved <input type="checkbox"/> Disapproved <input type="checkbox"/> Not Required Comments: _____	Date: _____ By: _____	
FLS _____ Date _____ <input type="checkbox"/> Approved <input type="checkbox"/> Disapproved <input type="checkbox"/> Not Required Comments: _____		
ACS _____ Date _____ <input type="checkbox"/> Approved <input type="checkbox"/> Disapproved <input type="checkbox"/> Not Required Comments: _____		



538 NINTH STREET SUITE 240 • OAKLAND, CALIFORNIA 94607 • T 510 625 9800 • F 510 625 9801 • WWW.HKIT.COM • A CALIFORNIA CORPORATION

INCREMENT #1 - ADDENDUM 5

DATE: April 12, 2023

PROJECT: SMFCSD: LEAD Elementary Multi-Purpose Building – Increment 1

FROM: HKIT Architects

TO: Perspective Bidders.

Cc: San Mateo-Foster City School District, Robert Price

This Addendum forms a part of the Contract Documents and modifies the original Procurement Documents and previous Addenda as described below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

DSA File Number: 41- 26 **DSA Application Number:** 01-120062

Signature of Design Professional: _____

Printed Name: Jeffrey M. Evans

Professional License: *Check One* Architect Structural Engineer

License Number: 32430

Expiration Date: 10-31-23

INCREMENT #1 - ADDENDUM 5

Page 1 of 4

0 – GENERAL CLARIFICATIONS

1. Increment #1 Addendums 1-4 were issued prior to the bidding period, and were incorporated into the bidding documents.

1 - BID RFIS

2. N/A

2 - SUBSTITUTION REQUESTS

1. N/A

3 - CHANGES TO SPECIFICATIONS

1. **Section: 00 0 06 Table of Contents**

Attachments: None

Description of Changes:

- a. **Division 00 General Requirements: ADD** section 00 45 55 Disabled Veteran Business Enterprise Participation Certification.
- b. **Division 01 General Requirements: ADD** section 01 75 19 Construction Waste Management and Disposal.

2. **Section: 00 41 13 Bid Form**

Attachments: As provided as part of Increment #2 – Addendum 2

Description of Changes:

- a. **REVISE** allowance for contaminated soil disposal to be **\$75,000**
- b. **ADD** allowance for dewatering to be **\$75,000**
- c. 2. Additive/Deductive Alternates: **DELETE** Alternate #1
- d. 11. Addenda Acknowledgment: **REVISE** to include Increment number.

3. **Section: 00 45 10 Agreement**

Attachments: As provided as part of Increment #2 – Addendum 2

Description of Changes:

- a. 7. Contract Price: **REVISE** allowance for contaminated soil disposal to be **\$75,000**
- b. 7. Contract Price: **ADD** allowance for dewatering to be **\$75,000**

4. **Section: 00 45 55 Disabled Veteran Business Enterprise Participation Certification**

INCREMENT #1 - ADDENDUM 5

Page 2 of 4

Attachments: As previously provided as part of Increment #2 – Addendum 1

Description of Changes:

- a. **ADD** this section in its entirety.

5. **Section: 00 70 00 General Conditions**

Attachments: As previously provided as part of Increment #2 – Addendum 1

Description of Changes:

- a. **ADD** Paragraph 13.1.6 Builder’s Risk Insurance: Builder’s Risk “All Risk” Insurance, and all subparagraphs.

6. **Section: 01 23 00 Alternates and Unit Pricing**

Attachments: As provided as part of Increment #2 – Addendum 2

Description of Changes:

- a. 4.1 Schedule of Alternates: **DELETE** Add Alternate #1.

7. **Section: 01 25 10 Product Options and Substitutions**

Attachments: As previously provided as part of Increment #2 – Addendum 1

Description of Changes:

- a. **ADD** the district’s substitution form to the end of the section.

8. **Section: 01 75 19 Construction Waste Management and Disposal**

Attachments: As previously provided as part of Increment #2 – Addendum 1

Description of Changes:

- a. **ADD** this section in its entirety.

9. **Section: 32 13 13 Site Concrete**

Attachments: As previously provided as part of Increment #2 – Addendum 1

Description of Changes:

- a. **Add** Testing paragraph as subsection 1.3.C Testing in subsection 1.3 Quality Assurance after subsection 1.3.B. Every subsequent paragraph after 1.3.C Testing will be labeled with the next sequential alphabet:
 - C. *Testing: Performed by a qualified independent testing laboratory selected and paid for by the Owner. The cost of re-testing rejected work shall be deducted from the amount due the Contractor for work under this section.*
- b. **Add** Batch Testing paragraph as subsection 1.3.G Batch Testing in subsection 1.3 Quality Assurance after subsection 1.3.F. Every subsequent paragraph after 1.3.G Batch Testing will be labeled with the next sequential alphabet.

INCREMENT #1 - ADDENDUM 5

C. *Batch Plant Testing*

1. *Continuous batch plant inspection may be waived by the registered design professional, subject to approval by the enforcement agency under the following condition:*
 - a. *The concrete plant complies fully with the requirements of ASTM C94, Sections 9 and 10, and has a current certificate from the National Ready Mixed Concrete Association or another agency acceptable to the enforcement agency. The certification shall indicate that the plant has automatic batching and recording capabilities.*
 2. *When Continuous batch plant inspection is waived, the following requirements shall apply:*
 - a. *An approved agency shall check the first batch at the start of the day to verify materials and proportions conform to the approved mix design.*
 - b. *A licensed weighmaster shall positively identify quantity of materials and certify each load by a batch ticket.*
 - c. *Batch tickets, including material quantities and weights shall accompany the load, shall be transmitted to the inspector of record by the truck driver with load identified thereon. The load shall not be placed without a batch ticket identifying the mix. The inspector of record shall keep a daily record of placements, identifying each truck, its load, and time of receipt at the jobsite, and approximate location of deposit in the structure and shall maintain a copy of the daily record as required by the enforcement agency.*
- d. 2.3. Reinforcement Steel A.2: Add dimension text “6” x 6”, w 1.4 x w 1.4” in subsection.
- e. 2.4.F. Waterproofing admixture: Remove the text “C-1000/C-2000” in subsection, add text “C-500” in place of removed text.

4 - CHANGES TO DRAWINGS

1. N/A
-

END OF INCREMENT #1 - ADDENDUM 5

INCREMENT #1 - ADDENDUM 5

Page 4 of 4