



730 Howe Avenue, Suite 450
Sacramento, CA 95825
Phone: 916.921.2112
Fax: 916.921.2212

October 10, 2022

Henry + Associates Project No. 22-32-057

DSA File No. 39-50

DSA Application No. 02-120272

ADDENDUM NO. 03
HVAC REPLACEMENT LODI MIDDLE SCHOOL
Lodi Unified School District
Lodi, California



.....
Henry + Associates Architects

1. ALL WORKMANSHIP, MATERIALS, APPLIANCES AND EQUIPMENT which may be included in the following items shall be the same relative quality as described for similar work set forth in the original or main specifications of which these Addendum items shall be considered a part.
2. ADDENDUM DRAWINGS (included in the back of this Addendum).
The following Addendum drawings modify or supplement the issued bid documents:

None

3. PROJECT MANUAL:

A. None

4. DRAWINGS:

A. Drawing detail 2/M6.1:

1. Detail 2/M6.1 shows control of exhaust fans, outdoor lighting circuits, etc. The details indicates the Contractor is to coordinate with the Electrical drawings to determine the number of exterior lighting circuits, if any, that are to be controlled. If there are no exterior lighting circuits in the Electrical drawings then none are to be controlled. There are no exterior lights on this project, therefore there are no requirements for controlling new lighting.

*** END OF ADDENDUM ***