#### ADDENDUM NO. 1

## **To Contract Documents**

For

Vinland Elementary School Gravity Sewer

Page 1 of 2

Issued: June 21, 2018

**Contents:** This Addendum No. 1 contains revisions to the Plans and Specifications. Revisions are made by re-issuing a specification page, plan sheet, OR by directing a change in writing. The due date and time for responses remains as 6/28/2018 @ 3:00PM PST. All revisions are listed below; bidders are cautioned to check the addendum contents carefully for the presence of all listed revisions.

**Distribution:** This Addendum No. 1 is distributed to all planholders of record by e-mail to e-mail addresses or facsimile to numbers given when documents were purchased. The planholder will be asked to confirm receipt when e-mailed.

**Integration:** The following changes, additions, deletions, and attachments are hereby made a part of the Contract Documents for Vinland Elementary School Gravity Sewer as fully and completely as if the same were fully set forth therein.

Acknowledgment of Receipt of Addendum: All prospective bidders are instructed to incorporate this revision into their bids and to acknowledge receipt of the Addenda in the Proposal. Failure to do so may result in the Bid being rejected as not responsive.

**Attachments to Addendum 1:** New plan sheets C2, C3, and D2.

#### **REVISIONS TO PLANS**

Item:

1

**Sheets:** 

C2, C3, and D2

Description: Add these new sheets to the Construction Plans. Revisions include the addition of

concrete pipe encasement, manhole inserts, ADA cross slope requirements for

concrete sidewalk and asphalt path, and 8" CSTC for trench repair.

### REVISIONS TO SPECIFICATIONS

Item:

**Specification:** Section 01 30 00 Measurement and Payment, page 01 30 00-2.

**Description:** Paragraph G, Bid Item No. 1-1-"8-inch Sanitary Sewer Service". Add "pipe

encasement" to items paid for under this bid item.

Item:

**Specification:** Section 01 30 00 Measurement and Payment, page 01 30 00-2.


Description: Paragraph H, Bid Item No. 1-2-"48-inch Type 1 Sanitary Sewer Manhole". Add

"inserts, to items paid for under this bid item.

# ADDENDUM NO. 1


To Contract Documents
For


Vinland Elementary School Gravity Sewer Page 2 of 2 Issued: June 21, 2018





David Dinkuhn, P.E. Project Engineer Parametrix


- END OF ADDENDUM NO. 1 -

















#### **NOTES**

- 1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE
  - 30 INCHES FOR PIPE UP TO TO AND INCLUDING 15" NOMINAL DIAMETER
  - 1.5 I.D. PLUS 18 INCHES FOR PIPE LARGER THAN 18" NOMINAL DIAMETER.
- 2. IN PAVED AREAS USE CRUSHED ROCK BACKFILL:
  - FULL DEPTH OF TRENCH BELOW PAVEMENT SECTION WHERE SEWER MAIN CROSSES PERPENDICULAR TO THE TRAVELED LANE OR DRIVEWAY.
  - TOP FOUR FEET BELOW PAVEMENT SECTION WHERE SEWER MAIN RUNS PARALLEL TO THE TRAVELED LANE
- PROVIDE UNIFORM SUPPORT UNDER BARREL AND PROVIDE POCKETS IN BEDDING FOR PIPE BELLS.
- HAND TAMP UNDER HAUNCHES.
- TRENCH WIDTH SHALL BE SPECIFIED IN SECTION 2-09.4 OF THE WSDOT STANDARD
- PIPE ZONE BEDDING SHALL MEET THE MATERIAL REQUIREMENTS OF WSDOT STANDARD SPECIFICATION SECTION 9-03.9(3) FOR CRUSHED SURFACING TOP
- REGRADE DISTURBED AREAS TO ORIGINAL CONTOURS LESS DEPTH OF NEW TOPSOIL PRIOR TO INSTALLING NEW TOPSOIL. RESTORE ORIGINAL GRADE AND ELEVATIONS AFTER INSTALLATION OF TOPSOIL

PIPE ZONE BEDDING **DETAIL** SCALE: 1" =5'



Know what's below.
Call before you dig.

ADDENDUM NO. 4

DESIGNED B. KUGEN 1> ADDENDUM NO. 1 6/21/2018 DLD B.ANDERSON D. DINKUHN

ONE INCH AT FULL SCALE FILE NAME PS4362003-D02 JOB No. 267-4362-003 DATE



NORTH KITSAP SCHOOL DISTRICT VINLAND ELEMENTARY SCHOOL **GRAVITY SEWER** POULSBO, WA

**DETAILS** 

D2

8 OF 8