Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
IR-2-K-KF-P-1	Kitchen Faucet	01/07/2023	0.021		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-K-KF-SS-1	Kitchen Faucet	01/07/2023	0.0045		mg/L	0.0020	NA	NA
IR-2-K-KF-F-1	Kitchen Faucet	01/07/2023	0.0025		mg/L	0.0020	NA	NA
IR-2-K-KF-P-2	Kitchen Faucet	01/07/2023	0.010		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-K-KF-SS-2	Kitchen Faucet	01/07/2023	0.0020	J	mg/L	0.0020	NA	NA
IR-2-K-KF-F-2	Kitchen Faucet	01/07/2023	0.0016	J	mg/L	0.0020	NA	NA
IR-2-K-KF-P-3	Kitchen Faucet	01/07/2023	0.0045		mg/L	0.0020	NA	NA
IR-2-K-KF-SS-3	Kitchen Faucet	01/07/2023	0.0025		mg/L	0.0020	NA	NA
IR-2-K-KF-F-3	Kitchen Faucet	01/07/2023	0.0013	J	mg/L	0.0020	NA	NA
IR-2-K-KF-P-4	Kitchen Faucet	01/07/2023	0.011		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-K-KF-SS-4	Kitchen Faucet	01/07/2023	0.0020		mg/L	0.0020	NA	NA
IR-2-K-KF-F-4	Kitchen Faucet	01/07/2023	0.0019	J	mg/L	0.0020	NA	NA
IR-2-K-KF-P-5	Kitchen Faucet	01/07/2023	0.013		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-K-KF-SS-5	Kitchen Faucet	01/07/2023	0.0020	J	mg/L	0.0020	NA	NA
IR-2-K-KF-F-5	Kitchen Faucet	01/07/2023	0.0016	J	mg/L	0.0020	NA	NA
IR-2-A115-WR-DWC-P-6	Drinking Fountain w/Cooler located between Room A115 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-A115-WR-DWC-SS-6	Drinking Fountain w/Cooler located between Room A115 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-A115-WR-DWC-F-6	Drinking Fountain w/Cooler located between Room A115 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-A115-MR-DWC-P-7	Drinking Fountain w/Cooler located between Room A115 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-A115-MR-DWC-SS-7	Drinking Fountain w/Cooler located between Room A115 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-A115-MR-DWC-F-7	Drinking Fountain w/Cooler located between Room A115 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-NUR-NS-P-8	Nurses Sink inside Nurses Office	01/07/2023	0.025		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-NUR-NS-SS-8	Nurses Sink inside Nurses Office	01/07/2023	0.0044		mg/L	0.0020	NA	NA
IR-2-NUR-NS-F-8	Nurses Sink inside Nurses Office	01/07/2023	0.0046		mg/L	0.0020	NA	NA
IR-2-NUR-NS-P-9	Nurses Sink inside Nurses Office	01/07/2023	0.013		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-NUR-NS-SS-9	Nurses Sink inside Nurses Office	01/07/2023	0.0089		mg/L	0.0020	NA	NA
IR-2-NUR-NS-F-9	Nurses Sink inside Nurses Office	01/07/2023	0.0030		mg/L	0.0020	NA	NA
IR-2-NUR-NS-P-10	Nurses Sink inside Nurses Office	01/07/2023	0.013		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
IR-2-NUR-NS-SS-10	Nurses Sink inside Nurses Office	01/07/2023	0.0048		mg/L	0.0020	NA	NA
IR-2-NUR-NS-F-10	Nurses Sink inside Nurses Office	01/07/2023	0.0021		mg/L	0.0020	NA	NA
IR-2-115-DWC-P-11	Drinking Fountain w/Cooler Room 115	01/07/2023	0.00069	J	mg/L	0.0020	NA	NA
IR-2-115-DWC-SS-11	Drinking Fountain w/Cooler Room 115	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-115-DWC-F-11	Drinking Fountain w/Cooler Room 115	01/07/2023	0.00070	J	mg/L	0.0020	NA	NA
IR-2-115-DWC-P-12	Drinking Fountain w/Cooler Room 115	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-115-DWC-SS-12	Drinking Fountain w/Cooler Room 115	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-115-DWC-F-12	Drinking Fountain w/Cooler Room 115	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-106-WR-DWC-P-13	Drinking Fountain w/Cooler in Between Room 106 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-106-WR-DWC-SS-13	Drinking Fountain w/Cooler in Between Room 106 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-106-WR-DWC-F-13	Drinking Fountain w/Cooler in Between Room 106 & Women's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA

IR-2-106-MR-DWC-P-14	Drinking Fountain w/Cooler in Between Room 106 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-106-MR-DWC-SS-14	Drinking Fountain w/Cooler in Between Room 106 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-106-MR-DWC-F-14	Drinking Fountain w/Cooler in Between Room 106 & Men's Restroom	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-P-15	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-SS-15	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-F-15	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-P-16	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-SS-16	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-100-DWC-F-16	Drinking Fountain w/Cooler Room 100	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-HE-KF-P-17	Kitchen Faucet in Home Economics Room	01/07/2023	0.0085		mg/L	0.0020	NA	NA
IR-2-HE-KF-SS-17	Kitchen Faucet in Home Economics Room	01/07/2023	0.0048		mg/L	0.0020	NA	NA
IR-2-HE-KF-F-17	Kitchen Faucet in Home Economics Room	01/07/2023	0.0087		mg/L	0.0020	NA	NA
IR-2-GYM-DWC-P-18	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-GYM-DWC-SS-18	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-GYM-DWC-F-18	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-GYM-DWC-P-19	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-GYM-DWC-SS-19	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-GYM-DWC-F-19	Drinking Fountain w/Cooler in Gym	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-P-20	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-SS-20	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-F-20	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-P-21	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-SS-21	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-320-DWC-F-21	Drinking Fountain w/Cooler Room 320	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-P-22	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-SS-22	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-F-22	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-P-23	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-SS-23	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-312-DWC-F-23	Drinking Fountain w/Cooler Room 312	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-P-24	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-SS-24	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-F-24	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-P-25	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-SS-25	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-2-307-DWC-F-25	Drinking Fountain w/Cooler Room 307	01/07/2023	0.0020	U	mg/L	0.0020	NA	NA

Key - Sample Name	
P	Primary Sample
SS	Sequential Sample
F	Flush Sample

Key - Qualifier	
U	Not Detected in Laboratory Analysis
J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit