Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
IR-4-1-KIT-KF-P-01	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-F-01	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-P-02	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-F-02	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-P-03	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-F-03	Kitchen Faucet	01/06/2023	0.0037		mg/L	0.0020	NA	NA
IR-4-1-CAF-WBF-P-04	Water Bottle Filler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-WBF-SS-04	Water Bottle Filler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-WBF-F-04	Water Bottle Filler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-P-05	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-SS-05	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-F-05	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-P-06	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-SS-06	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-CAF-DWC-F-06	Water Fountain w/Cooler in Cafeteria	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-P-07	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-SS-07	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-F-07	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-P-08	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-SS-08	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-125-DWC-F-08	Water Fountain w/Cooler Room 125	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-121A-DWC-P-09	Water Fountain w/Cooler Room 121A	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-121A-DWC-SS-09	Water Fountain w/Cooler Room 121A	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-121A-DWC-F-09	Water Fountain w/Cooler Room 121A	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-113-CF-P-10	Classroom Faucet in Room 113	01/06/2023	0.0011	J	mg/L	0.0020	NA	NA
IR-4-1-113-CF-F-10	Classroom Faucet in Room 113	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-104-DWC-P-12	Water Fountain w/Cooler Room 104	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-104-DWC-SS-12	Water Fountain w/Cooler Room 104	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-104-DWC-F-12	Water Fountain w/Cooler Room 104	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-P-13	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-F-13	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-P-14	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-1-KIT-KF-F-14	Kitchen Faucet	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-215-WBF-P-28	Water Bottle Filler Room 215	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-215-WBF-SS-28	Water Bottle Filler Room 215	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-215-WBF-F-28	Water Bottle Filler Room 215	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-P-29	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-SS-29	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-F-29	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-P-30	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-SS-30	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA
IR-4-2-219-DWC-F-30	Water Bottle Filler Room 219	01/06/2023	0.0020	U	mg/L	0.0020	NA	NA

Key - Sample Name	
P	Primary Sample
SS	Sequential Sample
F	Flush Sample

Key - Qualifier	
U	Not Detected in Laboratory Analysis
J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit