

SAMPLE NAME	SAMPLE LOCATION	DATE COLLECTED	RESULT	Qualifier	UNIT	REPORTING LIMIT
IR-8-1-SC-CF-F-10	Faucet Located in Classroom	12/22/2022	0.0020	U	mg/L	0.0020
IR-8-1-SC-CF-P-10	Faucet Located in Classroom	12/22/2022	0.0037		mg/L	0.0020
IR-8-1-SC-DWC-P-01	Water Fountain w/Cooler Located in Classroom	12/22/2022	0.012		mg/L	0.0020
IR-8-1-SC-DWC-SS-01	Water Fountain w/Cooler Located in Classroom	12/22/2022	0.012		mg/L	0.0020
IR-8-1-SC-DWC-F-01	Water Fountain w/Cooler Located in Classroom	12/22/2022	0.011		mg/L	0.0020
IR-8-1-SC-CF-P-02	Faucet Located in Classroom	12/22/2022	0.12		mg/L	0.0020
IR-8-1-SC-CF-F-02	Faucet Located in Classroom	12/22/2022	0.035		mg/L	0.0020
IR-8-1-SC-CF-P-03	Faucet Located in Classroom	12/22/2022	0.068		mg/L	0.0020
IR-8-1-SC-CF-F-03	Faucet Located in Classroom	12/22/2022	0.017		mg/L	0.0020
IR-8-1-SC-CF-F-04	Faucet Located in Classroom	12/22/2022	0.0041		mg/L	0.0020
IR-8-1-SC-CF-P-04	Faucet Located in Classroom	12/22/2022	0.037		mg/L	0.0020
IR-8-1-SC-CF-F-05	Faucet Located in Classroom	12/22/2022	0.0038		mg/L	0.0020
IR-8-1-SC-CF-P-05	Faucet Located in Classroom	12/22/2022	0.074		mg/L	0.0020
IR-8-1-SC-CF-F-06	Faucet Located in Classroom	12/22/2022	0.016		mg/L	0.0020
IR-8-1-SC-CF-P-06	Faucet Located in Classroom	12/22/2022	0.10		mg/L	0.0020

Immediate Remedial Response
NA
NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water, Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle WaterResample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet,Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle Water Resample
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continous Daily/Weekly Flushing, Provide Bottle WaterResample

Long-Term Remedial Response
NA
NA
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Provide Filters, Repalce Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample

IR-8-1-SC-CF-F-07	Faucet Located in Classroom	12/22/2022	0.0053		mg/L	0.0020
IR-8-1-SC-CF-P-07	Faucet Located in Classroom	12/22/2022	0.035		mg/L	0.0020
IR-8-1-SC-CF-F-08	Faucet Located in Classroom	12/22/2022	0.0067		mg/L	0.0020
IR-8-1-SC-CF-P-08	Faucet Located in Classroom	12/22/2022	0.063		mg/L	0.0020
IR-8-1-SC-CF-F-09	Faucet Located in Classroom	12/22/2022	0.0022		mg/L	0.0020
IR-8-1-SC-CF-P-09	Faucet Located in Classroom	12/22/2022	0.020		mg/L	0.0020

NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water Resample
NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water Resample
NA
Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water Resample

NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample

Key - Sample Name	
P	Primary Sample
SS	Sequential Sample
F	Flush Sample

Key - Qualifier	
U	Not Detected in Laboratory Analysis
J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit