



IR-16-1-D114-DWC-f-22C	Drinking Water Fountain w/Cooler Room D119	12/23/2022	0.002	U	mg/L	0.0020
IR-16-1-D114-DWC-P-23L	Drinking Water Fountain w/Cooler Room D120	12/23/2022	0.002	U	mg/L	0.0020
IR-16-1-D114-DWC-SS-23L	Drinking Water Fountain w/Cooler Room D121	12/23/2022	0.002	U	mg/L	0.0020
IR-16-1-D114-DWC-f-23L	Drinking Water Fountain w/Cooler Room D122	12/23/2022	0.002	U	mg/L	0.0020
IR-16-1-TL-CF-P-24	Room Faucet in Teachers Lounge	12/23/2022	0.00074	J	mg/L	0.0020
IR-16-1-TL-cf-f-24	Room Faucet in Teachers Lounge	12/23/2022	0.002	U	mg/L	0.0020

NA
NA
NA
NA
NA
NA
NA

NA
NA
NA
NA
NA
NA
NA

Key - Sample Name	
P	Primary Sample
SS	Sequential Sample
F	Flush Sample

Key - Qualifier	
U	Not Detected in Laboratory
J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit