



# Public Schools of the Tarrytowns

ADMINISTRATIVE OFFICES 200 North Broadway • Sleepy Hollow, New York 10591 914-631-9404 Fax 914-332-6283

**Christopher Borsari**  
*Superintendent of Schools*  
914-631-9404  
email – [cborsari@tufsd.org](mailto:cborsari@tufsd.org)

**Pamela T. Fisk**  
*Director of Human Resources*  
914-631-9406  
email – [pfisk@tufsd.org](mailto:pfisk@tufsd.org)

**Kevin A. Ziemba**  
*School Business Administrator*  
914-631-9401  
email – [kziemba@tufsd.org](mailto:kziemba@tufsd.org)

October 21, 2016

Dear Parents, Faculty, and Staff,

In April 2016, the Public Schools of the Tarrytowns voluntarily and proactively tested water at 169 locations in all District schools and the Administration Building. These tests were performed in accordance with the Environmental Protection Agency's testing procedures, which allowed for "first draw" and "second draw" tests to determine whether or not the lead content of the water exceeded the EPA Action Level of 0.015 mg/L. Using this procedure, 13 locations were found to exceed the EPA's Action Level on a "first draw," but only two exceeded those levels on a "second draw." These two locations, water fountains at Morse and Washington Irving, were replaced over the summer, and when retested were found to be well below the EPA's levels on "first draw."

On September 6, Governor Cuomo signed a new bill into law that requires all New York schools to test drinking water for lead contamination. As the regulations were developed and communicated, we learned that only "first draw" tests would be acceptable. As a result, we retested and remediated all the water sources that were found to exceed the EPA regulations on the "first draw" in April.

In addition to the water fountains at Morse and Washington Irving which were replaced over the summer, we have removed three unused water fountains from service, added lead filters and changed faucets on three sinks at John Paulding and one sink at Sleepy Hollow Middle/High School. We have retested these locations after each remediation measure, and I am pleased to report that all water sources still in service and originally tested in April have tested below the EPA Action Level on "first draw."

As required by the new state law, our testing results have been reported to the Westchester County Department of Health and have been posted for review on our website.

The health and safety of our students and staff are our highest priority, and I will continue to keep you informed on these and other issues should they arise.

Sincerely,



Christopher Borsari

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
39B 2421762	HS Hallway Water Fountain Near 302N	Water	0.002 mg/L
40A 2421763	HS Hallway Water Fountain Near 304W Upper	Water	0.002 mg/L
40B 2421764	HS Hallway Water Fountain Near 304W Upper	Water	0.001 mg/L
41A 2421765	HS Hallway Water Fountain Near 304W Lower	Water	0.001 mg/L
41B 2421766	HS Hallway Water Fountain Near 304W Lower	Water	0.001 mg/L
42A 2421767	HS Hallway Water Fountain Near 204W Upper	Water	BDL < 0.001 mg/L
42B 2421768	HS Hallway Water Fountain Near 204W Upper	Water	0.001 mg/L
43A 2421769	HS Hallway Water Fountain Near 204W Lower	Water	0.005 mg/L
43B 2421770	HS Hallway Water Fountain Near 204W Lower	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
44A 2421771	HS Hallway Water Fountain Near 104W Upper	Water	0.004 mg/L
44B 2421772	HS Hallway Water Fountain Near 104W Upper	Water	0.001 mg/L
45A 2421773	HS Hallway Water Fountain Near 104W Lower	Water	0.001 mg/L
45B 2421774	HS Hallway Water Fountain Near 104W Lower	Water	0.001 mg/L
45A 2421775	HS Nurse's Office 110W Water Cooler	Water	BDL < 0.001 mg/L
45B 2421776	HS Nurse's Office 110W Water Cooler	Water	0.001 mg/L
46A 2421777	MS Hallway Water Fountain Near 102S Upper	Water	0.001 mg/L
46B 2421778	MS Hallway Water Fountain Near 102S Upper	Water	0.007 mg/L
47A 2421779	MS Hallway Water Fountain Near 102S Lower	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

ILHA Accreditation No. 418 Rhode Island DOH No. AAL-07273 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851


Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
47B 2421780	MS Hallway Water Fountain Near 102S Lower	Water	BDL < 0.001 mg/L
48A 2421781	MS Main Entrance Hallway Water Fountain Upper	Water	BDL < 0.001 mg/L
48B 2421782	MS Main Entrance Hallway Water Fountain Upper	Water	BDL < 0.001 mg/L
49A 2421783	MS Main Entrance Hallway Water Fountain Lower	Water	BDL < 0.001 mg/L
49B 2421784	MS Main Entrance Hallway Water Fountain Lower	Water	BDL < 0.001 mg/L
50A 2421785	MS Hallway 2nd Floor Near Stair #5 Upper	Water	BDL < 0.001 mg/L
50B 2421786	MS Hallway 2nd Floor Near Stair #5 Upper	Water	BDL < 0.001 mg/L
51A 2421787	MS Hallway 2nd Floor Near Stair #5 Lower	Water	BDL < 0.001 mg/L
51B 2421788	MS Hallway 2nd Floor Near Stair #5 Lower	Water	BDL < 0.001 mg/L

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
52A 2421789	MS 3rd Floor Hallway Water Fountain Near 302S Upper	Water	BDL < 0.001 mg/L
52B 2421790	MS 3rd Floor Hallway Water Fountain Near 302S Upper	Water	BDL < 0.001 mg/L
53A 2421791	MS 3rd Floor Hallway Water Fountain Near 302S Lower	Water	BDL < 0.001 mg/L
53B 2421792	MS 3rd Floor Hallway Water Fountain Near 302S Lower	Water	BDL < 0.001 mg/L
54A 2421793	MS Hallway Water Fountain Near Upper	Water	BDL < 0.001 mg/L
54B 2421794	MS Hallway Water Fountain Near Upper	Water	BDL < 0.001 mg/L
55A 2421795	MS Hallway Water Fountain Near Lower	Water	BDL < 0.001 mg/L
55B 2421796	MS Hallway Water Fountain Near Lower	Water	BDL < 0.001 mg/L
56A 2421797	MS 303N Sink	Water	0.001 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis  
Results Applicable to Those Items Tested

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
56B 2421798	MS 303N Sink	Water	0.004 mg/L
57A 2421799	MS Hallway Water Fountain Near CR 324S (Upper)	Water	BDL < 0.001 mg/L
57B 2421800	MS Hallway Water Fountain Near CR 324S (Upper)	Water	BDL < 0.001 mg/L
58A 2421801	MS Hallway Water Fountain Near CR 324S (Lower)	Water	BDL < 0.001 mg/L
58B 2421802	MS Hallway Water Fountain Near CR 324S (Lower)	Water	BDL < 0.001 mg/L
59A 2421803	MS Hallway Water Fountain Near Stair #2 Floor 2 (Upper)	Water	BDL < 0.001 mg/L
59B 2421804	MS Hallway Water Fountain Near Stair #2 Floor 2 (Upper)	Water	BDL < 0.001 mg/L
60A 2421805	MS Hallway Water Fountain Near Stair #2 Floor 2 (Lower)	Water	BDL < 0.001 mg/L
60B 2421806	MS Hallway Water Fountain Near Stair #2 Floor 2 (Lower)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School


Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
61 2421807	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

ALHA Accreditation No. 418 Rhode Island DOH No. AAL-07ZT3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Admin Building

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851


Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
22A 2421728	Lobby Water Cooler (Quench)	Water	BDL < 0.001 mg/L
22B 2421729	Lobby Water Cooler (Quench)	Water	BDL < 0.001 mg/L
23A 2421730	2nd Floor Lunch Room Water Cooler (Quench)	Water	0.001 mg/L
23B 2421731	2nd Floor Lunch Room Water Cooler (Quench)	Water	0.001 mg/L
24A 2421732	1st Floor Lunch Room Water Cooler (Quench)	Water	0.002 mg/L
24B 2421733	1st Floor Lunch Room Water Cooler (Quench)	Water	0.001 mg/L
25 2421734	Not Applicable	Water Blank	BDL < 0.001 mg/L



**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - John Paulding School

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2421687	Kitchen Sink #1 (Sprayer) - Left to Right	Water	0.033 mg/L
1B 2421688	Kitchen Sink #1 (Sprayer)	Water	0.001 mg/L
2A 2421689	Kitchen Sink #2	Water	0.005 mg/L
2B 2421690	Kitchen Sink #2	Water	0.001 mg/L
3A 2421691	Kitchen Sink #3	Water	0.016 mg/L
3B 2421692	Kitchen Sink #3	Water	0.001 mg/L
4A 2421693	Kitchen Sink #4	Water	0.020 mg/L
4B 2421694	Kitchen Sink #4	Water	0.003 mg/L
5A 2421695	Kitchen - Water Cooler (Quench)	Water	BDL < 0.001 mg/L

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - John Paulding School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thomwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2421696	Kitchen - Water Cooler (Quench)	Water	BDL < 0.001 mg/L
6A 2421697	Main Lobby Water Fountain	Water	0.006 mg/L
6B 2421698	Main Lobby Water Fountain	Water	0.008 mg/L
7A 2421699	2nd Floor Supply Room Water Cooler (Quench)	Water	0.001 mg/L
7B 2421700	2nd Floor Supply Room Water Cooler (Quench)	Water	0.001 mg/L
8A 2421701	Nurse's Office Main Room Sink	Water	0.356 mg/L
8B 2421702	Nurse's Office Main Room Sink	Water	0.009 mg/L
9A 2421703	Water Fountain Between CR 6 & 8 (Near Bathroom)	Water	0.030 mg/L
9B 2421704	Water Fountain Between CR 6 & 8 (Near Bathroom)	Water	0.006 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - John Paulding School


Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thomwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10A 2421705	Water Fountain in CR 10	Water	0.223 mg/L
10B 2421706	Water Fountain in CR 10	Water	0.009 mg/L
11A 2421707	Teacher's Lounge Sink	Water	0.008 mg/L
11B 2421708	Teacher's Lounge Sink	Water	0.001 mg/L
12A 2421709	Teacher's Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
12B 2421710	Teacher's Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
13A 2421711	CR A Water Fountain	Water	0.029 mg/L
13B 2421712	CR A Water Fountain	Water	0.006 mg/L
14A 2421713	CR 11 Water Fountain	Water	0.011 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - John Paulding School

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
14B 2421714	CR 11 Water Fountain	Water	0.001 mg/L
15A 2421715	CR 9 Water Fountain	Water	0.003 mg/L
15B 2421716	CR 9 Water Fountain	Water	0.001 mg/L
16A 2421717	CR 7 Water Fountain	Water	0.007 mg/L
16B 2421718	CR 7 Water Fountain	Water	0.002 mg/L
17A 2421719	CR 5 Water Fountain	Water	0.004 mg/L
17B 2421720	CR 5 Water Fountain	Water	0.001 mg/L
18A 2421721	CR 3 Water Fountain	Water	0.003 mg/L
18B 2421722	CR 3 Water Fountain	Water	0.001 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - John Paulding School


Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19A 2421723	CR 1 Water Fountain	Water	0.006 mg/L
19B 2421724	CR 1 Water Fountain	Water	0.001 mg/L
20A 2421725	CR 4 Water Fountain	Water	0.011 mg/L
20B 2421726	CR 4 Water Fountain	Water	0.001 mg/L
21 2421727	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Washington Irving School


Date Collected: 04/26/2016  
 Collected By: Ernest Coon  
 Date Received: 04/26/2016  
 Date Analyzed: 04/27/2016  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
76A 2421835	Basement Water Fountain Near Cafeteria	Water	0.005 mg/L
76B 2421836	Basement Water Fountain Near Cafeteria	Water	0.001 mg/L
77A 2421837	Kitchen Sink #1 - Left to Right	Water	0.001 mg/L
77B 2421838	Kitchen Sink #1 - Left to Right	Water	BDL < 0.001 mg/L
78A 2421839	Kitchen Sink #2 - Left to Right	Water	0.035 mg/L
78B 2421840	Kitchen Sink #2 - Left to Right	Water	BDL < 0.001 mg/L
79A 2421841	Hallway Water Fountain Near CR 215	Water	0.084 mg/L
79B 2421842	Hallway Water Fountain Near CR 215	Water	0.060 mg/L
80A 2421843	Hallway Water Fountain Near CR 205	Water	0.006 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Washington Irving School


Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
80B 2421844	Hallway Water Fountain Near CR 205	Water	0.001 mg/L
81A 2421845	Staff Lounge Sink	Water	0.001 mg/L
81B 2421846	Staff Lounge Sink	Water	0.001 mg/L
82A 2421847	Staff Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
82B 2421848	Staff Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
83A 2421849	Hallway Water Fountain Near CR 104	Water	BDL < 0.001 mg/L
83B 2421850	Hallway Water Fountain Near CR 104	Water	0.001 mg/L
84A 2421851	Nurse's Office Sink	Water	0.018 mg/L
84B 2421852	Nurse's Office Sink	Water	0.005 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Washington Irving School

Date Collected: 04/26/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
85A 2421853	Cafeteria Water Fountain	Water	BDL < 0.001 mg/L
85B 2421854	Cafeteria Water Fountain	Water	0.001 mg/L
86 2421855	Not Applicable	Water Blank	BDL < 0.001 mg/L



# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Morse School

Date Collected: 04/16/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
✓ 62A 2421808	Hallway Water Fountain Basement by Boiler Room	Water	0.094 mg/L
✓ 62B 2421809	Hallway Water Fountain Basement by Boiler Room	Water	0.113 mg/L
63A 2421810	Kitchen Sink #1 - Left to Right	Water	0.005 mg/L
63B 2421811	Kitchen Sink #1 - Left to Right	Water	0.001 mg/L
64A 2421812	Kitchen Sink #2 - Left to Right	Water	0.016 mg/L
64B 2421813	Kitchen Sink #2 - Left to Right	Water	0.002 mg/L
65A 2421814	Kitchen Sink #3 - Left to Right	Water	0.001 mg/L
65B 2421815	Kitchen Sink #3 - Left to Right	Water	BDL < 0.001 mg/L
66A 2421816	Cafeteria Water Fountain	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-07ZT3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - Morse School

Date Collected: 04/16/2016  
Collected By: Ernest Coon  
Date Received: 04/26/2016  
Date Analyzed: 04/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
66B 2421817	Cafeteria Water Fountain	Water	0.001 mg/L
67A 2421818	Staff Lounge Sink	Water	0.004 mg/L
67B 2421819	Staff Lounge Sink	Water	0.002 mg/L
68A 2421820	Staff Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
68B 2421821	Staff Lounge Water Cooler (Quench)	Water	BDL < 0.001 mg/L
69A 2421822	Hallway Water Fountain Near CR 17	Water	BDL < 0.001 mg/L
69B 2421823	Hallway Water Fountain Near CR 17	Water	0.001 mg/L
70A 2421824	Nurse's Office Water Cooler (Quench)	Water	0.001 mg/L
70B 2421825	Nurse's Office Water Cooler (Quench)	Water	0.001 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature:

  
Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
26A 2421735	HS Cafeteria Water Fountain 1	Water	BDL < 0.001 mg/L
26B 2421736	HS Cafeteria Water Fountain 1	Water	BDL < 0.001 mg/L
27A 2421737	HS Kitchen Water Cooler (Quench)	Water	BDL < 0.001 mg/L
27B 2421738	HS Kitchen Water Cooler (Quench)	Water	0.001 mg/L
28A 2421739	HS Kitchen Sink 1 (Sprayer) - Left to Right	Water	0.032 mg/L
28B 2421740	HS Kitchen Sink 1 (Sprayer) - Left to Right	Water	0.008 mg/L
29A 2421741	HS Kitchen Sink 2	Water	0.005 mg/L
29B 2421742	HS Kitchen Sink 2	Water	BDL < 0.001 mg/L
30A 2421743	HS Kitchen Sink 3 (Sprayer)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School


Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
30B 2421744	HS Kitchen Sink 3 (Sprayer)	Water	0.001 mg/L
31A 2421745	HS Kitchen Sink 4 (Sprayer)	Water	BDL < 0.001 mg/L
31B 2421746	HS Kitchen Sink 4 (Sprayer)	Water	BDL < 0.001 mg/L
32A 2421747	HS Kitchen Sink 5 (Sprayer)	Water	0.001 mg/L
32B 2421748	HS Kitchen Sink 5 (Sprayer)	Water	BDL < 0.001 mg/L
33A 2421749	Water Fountain Hallway HS/MS Gym Upper Left of Main Door as You Enter	Water	0.003 mg/L
33B 2421750	Water Fountain Hallway HS/MS Gym Upper Left of Main Door as You Enter	Water	BDL < 0.001 mg/L
34A 2421751	Water Fountain Hallway HS/MS Gym Upper Right of Main Door as You Enter	Water	BDL < 0.001 mg/L
34B 2421752	Water Fountain Hallway HS/MS Gym Upper Right of Main Door as You Enter	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AllHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1033-16-IH - Tarrytown Public Schools - High School/Middle School

Date Collected: 04/26/2016

Collected By: Ernest Coon

Date Received: 04/26/2016

Date Analyzed: 04/27/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
35A 2421753	Water Fountain Hallway HS/MS Gym Upper Right of Main Door as You Enter	Water	BDL < 0.001 mg/L
35B 2421754	Water Fountain Hallway HS/MS Gym Upper Right of Main Door as You Enter	Water	0.001 mg/L
36A 2421755	HS Water Fountain Hallway HS/MS Gym Lower Right of Main Door as You Enter	Water	BDL < 0.001 mg/L
36B 2421756	HS Water Fountain Hallway HS/MS Gym Lower Right of Main Door as You Enter	Water	BDL < 0.001 mg/L
37A 2421757	HS Music Hallway Water Fountain Upper	Water	BDL < 0.001 mg/L
37B 2421758	HS Music Hallway Water Fountain Upper	Water	BDL < 0.001 mg/L
38A 2421759	HS Music Hallway Water Fountain Lower	Water	BDL < 0.001 mg/L
38B 2421760	HS Music Hallway Water Fountain Lower	Water	BDL < 0.001 mg/L
39A 2421761	HS Hallway Water Fountain Near 302N	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-10XX-16-IH

Date Collected: 06/02/2016  
Collected By: Nicholas Coon  
Date Received: 06/02/2016  
Date Analyzed: 06/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2429165	Washington Kitchen Sink #2	Water	BDL < 0.001 mg/L
1B 2429166	Washington Kitchen Sink #2	Water	BDL < 0.001 mg/L
2A 2429167	Washington Nurse Sink	Water	0.003 mg/L
2B 2429168	Washington Nurse Sink	Water	BDL < 0.001 mg/L
3A 2429169	Washington Water Fountain by 215 - Halsey-Taylor	Water	0.014 mg/L
3B 2429170	Washington Water Fountain by 215 - Halsey-Taylor	Water	0.012 mg/L
4A 2429171	Morse Elementary Kitchen Sink #2 (From Left to Right)	Water	0.012 mg/L
4B 2429172	Morse Elementary Kitchen Sink #2 (From Left to Right)	Water	0.003 mg/L
5A 2429173	Morse Elementary Water Fountain by Boiler Room - Water was Turned Off for 24 Hours Due to Pipe Break/Elkay Brand	Water	36.318 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-10XX-16-IH


Date Collected: 06/02/2016

Collected By: Nicholas Coon

Date Received: 06/02/2016

Date Analyzed: 06/03/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2429174	Morse Elementary Water Fountain by Boiler Room - Water was Turned Off for 24 Hours Due to Pipe Break/Elkay Brand	Water	7.223 mg/L
6A 2429175	H.S. Sink #1 Spayer/Kitchen (From Left to Right)	Water	0.019 mg/L
6B 2429176	H.S. Sink #1 Spayer/Kitchen (From Left to Right)	Water	0.004 mg/L
7A 2429177	Paulding Kitchen Sink #1 (From Left to Right)	Water	0.013 mg/L
7B 2429178	Paulding Kitchen Sink #1 (From Left to Right)	Water	BDL < 0.001 mg/L
8A 2429179	Paulding Kitchen Sink #3 (From Left to Right)	Water	0.006 mg/L
8B 2429180	Paulding Kitchen Sink #3 (From Left to Right)	Water	BDL < 0.001 mg/L
9A 2429181	Paulding Kitchen Sink #4 (From Left to Right)	Water	0.005 mg/L
9B 2429182	Paulding Kitchen Sink #4 (From Left to Right)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-10XX-16-IH

Date Collected: 06/02/2016  
Collected By: Nicholas Coon  
Date Received: 06/02/2016  
Date Analyzed: 06/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10A 2429183	Paulding Nurse Main Sink - First Draw Water was Brown	Water	0.440 mg/L
10B 2429184	Paulding Nurse Main Sink - First Draw Water was Brown	Water	0.075 mg/L
11A 2429185	Paulding Water Fountain Between Classroom 6 & 8 - Little Use Halsey W. Taylor Co.	Water	0.020 mg/L
11B 2429186	Paulding Water Fountain Between Classroom 6 & 8 - Little Use Halsey W. Taylor Co.	Water	0.003 mg/L
12A 2429187	Paulding Water Fountain Classroom 10 - Little Use Old Halsey W. Taylor Co.	Water	0.045 mg/L
12B 2429188	Paulding Water Fountain Classroom 10 - Little Use Old Halsey W. Taylor Co.	Water	0.005 mg/L
13A 2429189	Paulding Water Fountain Classroom 13 or A Halsey Taylor Co.	Water	0.016 mg/L
13B 2429190	Paulding Water Fountain Classroom 13 or A Halsey Taylor Co.	Water	0.005 mg/L
14 2429191	Not Applicable	Field Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095



# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-10XX-16-7H - Tarrytown Public Schools

Date Collected: 08/26/2016

Collected By: Ernest Coon

Date Received: 08/26/2016

Date Analyzed: 09/02/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2448772	Morse School - BR Hallway Water Fountain	Water	0.005 mg/L
1B 2448773	Morse School - BR Hallway Water Fountain	Water	0.007 mg/L
2A 2448774	Washington Irving School - 2nd Floor Water Fountain/Hallway	Water	0.001 mg/L
2B 2448775	Washington Irving School - 2nd Floor Water Fountain/Hallway	Water	0.002 mg/L
3 2448776	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1118-16-IH- Tarrytown Public Schools - 210 Broadway - Sleepy Hollow, NY


Date Collected: 09/22/2016

Collected By: S. Coon

Date Received: 09/23/2016

Date Analyzed: 09/26/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2453604	(From Left to Right) High School - Kitchen Sink Sprayer #1	Water	0.022 mg/L
2 2453605	J. Paulding - (From Left to Right) Sprayer Sink #1	Water	0.016 mg/L
3 2453606	J. Paulding - (From Left to Right) Sink #3	Water	0.080 mg/L
4 2453607	Washington Irving - (From Left to Right) Kitchen Sink #2	Water	0.001 mg/L
5 2453608	Not Applicable	Field Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TPS-1129-16-IH - Tarrytown Public Schools

Date Collected: 10/07/2016

Collected By: S. Coon

Date Received: 10/07/2016

Date Analyzed: 10/10/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2457329	J. Paulding - Sink #1 (Left to Right)	2nd Test - 6:35	0.005 mg/L
2 2457330	J. Paulding - Sink #3 (Left to Right)	2nd Test - 6:36	0.001 mg/L
3 2457331	Nurses Sink	First Sample - 6:40	0.031 mg/L
4 2457332	H.S. Kitchen Sink Sprayer	2nd Test - 6:45	0.003 mg/L
5 2457333	Not Applicable	Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN TTPS-1138-16-IH - Tarrytown Public Schools - Paulding School

Date Collected: 10/14/2016  
Collected By: S. Coon  
Date Received: 10/14/2016  
Date Analyzed: 10/17/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2459133	Nurse Sink (Paulding)	Water	0.007 mg/L
2 2459134	Not Applicable	Water Blank	BDL < 0.001 mg/L