

School Building	Total Number of Outlets Sampled	Locations which Exceeded EPA Action Level (>15ppb)	Outlet Number/AHERA Map Location	Result ppb	Remedial Action Taken*
Andrew Muller Primary School	91	Classroom 29: Faucet	MILL-0514/1-39	16	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Kitchen Locker Room: Bathroom Faucet	MILL-0433/ 1-09A	59	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
Laddie A Decker Sound Beach School	82	Classroom 153: Faucet	MILL-0648/ 1-19	20	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Principal Office: Bathroom Faucet	MILL-0646/ 1-30B1	21	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Classroom 148: Faucet	MILL-0641/ 1-12	19	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Classroom 147: Faucet	MILL-0640/ 1-11	19	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Classroom 137: Faucet	MILL-0638/ 1-08	63	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Classroom 139: Faucet	MILL-0636/ 1-06	24	Added Water Filter, Certified Lead-free Faucet, and New Supply Line
		Library: Faucet	MILL-0629/ 1-35	23	Added Certified Lead-free Aerator
		Kitchen Bathroom: Faucet	MILL-0556/ 0-62A1	51	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Kitchen: Faucet	MILL-0552/ 0-62	19	Added Certified Lead-free Faucet and Aerator, and New Supply Line**
		Kitchen: Steam Kettle Faucet	MILL-0550/ 0-62	110	Removed from Service***
Miller Place High School	67	Kitchen: Hand Wash Faucet	MILL-0549/ 0-62	16	Added Water Filter
Miller Place High School		Mens Bathroom by 112: Faucet	MILL-0155/ 1012	44	Added Certified Lead-free Aerator
		Principal Office: Bathroom Faucet	MILL-0121/ 1028B	150	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Nurse Bathroom: Faucet	MILL-0119/ 1039A	16	Added Water Filter
		Nurse Bathroom: Faucet	MILL-0118/ 1039B	77	Added Water Filter
		Classroom 131: Faucet	MILL-0110/ 1042	25	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Classroom 131: Faucet	MILL-0109/ 1042	150	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Classroom 131: Faucet	MILL-0108/ 1042	32	Added Certified Lead-free Faucet and Aerator, and New Supply Line
		Athletic Office: Faucet	MILL-0107/ 1049B	28	Added Certified Lead-free Aerator
		Trainers Room Bathroom: Faucet	MILL-0042/ 1172A1	19	Added Certified Lead-free Aerator and Certified Lead-free Faucet
		Trainers Room Bathroom: Fountain	MILL-0039/ 1072	71	Removed from Service****
		Kitchen Hand Wash Sink: Faucet	MILL-0012/ 1056	46	Added Water Filter
Kitchen: Pot Filler	MILL-0009/ 1056J	240	Removed from Service*****		
Kitchen Hand Wash Sink: Faucet	MILL-0005/ 1056J	37	Added Water Filter		
Kitchen Hand Wash Sink: Faucet	MILL-0003/ 1056I	36	Added Water Filter		

* Placards placed at all locations stating "Caution Non-Potable Water Not for Drinking" until test can confirm lead level ≤ 15 ppb

** Removed from service until testing confirms ppb is less than EPA level ≤ 15 ppb

*** Removed from service until correct faucet type can be located, installed, and tested ≤ 15 ppb

**** Lead Free Bottle Filler will be installed. Requires plumbing and masonry work. Will remain out of service until completed and tested ≤ 15 ppb

***** Permanently removed from service and water line capped. Has not been used in years and no longer needed