

JMSI Environmental Corp

284 Dennison Street Suite B Swoyersville, PA 18704 Jeff@JMSIenviro.com
(800) 828-1482 (570) 288-1037 Fax (570) 288-1068

December 7, 2014

RE: TEM Air Sample Results

Lehigh Area School District
Mr. Jonathan J. Cleaver
1000 Union Street
Lehigh, PA 18235

Mr. Cleaver:

Attached you will find the laboratory report relative to the clearance TEM asbestos air samples which were collected from numerous areas of the Middle School C Wing 1st Floor following the asbestos abatement project which was conducted on Friday and Saturday.

The laboratory analysis revealed that all 10 samples were found to be none detected for airborne asbestos structures. At this time Sargent Enterprises will remove the containment and all equipment, your staff can now begin to return the area to its original condition.

Please feel free to contact me with any questions or concerns regarding this information.

Sincerely:


Jeff J. Milletr

**“Specializing in Asbestos Consulting and Testing, Lead Based Paint Inspections,
Mold Testing and Remediation, Right-to-Know Compliance Programs,
Indoor Air Quality Testing and Housing Rehabilitation Consulting”**

**EMSL Analytical, Inc.**

521 Plymouth Road, Suite 107, Plymouth Meeting, PA 19462

Phone/Fax: (610) 828-3102 / (610) 828-3122

<http://www.EMSL.com>plymouthmeetinglab@emsl.com

EMSL Order: 181402859

CustomerID: JMIL50

CustomerPO: cc 000442

ProjectID:

Attn: **Jeff Miller**
JMSI Environmental Corp
284 Dennison Street
Suite B
Swoyersville, PA 18704

Phone: (570) 288-1037
Fax: (570) 288-1068
Received: 12/07/14 2:20 PM
Analysis Date: 12/7/2014
Collected: 12/7/2014

Project: **Lehighton Area School District - Middle School**

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥ 0.5μ	< 5μ		(S/mm ²)	(S/cc)
1207-01 181402859-0001	Room C106	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-02 181402859-0002	Room C108	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-03 181402859-0003	Room C109	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-04 181402859-0004	Room C112	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-05 181402859-0005	Room C113	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-06 181402859-0006	Room C114	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-07 181402859-0007	Room C115	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-08 181402859-0008	1st Floor Corridor C by D Hall	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-09 181402859-0009	1st Floor Corridor C by Room C112	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1207-10 181402859-0010	1st Floor Corridor C by Room C115	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041

Analyst(s)

Michael Thoma (10)


Michael Thoma, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA NVLAP Lab Code 200699-0, Philadelphia 292, VA 3333 00315, Massachusetts AA000230

Initial report from 12/07/2014 18:11:36

(800) 828-1482 Fax (570) 288-1068 Email Jeff@jmsienviro.com

Project: Lehigh Area School District-Middle School **Date:** 12-7-14 **Turn Around Time:** 6 hour

Relinquished By	Date	Received By	Date
<i>Beck Janov</i>	<i>12-07-2014</i>	<i>M/J</i>	<i>12-7-14</i> <i>2:00 pm</i>

Dropbox