

JMSI Environmental Corp

284 Dennison Street Suite B Swoyersville, PA 18704 Jeff@JMSIenviro.com
(800) 828-1482 (570) 288-1037 Fax (570) 288-1068

December 14, 2014

RE: TEM Air Sample Results


Lehigh Area School District
Mr. Jonathan J. Cleaver
1000 Union Street
Lehigh, PA 18235

Mr. Cleaver:

Attached you will find the laboratory report relative to the clearance TEM asbestos air samples which were collected from numerous areas of the Middle School C Wing 1st and 2nd Floors following the asbestos abatement project which was conducted on Friday and Saturday.

The laboratory analysis revealed that all 6 samples were found to be none detected for airborne asbestos structures. At this time Sargent Enterprises will remove the containment and all equipment, your staff can now begin to return the area to its original condition.

Please feel free to contact me with any questions or concerns regarding this information.

Sincerely:

Jeff J. Miller

**“Specializing in Asbestos Consulting and Testing, Lead Based Paint Inspections,
Mold Testing and Remediation, Right-to-Know Compliance Programs,
Indoor Air Quality Testing and Housing Rehabilitation Consulting”**

**EMSL Analytical, Inc.**

521 Plymouth Road, Suite 107, Plymouth Meeting, PA 19462

Phone/Fax: (610) 828-3102 / (610) 828-3122

<http://www.EMSL.com>plymouthmeetinglab@emsl.com

EMSL Order: 181402920

CustomerID: JMIL50

CustomerPO: CC 000455

ProjectID:

Attn: **Jeff Miller**
JMSI Environmental Corp
284 Dennison Street
Suite B
Swoyersville, PA 18704

Phone: (570) 288-1037
Fax: (570) 288-1068
Received: 12/14/14 1:00 PM
Analysis Date: 12/14/2014
Collected: 12/14/2014


Project: **Lehighon Area School District-Middle School**

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						$\geq 0.5\mu$	$< 5\mu$		(S/mm ²)	(S/cc)
1214-01 181402920-0001	Room C208	1800.00	0.0520	0	None Detected			0.0041	<19.00	
1214-02 181402920-0002	Room C210	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1214-03 181402920-0003	2nd Flor Corridor C North	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1214-04 181402920-0004	Room C103	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1214-05 181402920-0005	1st Floor Corridor C North	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041
1214-06 181402920-0006	1ST Floor Corridor C South	1800.00	0.0520	0	None Detected			0.0041	<19.00	<0.0041

Analyst(s)

Kevin Ream (6)


Michael Thoma, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA NVLAP Lab Code 200699-0, Philadelphia 292, VA 3333 00315, Massachusetts AA000230

Initial report from 12/14/2014 16:36:40

JMSI Environmental Corp

(800) 828-1482 Fax (570) 288-1068 Email Jeff@jmsienviro.com

Project: Lehigh Area School District-Middle School **Date:** 12-14-14 **Turn Around Time:** 6 hour

Relinquished By	Date	Received By	Date
Rich Javor	12-14-2014	Tim Rom	12/14/14 1:30pm