

Aloha HS

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	22431186-001KF21A	Main	Kitchen	Kitchen Food Prep	0.33
002	22431186-002KF21A	Main	Kitchen	Kitchen Food Prep	0.852
003	22431186-003KF21A	Main	Kitchen	Kettle Fill	2.08
004	22431186-004WB21A	Main	Boys Locker Room	Water Bottle Fill	ND
005	22431186-005DW21A	Main	Boys Locker Room	Drinking Fountain	ND
006	22431186-006SF21A	Main	Boys Locker Room Office	Staff Sink	0.296
007	22431186-007SF21A	Main	Girls Locker Room Office	Staff Sink	0.214
008	22431186-008WB21A	Main	Girls Locker Room	Water Bottle Fill	1.03
009	22431186-009DW21A	Main	Girls Locker Room	Drinking Fountain	0.862
010	22431186-010WB21A	Main	Athletics Hallway	Water Bottle Fill	ND
011	22431186-011DW21A	Main	Athletics Hallway	Drinking Fountain	ND
012	22431186-012SF21A	Main	Athletics Conference Room	Staff Sink	1.35
013	22431186-013DW21A	Main	Lower-level Commons	Drinking Fountain	0.596
014	22431186-014WB21A	Main	Lower-level Commons	Water Bottle Fill	0.675
015	22431186-015DW21A	Main	Lower-level Commons	Drinking Fountain	0.215
016	22431186-016DW21A	Main	C Hall	Drinking Fountain	ND
017	22431186-017DW21A	Main	C Hall	Drinking Fountain	ND
018	22431186-018DW21A	Main	D Hall East	Drinking Fountain	0.316
019	22431186-019DW21A	Main	D Hall East	Drinking Fountain	0.228
020	22431186-020DW21A	Main	D Hall West	Drinking Fountain	0.22
021	22431186-021DW21A	Main	D Hall West	Drinking Fountain	ND
022	22431186-022WB21A	Main	E Hall at E-15	Water Bottle Fill	0.206
023	22431186-023DW21A	Main	E Hall at E-15	Drinking Fountain	ND
024	22431186-024CF21A	Main	E-18	Classroom Faucet	5.6
025	22431186-025DW21A	Main	E Hall at E-1	Drinking Fountain	3.09
026	22431186-026WB21A	Main	F Hall	Water Bottle Fill	0.546
027	22431186-027DW21A	Main	F Hall	Drinking Fountain	0.471
028	22431186-028OT21A	Main	Student Store	Sink	6.63
029	22431186-029DW21A	Main	C Hall at Auditorium	Drinking Fountain	0.311
030	22431186-030DW21A	Main	C Hall at Auditorium	Drinking Fountain	1.62
031	22431186-031DW21A	Main	C Hall at Auditorium	Drinking Fountain	ND
032	22431186-032WB21A	Main	C Hall at Auditorium	Water Bottle Fill	ND
033	22431186-033DW21A	Main	C Hall at Auditorium	Drinking Fountain	ND
034	22431186-034DW21A	Main	West Gym	Drinking Fountain	1.17
035	22431186-035DW21A	Main	East Gym	Drinking Fountain	7.35
036	22431186-036DW21A	Main	J Hall	Drinking Fountain	1.22
037	22431186-037CF21A	Main	A-6	Classroom Faucet	1.48
038	22431186-038DW21A	Main	Main Entrance	Drinking Fountain	0.494
039	22431186-039SF21A	Main	Staff Lounge	Staff Sink	0.743
040	22431186-040WC21A	Main	Staff lounge	Water Cooler	ND
041	22431186-041DW21A	Main	Main Office	Drinking Fountain	2.34
042	22431186 042 CF21A	B Modular	B1	Drinking Fountain Left	1.29
043	22431186 043 CF21A	B Modular	B2	Drinking Fountain Left	1.73
044	22431186 044 DW21A	Main	Auto Shop (out of service)	Drinking Fountain Left	45.3
044	22431186 044 DW21B	Main	Auto Shop (out of service)	Drinking Fountain Left	80.8
045	22431186 045 DW21A	Main	Auto Shop (out of service)	Drinking Fountain Right	37.8

045	22431186 045 DW21B	Main	Auto Shop (out of service)	Drinking Fountain Right	74.4
046	22431186 046KF21A	Baseball Concessions	Concessions	Concessions Sink Faucet	19.1
	22430900-004KF23A	Baseball Concessions	Concessions (<i>post mitigation</i>)	Concessions Sink Faucet	4.45
	22430900-004KF23B	Baseball Concessions	Concessions (<i>flush</i>)	Concessions Sink Faucet	0.214
047	22431186 047DW21A	Baseball Concessions	Exterior	Exterior	3.63
	22430900-004DW23A	Baseball Concessions (2023, replaced after vandalization)	Exterior (out of service)	Exterior	37.2
	22430900-004DW23B	Baseball Concessions	Exterior (<i>flush sample</i>) (out of service)	Exterior	1.64
048	22431186 048KF21A	Football Concessions	Concessions	Concessions Sink Faucet	3.19
049	22431186 049DW21A	Football Concessions	Exterior	Drinking Fountain	1.05
050	22431186 050KF21A	Softball Concessions	Concessions	Concessions Sink Faucet	2.66
051	22431186 051OS21A	Football Stands	Exterior	Yard Hydrant	0.523