

Morris school district  
 Alexander Hamilton Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
WF # 1	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 2	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 3	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 4	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 5	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 6	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	0.00681 mg/L	0.015 mg/L

Morris School District  
 Hillcrest Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
W.F. #1	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #2	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #3	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #4	Water Fountain	5/3/2022	First Draw	0.00322 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	< 0.001 mg/l	0.015 mg/L

Morris school District  
 Alfred Vail Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of Sample	Results	Maximum Containment Level
WF # 1	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 2	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 3	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 4	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 5	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 6	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 7	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 8	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	0.00485 mg/L	0.015 mg/L

Morris School District  
 Sussex Avenue Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of Sample	Results	Maximum Containment Level
WF # 1	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 2	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 3	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 4	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 5	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 6	Water Fountain	4/28/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	0.00505 mg/L	0.015 mg/L

Morris School District  
 Thomas Jefferson Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
W.F. #1	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #2	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #3	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. #4	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	0.00253 mg/L	0.015 mg/L

Morris School District  
 Woodland Avenue Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
W.F # 1	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F # 2	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F # 3	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	0.0136 mg/l	0.015 mg/L

Morris School District  
 Normandy Park Elementary School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of Sample	Results	Maximum Containment Level
WF # 1	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 2	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 3	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 4	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 5	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 6	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
WF # 7	Water Fountain	5/5/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kitchen Prep Sink	5/19/2022	First Draw	< 0.001 mg/l	0.015 mg/L

Morris School District  
 Frelinghuysen Middle School  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level	Corrective Action	Date Corrected
WF # 1	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 2	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 3	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 4	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 5	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 6a	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 6b	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 7	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 8	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 9	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 10	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 11	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 12	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 13	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 14	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 1 T.R.- A	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 2 T.R.- A	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 1 T.R.- B	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 2 T.R.- B	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 1 T. R - C	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # 2 T. R - C	Water Fountain	5/10/2022	First Draw	< 0.001 mg/L	0.015 mg/L		
WF # wood shop	Water Fountain	5/10/2022	First Draw	0.0204 mg/L	0.015 mg/L	removed	5/18/22
Kitchen	Kitchen Prep Sink	5/10/2022	First Draw	0.00320mg/L	0.015 mg/L		



Morris School District  
Morristown High School  
Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
WF # 1	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 2	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 3	Water Fountain	5/12/2022	First Draw	0.001 mg/L	0.015 mg/L
WF # 4A	Water Fountain	5/12/2022	First Draw	0.001 mg/L	0.015 mg/L
WF # 4B	Water Fountain	5/12/2022	First Draw	0.00129 mg/L	0.015 mg/L
WF # 5	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 6	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 7	Water Fountain	5/12/2022	First Draw	0.00106 mg/L	0.015 mg/L
WF # 8	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 9	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 10	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 11	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 12	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 13	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 14	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 15	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 2A	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 1A	Water Fountain	5/12/2022	First Draw	< 0.001 mg/L	0.015 mg/L
Kitchen 1A	Kitchen Prep Sink	5/12/2022	First Draw	0.00282 mg/L	0.015 mg/L
Kitchen 1B	Kitchen Prep Sink	5/12/2022	First Draw	0.0017 mg/L	0.015 mg/L
WF # 16	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 17	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 18	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 19	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 20	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 21	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
Wf # 22	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 23	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 24	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 25	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 3A	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L
WF # 4A	Water Fountain	5/17/2022	First Draw	< 0.001 mg/L	0.015 mg/L

Morris School District  
 Athletic Fields  
 Drinking Water Testing - 2022 School Year

Field	Location	Description	Date of Sample	Type of sample	Results	Contaniment	Corrective Action
Harter Road	Wf # 1	Water Fountair	5/17/2022	First Draw	0.0217 mg/L	0.015 mg/L	Filter Added Aug. 2022
Harter Road	WF # 2	Water Fountair	5/17/2022	First Draw	0.011 mg/L	0.015 mg/L	Filter Added Aug. 2022
Harter Road	WF # 3	Water Fountair	5/17/2022	First Draw	0.0231 mg/L	0.015 mg/L	Filter Added Aug. 2022
High School	WF by visitors Bleachers	Water Fountair	5/24/2022	First Draw	0.00821 mg/L	0.015 mg/L	
High School	Bubbler by concession	Bubbler	5/24/2022	First Draw	0.0287 mg/L	0.015 mg/L	Filter Added Aug. 2022
Frelinghuysen	WF between F1 & F2	Water Fountair	5/24/2022	First Draw	0.000714 mg/L	0.015 mg/L	

August 2022 Update

Field	Location	Description	Date of Sample	Type of sample	Results	Contaniment	Corrective Action
Harter Road	Wf # 1	Water Fountair	8/8/2022	First Draw	< 0.001 mg/L	0.015 mg/L	Filter Added Aug. 2022
Harter Road	WF # 2	Water Fountair	8/8/2022	First Draw	.00368 mg/L	0.015 mg/L	Filter Added Aug. 2022
Harter Road	WF # 3	Water Fountair	8/8/2022	First Draw	< 0.001 mg/L	0.015 mg/L	Filter Added Aug. 2022
High School	Bubbler by concession	Bubbler	8/8/2022	First Draw	< 0.001 mg/L	0.015 mg/L	Filter Added Aug. 2022

Morris School District  
 Lafayette Learning Center  
 Drinking Water Testing - 2022 School Year

Location	Description	Date of Sample	Type of sample	Results	Maximum Containment Level
W.F # 1	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
W.F. # 2	Water Fountain	5/3/2022	First Draw	< 0.001 mg/l	0.015 mg/L
Kitchen	Kithen Prep Sink	5/19/2022	First Draw	0.00444 mg/L	0.015 mg/L