

Calvert Middle School

2022-2023 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	1	DF	left fountain outside 134	FD	3/21/23	6:00pm	3/22/23	6:03am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	2	DF	right fountain outside 134	FD	3/21/23	6:00pm	3/22/23	6:03am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	3a	DF	Bottle Filler outside cafeteria	FD	3/21/23	6:00pm	3/22/23	5:57am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	5/15/23	1	3b	DF	Bottle Filler fountain outside cafeteria	FD	4/11/23	8:00pm	4/12/23	5:42am	4/17/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	5	DF	left fountain outside gym	FD	3/21/23	6:00pm	3/22/23	6:01am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	6	DF	right fountain outside gym	FD	3/21/23	6:00pm	3/22/23	6:01am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	7	DF	left fountain outside 118	FD	3/21/23	6:00pm	3/22/23	6:12am	3/31/23	1.0	NO

Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	8	DF	right fountain outside 118	FD	3/21/23	6:00pm	3/22/23	6:12am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	9	DF	left fountain outside 115	FD	3/21/23	6:00pm	3/22/23	6:14am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	10	DF	right fountain outside 115	FD	3/21/23	6:00pm	3/22/23	6:14am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	11	DF	left fountain outside guidance	FD	3/21/23	6:00pm	3/22/23	6:23am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	12	DF	right fountain outside guidance	FD	3/21/23	6:00pm	3/22/23	6:23am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	13	DF	left fountain outside 201	FD	3/21/23	6:00pm	3/22/23	5:55am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	14	DF	right fountain outside 201	FD	3/21/23	6:00pm	3/22/23	5:55am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	15a	DF	Bottle filler outside 212	FD	3/21/23	6:00pm	3/22/23	5:50am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	5/15/23	2	15b	DF	Bottle filler fountain outside 212	FD	4/11/23	8:00pm	4/12/23	5:46am	4/17/23	<1.0	NO
Water Testing	Calvert Middle School	4/13/23	2	17	DF	left fountain outside 223	FD	3/21/23	6:00pm	3/22/23	6:02am	3/31/23	<1.0	NO

Laboratory of MD														
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	18	DF	right fountain outside 223	FD	3/21/23	6:00pm	3/22/23	6:02am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	21	DF	left fountain girNo locker room	FD	3/21/23	6:00pm	3/22/23	6:08am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	22	DF	right fountain girNo locker room	FD	3/21/23	6:00pm	3/22/23	6:08am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	23	CR	cold faucet in 132	FD	3/21/23	6:00pm	3/22/23	5:44am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	24	CR	cold faucet in 134	FD	3/21/23	6:00pm	3/22/23	5:45am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	25	CR	cold faucet in staff lounge	FD	3/21/23	6:00pm	3/22/23	5:47am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	26	IM	ice machine in staff lounge	FD	3/21/23	6:00pm	3/22/23	5:48am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	27	KS	sprayer in dish room	FD	3/21/23	6:00pm	3/22/23	5:49am	3/31/23	4.7	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	28	KS	left cold faucet 3 compartment sink	FD	3/21/23	6:00pm	3/22/23	5:50am	3/31/23	<1.0	NO

Water Testing Laboratory of MD	Calvert Middle School	5/15/23	1	29	KS	right cold faucet 3 compartment sink	FD	4/11/23	8:00pm	4/12/23	5:37am	4/17/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	30	KS	sprayer 2 compartment sink	FD	3/21/23	6:00pm	3/22/23	5:51am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	5/15/23	1	31	KS	cold faucet 2 compartment sink	FD	4/11/23	8:00pm	4/12/23	5:38am	4/17/23	2.3	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	32	KS	solo cold faucet	FD	3/21/23	6:00pm	3/22/23	5:53am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	33	IM	ice machine in kitchen	FD	3/21/23	6:00pm	3/22/23	5:53am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	34	KS	kettle filler	FD	3/21/23	6:00pm	3/22/23	5:53am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	5/15/23	1	35	CR	cold faucet 116	FD	4/11/23	8:00pm	4/12/23	5:44am	4/17/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	36	CR	cold faucet 125	FD	3/21/23	6:00pm	3/22/23	6:10am	3/31/23	4.7	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	37	CR	cold faucet in 123	FD	3/21/23	6:00pm	3/22/23	6:10am	3/31/23	<1.0	NO

Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	38	CR	cold faucet 121	FD	3/21/23	6:00pm	3/22/23	6:16am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	39	CR	cold faucet in 112	FD	3/21/23	6:00pm	3/22/23	6:15am	3/31/23	2.3	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	40	CR	cold faucet in 103	FD	3/21/23	6:00pm	3/22/23	5:49am	3/31/23	1.4	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	41	CR	cold faucet in 101	FD	3/21/23	6:00pm	3/22/23	5:48am	3/31/23	1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	42	NO	cold faucet in health room	FD	3/21/23	6:00pm	3/22/23	5:47am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	43	DF	Quench cold water	FD	3/21/23	6:00pm	3/22/23	5:45am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	44	CR	cold faucet in work room	FD	3/21/23	6:00pm	3/22/23	5:45am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	1	45	CR	cold faucet in media center office	FD	3/21/23	6:00pm	3/22/23	6:25am	3/31/23	4.4	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	46	CR	left solo cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:56am	3/31/23	1.3	NO
Water Testing	Calvert Middle School	4/13/23	2	47	CR	far left cold faucet 201		3/21/23	6:00pm	3/22/23	5:57am	3/31/23	1.1	NO

Laboratory of MD														
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	48	CR	left middle cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:57am	3/31/23	26.1	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	49	CR	middle left cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:58am	3/31/23	1.4	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	50	CR	middle right cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:58am	3/31/23	1.1	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	51	CR	far right cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:59am	3/31/23	2.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	52	CR	teacher cold faucet 201	FD	3/21/23	6:00pm	3/22/23	5:59am	3/31/23	1.8	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	53	CR	cold faucet 206	FD	3/21/23	6:00pm	3/22/23	5:54am	3/31/23	2.8	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	54	CR	front cold faucet 203	FD	3/21/23	6:00pm	3/22/23	5:53am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	55	CR	back cold faucet 203	FD	3/21/23	6:00pm	3/22/23	5:53am	3/31/23	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	4/13/23	2	56	CR	cold faucet 205	FD	3/21/23	6:00pm	3/22/23	5:52am	3/31/23	<1.0	NO

