

Windy Hill Middle School

2022-2023 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	1	DF	left fountain outside of office	FD	3/14/23	8:00pm	3/15/2023	5:39am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	2	DF	right fountain outside of office	FD	3/14/23	8:00pm	3/15/2023	5:39am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	3a	DF	bottle filler outside gym	FD	3/14/23	8:00pm	3/15/2023	5:54am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	3b	DF	bottle filler fountain outside gym	FD	4/11/23	8:00pm	4/12/23	6:10am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	5	DF	left fountain in boys locker room	FD	4/11/23	8:00pm	4/12/23	6:30am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	6	DF	right fountain in boys locker room	FD	4/11/23	8:00pm	4/12/23	6:30am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	7	DF	left fountain in girls locker room	FD	4/11/23	8:00pm	4/12/23	6:28am	4/17/23	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	8	DF	right fountain in girls locker room	FD	4/11/23	8:00pm	4/12/23	6:28am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	9	DF	left fountain outside 117	FD	3/14/23	8:00pm	3/15/2023	6:01am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	10	DF	right fountain outside 117	FD	3/14/23	8:00pm	3/15/2023	6:01am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	11a	DF	bottle filler outside 126	FD	3/14/23	8:00pm	3/15/2023	5:44am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	11b	DF	bottle filler fountain outside 126	FD	4/11/23	8:00pm	4/12/23	6:15am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	12	CR	Faucet in 120	FD	3/14/23	8:00pm	3/15/2023	5:45am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	2	13a	DF	Bottle filler outside 222	FD	3/14/23	8:00pm	3/15/2023	5:35am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	2	13b	DF	Bottle filler fountain outside 222	FD	4/11/23	8:00pm	4/12/23	6:20am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	2	14	DF	Quench cold water	FD	3/14/23	8:00pm	3/15/2023	5:41am	3/25/23	<1.0	No
Water Testing	Windy Hill Middle School	4/13/23	1	15	CR	cold faucet in office work room	FD	3/14/23	8:00pm	3/15/2023	5:41am	3/25/23	<1.0	No

Laboratory of MD														
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	16	NO	cold faucet in health room	FD	3/14/23	8:00pm	3/15/2023	5:47am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	17	IM	ice machine in health room	FD	3/14/23	8:00pm	3/15/2023	6:16am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	18	TL	cold faucet in staff lounge	FD	3/14/23	8:00pm	3/15/2023	5:43am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	19	CR	cold faucet in 107	FD	3/14/23	8:00pm	3/15/2023	5:45am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	20	CR	cold faucet in 109	FD	3/14/23	8:00pm	3/15/2023	5:46am	3/25/23	2.3	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	21	IM	ice machine in kitchen	FD	3/14/23	8:00pm	3/15/2023	5:48am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	22	KS	solo cold faucet on prep table	FD	3/14/23	8:00pm	3/15/2023	5:48am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	23	KS	cold faucet on 2 compartment sink	FD	3/14/23	8:00pm	3/15/2023	5:50am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	24	KS	sprayer on 2 compartment sink	FD	3/14/23	8:00pm	3/15/2023	5:50am	3/25/23	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	25	KS	left kettle	FD	3/14/23	8:00pm	3/15/2023	5:51am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	26	KS	right kettle	FD	3/14/23	8:00pm	3/15/2023	5:51am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	27	KS	left cold faucet 3 compartment sink	FD	3/14/23	8:00pm	3/15/2023	5:52am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	5/15/23	1	28	KS	right cold faucet 3 compartment sink	FD	4/11/23	8:00pm	4/12/23	6:05am	4/17/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	29	KS	right dish washer sprayer	FD	3/14/23	8:00pm	3/15/2023	5:53am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	30	HE	front left cold faucet 115	FD	3/14/23	8:00pm	3/15/2023	5:50am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	31	HE	front right cold faucet 115	FD	3/14/23	8:00pm	3/15/2023	5:50am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	33	HE	middle left cold faucet 115	FD	4/11/23	8:00pm	3/15/2023	5:51am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	34	HE	middle right cold faucet 115	FD	4/11/23	8:00pm	3/15/2023	5:51am	3/25/23	<1.0	No

Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	35	HE	back left cold faucet 115	FD	3/14/23	8:00pm	3/15/2023	5:52am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	36	HE	back right cold faucet 115	FD	3/14/23	8:00pm	3/15/2023	5:52am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	37	IM	ice machine in back right fridge	FD	3/14/23	8:00pm	3/15/2023	5:53am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	38	HE	teacher prep cold faucet	FD	3/14/23	8:00pm	3/15/2023	5:53am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	39	CR	left cold faucet 119	FD	3/14/23	8:00pm	3/15/2023	5:48am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	40	CR	right cold faucet 119	FD	3/14/23	8:00pm	3/15/2023	5:48am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	41	CR	cold faucet 118	FD	3/14/23	8:00pm	3/15/2023	5:47am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	42	CR	cold faucet in room between 122 and 124	FD	3/14/23	8:00pm	3/15/2023	5:45am	3/25/23	<1.0	No
Water Testing Laboratory of MD	Windy Hill Middle School	4/13/23	1	43	CR	cold faucet in media center work room	FD	3/14/23	8:00pm	3/15/2023	5:43am	3/25/23	<1.0	No
Water Testing	Windy Hill Middle School	4/13/23	2	44	CR	cold faucet 211	FD	3/14/23	8:00pm	3/15/2023	5:40am	3/25/23	<1.0	No

