



ENGINEER
CONSULT
MANAGE

DELIVERING YOUR PROJECTS WITH INNOVATION & INTEGRITY

February 14, 2022

Dan Watson
Director of Facilities
Greenwich Public Schools
290 Greenwich Avenue
Greenwich, CT 06830

Subject: **GREENWICH CENTRAL MIDDLE SCHOOL**

Dear Mr. Watson,

This provides you with DTC's schedule for safe operation of the school as it relates to DTC structural concerns for life safety.

Pedestrian traffic in and around the school are safe from potential falling facade block and debris following the installation and acceptance of bridging work. At that point the building is structurally safe to occupy.

The District is implementing exigent repairs to wall ties following completion of bridging work. Wall tie repairs add a redundant assembly that stabilizes facades from pulling away from the structure. The system is serviceable for 5-years. Completion of wall tie work satisfies DTC's life safety concerns noted in our various letters and report. The building will be structurally safe to occupy and operate following installation of bridging. The bridging can be removed after wall tie repairs are complete.

Please call or email me if you have any questions or need additional information. My cell phone number is (603) 400-5455 and my email is cory.attra@teamdte.com.

Very truly yours,

DTC, INC.

B. Cory Attra, PE, SI, M.ASCE
Chief Engineer in Responsible Charge

cc: Bob Hammersley, DTC
Katie Bosnan, DTC

Information contained in this document is proprietary and confidential and may not be disseminated to any party other than the intended recipient without the written consent of DTC.

2321 WHITNEY AVENUE, HAMDEN CONNECTICUT 06518

203 239 4200

www.teamdte.com