

**PROJECT: Lakewood Elementary School
Kitchen Renovation and Freezer Installation**

Lakewood Elementary School
9370 Lancer Road
Hebron, OH 43025

ADDENDUM 1

Revision to **Construction Documents**
ISSUE DATE: March 24, 2023

The following revisions modify the statements in the Construction Documents and/or Pre Bid Specifications. This amended information takes precedence over the previous Construction Documents and/or Pre Bid Specifications statements.

1. Modification/Clarification to **CONSTRUCTION DOCUMENTS:**

a) **HOOD SPECIFICATION**

- 1) Control cabinet and fire suppression to be on the left-hand side facing the hood.
- 2) Makeup air unit gas pressure design to be revised to be capable of accepting 6" – 8" WC gas pressure.

b) **SHEET PH-1**

- 1) Hood elevation: roof deck above hood is at 9' 0" not 9' 6" .
- 2) For the supply air plenum to the hood, field adjust and drop the plenum down 3" +- to allow for duct connections. Drop ceiling down 3" +-. Wrap the supply plenum with stainless steel to conceal the sides of the plenum and collars, etc. See attached sketch.

c) **SHEET E-1**

- 1) Provide new 2 x 4 lay-in LED lighting with a dimming On/Off switch. See attached plan.