

School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

Instructions

- 1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
- 2. Include this form, raw data (e.g. laboratory report) and a building map.
- 3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
- 4. Email information to health.indoorair@state.mn.us.

Contact Information

Name: Wendy German	
	Douglas Rd S. Cottage Grove, MN 55016
Phone: 651-425-6277	Email: Wgerman@sowushco.org

Initial Radon Testing Information

School Building Name: Woodbury Midd	Ht School
School Building Name: Woodbury Midd School District & District Number: South Way	hington County Schools - District 833
Building Address: 1425 School Drive,	Woodbury, MN 55125
Test Kit Manufacturer: AIr Chek	Device Name: Pro Chek
Date of Kit Retrieval (DD/MM/YY): 28/02/20	Length of Test (days): 3
How many rooms were tested? 39	
Does the test period include weekends?	es 💢 No
Does the test period include school breaks or h	olidays? □ Yes □ No

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact ro		es 🗷 No
If no, did you attempt to test all frequentest kits were placed in all these rooms?	reduce. Versa	ntact rooms, meaning
How many rooms had results ≥ 4 pCi/L?: D		
Were the results reported at a school board me	eeting? □ □ Yes □ N	lo
Follow-up Testing, Mitigation, & If one or more rooms tested ≥ 4 pCi/L, please ans		
one of more rooms tested = 4 pely 2, pieuse una	swer the questions belo	
How many rooms had follow-up testing?:		
Number of rooms with follow-up results	≥ 4 pCi/L:	< 4 pCi/L:
Of the rooms that had test results ≥ 4 pCi/L, ho	w many rooms were:	
mitigated by HVAC balancing or operational cha	anges?:	
mitigated by installation of active soil depressur	rization:	
addressed through other corrective measures?	2:	
What was the cost of the installation and/or HV	AC service work, to mit	igate radon? \$
What is the known or anticipated annual opera-	ting cost of mitigation (estimate)? \$
After radon mitigation, how many rooms were	retested?:	,

≥ 4 pCi/L:

< 4 pCi/L:

Post mitigation results (# of rooms)

¹ This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

² 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

Radon test result report for: SOWASHCO WOODBURY MIDDLE

Kit#	Room Id	Started	Ended	pCi/L	Analyzed
9393582	A101	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.8 ± 0.4	2020-03-03
9393583	A102	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.8 ± 0.5	2020-03-03
9393560	A103	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393584	A104	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.7 ± 0.4	2020-03-03
9393585	A105	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.6 ± 0.4	2020-03-03
9393559	A106	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393586	A107	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.7 ± 0.4	2020-03-03
9393587	A108	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393565	A109 ROSS	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393566	B110	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393574	B111	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393543	B112	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393548	B113	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393544	B114	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	0.5 ± 0.4	2020-03-03
9393523	B115	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393524	B116	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	0.6 ± 0.4	2020-03-03
9393547	C130	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393553	C132	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	0.5 ± 0.4	2020-03-03
9393546	CAFETERIA	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393558	COUNSELING OFFICE	The state of the s	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393564	D120	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	0.7 ± 0.4	2020-03-03
9393552	D122	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393557	D123	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393549	D124	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393550	D125	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393555	D126	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393562	D127	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	0.8 ± 0.4	2020-03-03
9393556	D128	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393561	D129	2020-02-24 @ 4:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03
9393567	G100	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393573	G101	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.6 ± 0.4	2020-03-03
9393572	G102	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393571	G103	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393570	G104	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393568	G105	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.9 ± 0.4	2020-03-03
9393569	G106	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393554	GYM A	2020-02-24 @ 3:00 pm	2020-02-27 @ 2:00 pm	< 0.3	2020-03-03

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

** LABORATORY ANALYSIS REPORT **

March 5, 2020

Radon test result report for: SOWASHCO WOODBURY MIDDLE

Kit#	Room Id	Started	Ended	pCi/L	Analyzed
9393581	NURSE	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	0.8 ± 0.4	2020-03-03
9393580	OFFICE	2020-02-24 @ 3:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03
9393563	PRINCIPAL	2020-02-24 @ 4:00 pm	2020-02-27 @ 1:00 pm	< 0.3	2020-03-03

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498