

School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

Instructions

1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
2. Include this form, raw data (e.g. laboratory report) and a building map.
3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
4. Email information to health.indoorair@state.mn.us.

Contact Information

Name:	Wendy German
Mailing Address:	7362 East Point Douglas Rd, Cottage Grove, MN 55016
Phone:	651-425-6277
Email:	wgerman@sowashco.org

Initial Radon Testing Information

School Building Name:	Valley Crossing Elementary		
School District & District Number:	South Washington County Schools - District 833		
Building Address:	9900 Park Crossing, Woodbury, MN 55125		
Test Kit Manufacturer:	AirChek	Device Name:	ProChek
Date of Kit Retrieval (DD/MM/YY):	11/3/21	Length of Test (days):	3
How many rooms were tested?	56		
Does the test period include weekends?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Does the test period include school breaks or holidays?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact rooms tested?¹ ☒ Yes ☐ No
 If no, did you attempt to test all frequently occupied ground contact rooms, meaning test kits were placed in all these rooms? ☐ Yes ☐ No

How many rooms had results ≥ 4 pCi/L?: 0

Were the results reported at a school board meeting? ☒ Yes ☐ No

Follow-up Testing, Mitigation, & Post-Mitigation Testing

If one or more rooms tested ≥ 4 pCi/L, please answer the questions below:

How many rooms had follow-up testing?:

Number of rooms with follow-up results	≥ 4 pCi/L:	< 4 pCi/L:
--	-----------------	--------------

Of the rooms that had test results ≥ 4 pCi/L, how many rooms were:

mitigated by HVAC balancing or operational changes? :

mitigated by installation of active soil depressurization?:

addressed through other corrective measures?²:

What was the cost of the installation and/or HVAC service work, to mitigate radon? \$

What is the known or anticipated annual operating cost of mitigation (estimate)? \$

After radon mitigation, how many rooms were retested?:

Post mitigation results (# of rooms)	≥ 4 pCi/L:	< 4 pCi/L:
--------------------------------------	-----------------	--------------

¹ This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

² 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SWC 833
VALLEY CROSSING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594133	A102	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.1 ± 0.4	2021-03-15
9594134	A103	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594129	A104	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.7 ± 0.4	2021-03-15
9594135	A105	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.6 ± 0.4	2021-03-15
9594130	A106	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	2.1 ± 0.4	2021-03-15
9594131	A107	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.9 ± 0.4	2021-03-15
9594132	A108	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594141	A109	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15
9594137	A110	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.3	2021-03-15
9594138	A111	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594136	A112	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594142	A113	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.5 ± 0.3	2021-03-15
9594145	A114	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.3	2021-03-15
9594143	A132	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.3	2021-03-15
9594167	B101	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594160	B102	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594159	B103	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.4	2021-03-15
9594157	B104	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15
9594152	B106	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594151	B106	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594150	B107	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.3	2021-03-15
9594149	B108	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594148	B109	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15
9594147	B110	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.9 ± 0.3	2021-03-15
9594146	B111	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594158	B112	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594165	B113	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594166	B132	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594169	C101	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.4	2021-03-15
9594162	C102	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594161	C103	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594173	C104	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.9 ± 0.3	2021-03-15
9594164	C105	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.3	2021-03-15
9594168	C106	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.3	2021-03-15
9594163	C107	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.4	2021-03-15
9594156	C108	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594155	C109	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SWC 833
VALLEY CROSSING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594154	C110	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594153	C111	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15
9594174	C112	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.9 ± 0.4	2021-03-15
9594175	C113	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.3	2021-03-15
9594171	C114	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594176	C132	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.7 ± 0.3	2021-03-15
9594088	CAFETERIA	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.8 ± 0.3	2021-03-15
9594172	D165	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594170	D167	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594181	D172	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594144	D180	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594139	D184	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594087	GYM A	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594100	GYM B	2021-03-08 @ 12:00 pm	2021-03-11 @ 10:00 am	< 0.3	2021-03-15
9594099	GYM C	2021-03-08 @ 12:00 pm	2021-03-11 @ 10:00 am	< 0.3	2021-03-15
9594140	MEDIA CENTER	2021-03-08 @ 1:00 pm	2021-03-11 @ 11:00 am	0.9 ± 0.3	2021-03-15
9594095	NURSE	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.3	2021-03-15
9594096	NURSE 2	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.3 ± 0.3	2021-03-15
9594097	OFFICE	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.6 ± 0.3	2021-03-15
9594098	OFFICE 2	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	1.0 ± 0.4	2021-03-15
9594126	PRINCIPAL	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15
9594127	PRINCIPAL 2	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	< 0.3	2021-03-15

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SWC 833

VALLEY CROSSING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594128	A101	2021-03-08 @ 12:00 pm	2021-03-11 @ 11:00 am	0.9 ± 0.4	2021-03-16

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498