



School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

Instructions

1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
2. Include this form, raw data (e.g. laboratory report) and a building map.
3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
4. Email information to health.indoorair@state.mn.us.

Contact Information

Name: Wendy German	
Mailing Address: 7362 East Point Douglas Road S, Cottage Grove, MN 55016	
Phone: 651-425-6277	Email: wgerman@sowashco.org

Initial Radon Testing Information

School Building Name: Grey Cloud Elementary School	
School District & District Number: South Washington County Schools - District 833	
Building Address: 9525 Indian Blvd S, Cottage Grove, MN 55016	
Test Kit Manufacturer: AirChek	Device Name: ProChek
Date of Kit Retrieval (DD/MM/YY): 12/3/21	Length of Test (days): 3
How many rooms were tested? 55	
Does the test period include weekends? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Does the test period include school breaks or holidays? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact rooms tested? ¹ <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If no, did you attempt to test all frequently occupied ground contact rooms, meaning test kits were placed in all these rooms? <input type="checkbox"/> Yes <input type="checkbox"/> No
How many rooms had results ≥ 4 pCi/L?: 0
Were the results reported at a school board meeting? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Follow-up Testing, Mitigation, & Post-Mitigation Testing

If one or more rooms tested ≥ 4 pCi/L, please answer the questions below:

How many rooms had follow-up testing?:		
Number of rooms with follow-up results	≥ 4 pCi/L:	< 4 pCi/L:
Of the rooms that had test results ≥ 4 pCi/L, how many rooms were:		
mitigated by HVAC balancing or operational changes? :		
mitigated by installation of active soil depressurization?:		
addressed through other corrective measures? ² :		
What was the cost of the installation and/or HVAC service work, to mitigate radon? \$		
What is the known or anticipated annual operating cost of mitigation (estimate)? \$		
After radon mitigation, how many rooms were retested?:		
Post mitigation results (# of rooms)	≥ 4 pCi/L:	< 4 pCi/L:

¹ This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

² 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SWC 833
GREY CLOUD

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594277	001	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594290	002A	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594281	002B	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.6 ± 0.3	2021-03-16
9594258	003	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594267	004A	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594257	004B	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594270	005	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.6 ± 0.4	2021-03-16
9594271	006	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.4 ± 0.4	2021-03-16
9594285	100	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594269	101	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.3	2021-03-16
9594264	102	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.2 ± 0.3	2021-03-16
9594273	115	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594274	116	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594275	117	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594272	118	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594276	119	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594279	120	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594289	121	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	0.9 ± 0.4	2021-03-16
9594284	122	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	0.5 ± 0.3	2021-03-16
9594278	123	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594283	124	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594282	125	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594280	126	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594259	127	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594260	128	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.3	2021-03-16
9594261	129	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.6 ± 0.3	2021-03-16
9594265	130	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.3	2021-03-16
9594262	131	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.0 ± 0.4	2021-03-16
9594266	132	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.3 ± 0.3	2021-03-16
9594256	133	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.3 ± 0.3	2021-03-16
9594255	134	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	1.1 ± 0.3	2021-03-16
9594254	135	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.4	2021-03-16
9594253	136	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.6 ± 0.3	2021-03-16
9594252	137	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.7 ± 0.3	2021-03-16
9594251	138	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.7 ± 0.3	2021-03-16
9594248	139	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594238	140	2021-03-09 @ 10:00 am	2021-03-12 @ 10:00 am	1.1 ± 0.3	2021-03-16

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SWC 833

GREY CLOUD

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594233	159 PRINCIPAL	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594234	159 PRINCIPAL 2	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594235	162 ASST PRINCIPAL	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.5 ± 0.3	2021-03-16
9594236	162 ASST PRINCIPAL 2	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.3	2021-03-16
9594263	200	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.7 ± 0.3	2021-03-16
9594268	201	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.0 ± 0.3	2021-03-16
9594249	300	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.9 ± 0.4	2021-03-16
9594246	301	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.7 ± 0.3	2021-03-16
9594247	302	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.4 ± 0.4	2021-03-16
9594245	303	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.2 ± 0.3	2021-03-16
9594244	304	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.4 ± 0.3	2021-03-16
9594243	305	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.5 ± 0.3	2021-03-16
9594242	306	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.7 ± 0.3	2021-03-16
9594250	COMMONS	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.3 ± 0.4	2021-03-16
9594241	GYM A	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	1.4 ± 0.4	2021-03-16
9594240	GYM B	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.9 ± 0.3	2021-03-16
9594239	GYM C	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.8 ± 0.3	2021-03-16
9594231	NURSE	2021-03-09 @ 9:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594232	NURSE 2	2021-03-09 @ 9:00 am	2021-03-12 @ 9:00 am	0.6 ± 0.3	2021-03-16
9594229	OFFICE	2021-03-09 @ 9:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594230	OFFICE 2	2021-03-09 @ 9:00 am	2021-03-12 @ 9:00 am	< 0.3	2021-03-16
9594237	STAFF	2021-03-09 @ 10:00 am	2021-03-12 @ 9:00 am	0.9 ± 0.3	2021-03-16