



School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

Instructions

1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
2. Include this form, raw data (e.g. laboratory report) and a building map.
3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
4. Email information to health.indoorair@state.mn.us.

Contact Information

Name: Wendy German	
Mailing Address: 7362 East Point Douglas Road S, Cottage Grove, MN 55016	
Phone: 651-425-6277	Email: wgerman@sowashco.org

Initial Radon Testing Information

School Building Name: District Program Center/Alternative High School	
School District & District Number: South Washington County Schools - District 833	
Building Address: 8400 E Point Douglas Rd S, Cottage Grove, MN 55016	
Test Kit Manufacturer: AirChek	Device Name: ProChek
Date of Kit Retrieval (DD/MM/YY): 12/3/21	Length of Test (days): 3
How many rooms were tested? 37	
Does the test period include weekends? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Does the test period include school breaks or holidays? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact rooms tested? ¹ <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If no, did you attempt to test all frequently occupied ground contact rooms, meaning test kits were placed in all these rooms? <input type="checkbox"/> Yes <input type="checkbox"/> No
How many rooms had results ≥ 4 pCi/L?: 0
Were the results reported at a school board meeting? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Follow-up Testing, Mitigation, & Post-Mitigation Testing

If one or more rooms tested ≥ 4 pCi/L, please answer the questions below:

How many rooms had follow-up testing?:		
Number of rooms with follow-up results	≥ 4 pCi/L:	< 4 pCi/L:
Of the rooms that had test results ≥ 4 pCi/L, how many rooms were:		
mitigated by HVAC balancing or operational changes? :		
mitigated by installation of active soil depressurization?:		
addressed through other corrective measures? ² :		
What was the cost of the installation and/or HVAC service work, to mitigate radon? \$		
What is the known or anticipated annual operating cost of mitigation (estimate)? \$		
After radon mitigation, how many rooms were retested?:		
Post mitigation results (# of rooms)	≥ 4 pCi/L:	< 4 pCi/L:

¹ This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

² 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**SWC 833
DPC/AHS**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9594207	103	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594214	104	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594219	105	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594217	106	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594215	107	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594216	108	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594221	109	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594220	110	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594201	111	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594202	112	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594218	113	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594223	115	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594228	116	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594224	117	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594211	123	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594205	124	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594212	125	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594291	126	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594292	126A NURSE	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594287	127	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594225	128	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594297	129	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594288	130	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594298	132	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	0.6 ± 0.3	2021-03-16
9594299	135	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594200	800	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
9594185	801	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324432	802	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324431	803	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324424	805	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324423	806	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324426	807	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324422	808	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
9594293	810	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324429	820	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
9594190	830	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324427	831	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16

QA
blanks

March 16, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SWC 833
DPC/AHS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
QA blank { 7324428	835	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324430	836	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
7324425	840	2021-03-09 @ 12:00 pm	2021-03-12 @ 7:00 am	< 0.3	2021-03-16
9594296	COMM ED N	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594295	COMM ED S	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594222	GYM 1	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594227	GYM 2	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594300	LOBBY	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594208	NURSE	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594213	NURSE 2	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594203	OFFICE	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594204	OFFICE 2	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594209	PRINCIPAL	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	0.7 ± 0.4	2021-03-16
9594210	PRINCIPAL 2	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594206	SCREENING ROOM	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594294	SENIOR CENTER	2021-03-09 @ 11:00 am	2021-03-12 @ 11:00 am	< 0.3	2021-03-16
9594286	SPE IAL SERVICES E	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16
9594226	SPECIAL SERVICES W	2021-03-09 @ 11:00 am	2021-03-12 @ 10:00 am	< 0.3	2021-03-16