



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Wednesday, June 7, 2023
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60820.

First Draw samples flushed by Martel Laboratories on March 28, 2022, sampled by Martel on March 29, 2022.

Project Identification: MD HB 270

School: Benjamin Stoddert Middle School

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60820 1 CLIENT SAMPLE IDENTIFICATION BSMS-1-FC-COMP Sample Date/Time 03/29/2023 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:20 CSG

MARTEL NO. 60820 2 CLIENT SAMPLE IDENTIFICATION BSMS-2-IM Sample Date/Time 03/29/2023 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:32 CSG

MARTEL NO. 60820 3 CLIENT SAMPLE IDENTIFICATION BSMS-3-KK Sample Date/Time 03/29/2023 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.20	ug/l	EPA 200.8	2	06/01/2023 16:34 CSG

MARTEL NO. 60820 4 CLIENT SAMPLE IDENTIFICATION BSMS-4-FC-COMP Sample Date/Time 03/29/2023 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:36 CSG

MARTEL NO. 60820 5 CLIENT SAMPLE IDENTIFICATION BSMS-5-FC-COMP Sample Date/Time 03/29/2023 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:39 CSG

MARTEL NO. 60820 6 CLIENT SAMPLE IDENTIFICATION BSMS-6-FC Sample Date/Time 03/29/2023 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:41 CSG

MARTEL NO. 60820 7 CLIENT SAMPLE IDENTIFICATION BSMS-7-FC Sample Date/Time 03/29/2023 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:44 CSG

MARTEL NO. 60820 8 CLIENT SAMPLE IDENTIFICATION BSMS-8-DF Sample Date/Time 03/29/2023 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 16:46 CSG



Certificate of Analysis

MARTEL NO. 60820 9 CLIENT SAMPLE IDENTIFICATION BSMS-9-DF-C Sample Date/Time 03/29/2023 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 16:49 CSG

MARTEL NO. 60820 10 CLIENT SAMPLE IDENTIFICATION BSMS-10-BF-C Sample Date/Time 03/29/2023 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 16:51 CSG

MARTEL NO. 60820 11 CLIENT SAMPLE IDENTIFICATION BSMS-11-DF Sample Date/Time 03/29/2023 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:01 CSG

MARTEL NO. 60820 12 CLIENT SAMPLE IDENTIFICATION BSMS-12-DF-C Sample Date/Time 03/29/2023 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:06 CSG

MARTEL NO. 60820 13 CLIENT SAMPLE IDENTIFICATION BSMS-13-BF-C Sample Date/Time 03/29/2023 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:09 CSG

MARTEL NO. 60820 14 CLIENT SAMPLE IDENTIFICATION BSMS-14-DF Sample Date/Time 03/29/2023 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:11 CSG

MARTEL NO. 60820 15 CLIENT SAMPLE IDENTIFICATION BSMS-15-DF-C Sample Date/Time 03/29/2023 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:14 CSG

MARTEL NO. 60820 16 CLIENT SAMPLE IDENTIFICATION BSMS-16-BF-C Sample Date/Time 03/29/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/01/2023 17:16 CSG



Certificate of Analysis

MARTEL NO. 60820 17 CLIENT SAMPLE IDENTIFICATION BSMS-17-BF-C Sample Date/Time 03/29/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 17:18 CSG

MARTEL NO. 60820 18 CLIENT SAMPLE IDENTIFICATION BSMS-18-DF-C Sample Date/Time 03/29/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 17:21 CSG

MARTEL NO. 60820 19 CLIENT SAMPLE IDENTIFICATION BSMS-19-DF Sample Date/Time 03/29/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 17:23 CSG

MARTEL NO. 60820 20 CLIENT SAMPLE IDENTIFICATION BSMS-20-FC-COMP Sample Date/Time 03/29/2023 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/01/2023 17:26 CSG

MARTEL NO. 60820 21 CLIENT SAMPLE IDENTIFICATION BSMS-21-FC Sample Date/Time 03/29/2023 06:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:34 CSG

MARTEL NO. 60820 22 CLIENT SAMPLE IDENTIFICATION BSMS-22-FC Sample Date/Time 03/29/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:46 CSG

MARTEL NO. 60820 23 CLIENT SAMPLE IDENTIFICATION BSMS-23-FC Sample Date/Time 03/29/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.92	ug/l	EPA 200.8	2	06/06/2023 14:49 CSG

MARTEL NO. 60820 24 CLIENT SAMPLE IDENTIFICATION BSMS-24-DF Sample Date/Time 03/29/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:51 CSG



Certificate of Analysis

MARTEL NO. 60820 25 CLIENT SAMPLE IDENTIFICATION BSMS-25-DF-C Sample Date/Time 03/29/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:53 CSG

MARTEL NO. 60820 26 CLIENT SAMPLE IDENTIFICATION BSMS-26-BF-C Sample Date/Time 03/29/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:56 CSG

MARTEL NO. 60820 27 CLIENT SAMPLE IDENTIFICATION BSMS-27-DF Sample Date/Time 03/29/2023 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 14:58 CSG

MARTEL NO. 60820 28 CLIENT SAMPLE IDENTIFICATION BSMS-28-DF-C Sample Date/Time 03/29/2023 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:01 CSG

MARTEL NO. 60820 29 CLIENT SAMPLE IDENTIFICATION BSMS-29-BF-C Sample Date/Time 03/29/2023 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:03 CSG

MARTEL NO. 60820 30 CLIENT SAMPLE IDENTIFICATION BSMS-30-DF Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:06 CSG

MARTEL NO. 60820 31 CLIENT SAMPLE IDENTIFICATION BSMS-31-DF-C Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:16 CSG

MARTEL NO. 60820 32 CLIENT SAMPLE IDENTIFICATION BSMS-32-BF-C Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:21 CSG



Certificate of Analysis

MARTEL NO. 60820 33 CLIENT SAMPLE IDENTIFICATION BSMS-33-BF-C Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:23 CSG

MARTEL NO. 60820 34 CLIENT SAMPLE IDENTIFICATION BSMS-34-DF-C Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:26 CSG

MARTEL NO. 60820 35 CLIENT SAMPLE IDENTIFICATION BSMS-35-DF Sample Date/Time 03/29/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:28 CSG

MARTEL NO. 60820 36 CLIENT SAMPLE IDENTIFICATION BSMS-36-FC-COMP Sample Date/Time 03/29/2023 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:31 CSG

MARTEL NO. 60820 37 CLIENT SAMPLE IDENTIFICATION BSMS-37-FC Sample Date/Time 03/29/2023 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:33 CSG

MARTEL NO. 60820 38 CLIENT SAMPLE IDENTIFICATION BSMS-38-FC Sample Date/Time 03/29/2023 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.24	ug/l	EPA .200.8	2	06/06/2023 15:36 CSG

MARTEL NO. 60820 39 CLIENT SAMPLE IDENTIFICATION BSMS-39-DF Sample Date/Time 03/29/2023 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:38 CSG

MARTEL NO. 60820 40 CLIENT SAMPLE IDENTIFICATION BSMS-40-DF-C Sample Date/Time 03/29/2023 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 15:40 CSG



Certificate of Analysis

MARTEL NO. 60820 41 CLIENT SAMPLE IDENTIFICATION BSMS-41-BF-C Sample Date/Time 03/29/2023 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:48 CSG

MARTEL NO. 60820 42 CLIENT SAMPLE IDENTIFICATION BSMS-42-DF Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:55 CSG

MARTEL NO. 60820 43 CLIENT SAMPLE IDENTIFICATION BSMS-43-DF-C Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 15:58 CSG

MARTEL NO. 60820 44 CLIENT SAMPLE IDENTIFICATION BSMS-44-BF-C Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 16:00 CSG

MARTEL NO. 60820 45 CLIENT SAMPLE IDENTIFICATION BSMS-45-DF Sample Date/Time 03/29/2023 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 16:03 CSG

MARTEL NO. 60820 46 CLIENT SAMPLE IDENTIFICATION BSMS-46-DF-C Sample Date/Time 03/29/2023 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 16:05 CSG

MARTEL NO. 60820 47 CLIENT SAMPLE IDENTIFICATION BSMS-47-BF-C Sample Date/Time 03/29/2023 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 16:08 CSG

MARTEL NO. 60820 48 CLIENT SAMPLE IDENTIFICATION BSMS-48-BF-C Sample Date/Time 03/29/2023 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 16:10 CSG



MARTEL NO. 60820 49 CLIENT SAMPLE IDENTIFICATION BSMS-49-DF-C Sample Date/Time 03/29/2023 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:13 CSG

MARTEL NO. 60820 50 CLIENT SAMPLE IDENTIFICATION BSMS-50-DF Sample Date/Time 03/29/2023 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:15 CSG

MARTEL NO. 60820 51 CLIENT SAMPLE IDENTIFICATION BSMS-51-FC-COMP Sample Date/Time 03/29/2023 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:25 CSG

MARTEL NO. 60820 52 CLIENT SAMPLE IDENTIFICATION BSMS-52-FC Sample Date/Time 03/29/2023 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.43	ug/l	EPA .200.8	2	06/06/2023 16:30 CSG

MARTEL NO. 60820 53 CLIENT SAMPLE IDENTIFICATION BSMS-53-FC Sample Date/Time 03/29/2023 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.77	ug/l	EPA .200.8	2	06/06/2023 16:32 CSG

MARTEL NO. 60820 54 CLIENT SAMPLE IDENTIFICATION BSMS-54-DF-C Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	working	EPA .200.8	2	//

MARTEL NO. 60820 55 CLIENT SAMPLE IDENTIFICATION BSMS-55-BF-C Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	working	EPA .200.8	2	//

MARTEL NO. 60820 56 CLIENT SAMPLE IDENTIFICATION BSMS-56-DF Sample Date/Time 03/29/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	working	EPA .200.8	2	//

MARTEL NO. 60820 57 CLIENT SAMPLE IDENTIFICATION BSMS-57-DF Sample Date/Time 03/29/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:35 CSG

MARTEL NO. 60820 58 CLIENT SAMPLE IDENTIFICATION BSMS-58-DF-C Sample Date/Time 03/29/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:37 CSG

MARTEL NO. 60820 59 CLIENT SAMPLE IDENTIFICATION BSMS-59-BF-C Sample Date/Time 03/29/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:40 CSG

MARTEL NO. 60820 60 CLIENT SAMPLE IDENTIFICATION BSMS-60-FC Sample Date/Time 03/29/2023 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.25	ug/l	EPA .200.8	2	06/06/2023 16:42 CSG

MARTEL NO. 60820 61 CLIENT SAMPLE IDENTIFICATION BSMS-61-FC Sample Date/Time 03/29/2023 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 16:55 CSG

MARTEL NO. 60820 62 CLIENT SAMPLE IDENTIFICATION BSMS-62-FC Sample Date/Time 03/29/2023 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.84	ug/l	EPA .200.8	2	06/06/2023 17:02 CSG

MARTEL NO. 60820 63 CLIENT SAMPLE IDENTIFICATION BSMS-63-FC Sample Date/Time 03/29/2023 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.64	ug/l*	EPA .200.8	2	06/06/2023 17:04 CSG

MARTEL NO. 60820 64 CLIENT SAMPLE IDENTIFICATION BSMS-64-DF Sample Date/Time 03/29/2023 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:07 CSG



MARTEL NO. 60820 65 CLIENT SAMPLE IDENTIFICATION BSMS-65-DF-C Sample Date/Time 03/29/2023 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:09 CSG

MARTEL NO. 60820 66 CLIENT SAMPLE IDENTIFICATION BSMS-66-BF-C Sample Date/Time 03/29/2023 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:12 CSG

MARTEL NO. 60820 67 CLIENT SAMPLE IDENTIFICATION BSMS-67-DF-C Sample Date/Time 03/29/2023 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:14 CSG

MARTEL NO. 60820 68 CLIENT SAMPLE IDENTIFICATION BSMS-68-DF Sample Date/Time 03/29/2023 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:17 CSG

MARTEL NO. 60820 69 CLIENT SAMPLE IDENTIFICATION BSMS-69-BF-C Sample Date/Time 03/29/2023 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:19 CSG

MARTEL NO. 60820 70 CLIENT SAMPLE IDENTIFICATION BSMS-70-FC Sample Date/Time 03/29/2023 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:22 CSG

MARTEL NO. 60820 1F CLIENT SAMPLE IDENTIFICATION BSMS-1-FC-COMP Sample Date/Time 03/29/2023 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:31 CSG

MARTEL NO. 60820 3F CLIENT SAMPLE IDENTIFICATION BSMS-3-KK Sample Date/Time 03/29/2023 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/06/2023 17:36 CSG



Certificate of Analysis

MARTEL NO. 60820 4F CLIENT SAMPLE IDENTIFICATION BSMS-4-FC-COMP Sample Date/Time 03/29/2023 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:39 CSG

MARTEL NO. 60820 5F CLIENT SAMPLE IDENTIFICATION BSMS-5-FC-COMP Sample Date/Time 03/29/2023 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:41 CSG

MARTEL NO. 60820 70F CLIENT SAMPLE IDENTIFICATION BSMS-70-FC Sample Date/Time 03/29/2023 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:44 CSG

MARTEL NO. 60820 20F CLIENT SAMPLE IDENTIFICATION BSMS-20-FC-COMP Sample Date/Time 03/29/2023 06:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:46 CSG

MARTEL NO. 60820 36F CLIENT SAMPLE IDENTIFICATION BSMS-36-FC-COMP Sample Date/Time 03/29/2023 06:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:49 CSG

MARTEL NO. 60820 51F CLIENT SAMPLE IDENTIFICATION BSMS-51-FC-COMP Sample Date/Time 03/29/2023 06:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	06/06/2023 17:51 CSG

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: MARCH 28th 2023 05:00 End Date/Time: MARCH 29, 2023 0700

Sampler/Relinquished By: [Signature] Received at Martel by [Signature] Date/Time: 3/29/23

38 Benjamin Stoddert Middle School
First Draw

2040 St. Thomas Drive Waldorf, MD 20602

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM.
WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

3/28
Martel NO: 429

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubblers, Water Fountain, Gooseneck, Ice Machine, Hose Bib)	Outlet Env. Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
							60820	
1	1	BSMS-1-FC-COMP	2 Comp Sink	FC-COMP	Kitchen	C		506
2	2	BSMS-2-IM	Ice Machine	IM	Kitchen	C		505
3	3	BSMS-3-KK	Kettle	KK	Kitchen	C		508
4	4	BSMS-4-FC-COMP	3 comp sink right fixture	FC-COMP	Kitchen	C		507
5	5	BSMS-5-FC-COMP	3 comp sink left fixture	FC-COMP	Kitchen	C		507
6	6	BSMS-6-FC	Sink	FC	A100 Teacher Lounge	C		515
7	7	BSMS-7-FC	Sink	FC	A102 Privacy Room	C		515
8	8	BSMS-8-DF	Water Fountain (Low)	DF	Corridor	C		530
9	9	BSMS-9-DF-C	Water Fountain (High)	DF-C	Corridor	C		530
10	10	BSMS-10-BF-C	Bottle Filler	BF-C	Corridor	C		530
11	11	BSMS-11-DF	Water Fountain (Low)	DF	Corridor	C		526
12	12	BSMS-12-DF-C	Water Fountain (High)	DF-C	Corridor	C		526
13	13	BSMS-13-BF-C	Bottle Filler	BF-C	Corridor	C		526
14	14	BSMS-14-DF	Water Fountain (Low) Left of serving line	DF	Café	C		520
15	15	BSMS-15-DF-C	Water Fountain (High) Left of serving line	DF-C	Café	C		520
16	16	BSMS-16-BF-C	Bottle Filler - Left of serving line	BF-C	Café	C		250
17	17	BSMS-17-BF-C	Bottle Filler - Right of serving line	BF-C	Café	C		522
18	18	BSMS-18-DF-C	Water Fountain (High) Right of serving line	DF-C	Café	C		522
19	19	BSMS-19-DF	Water Fountain (Low) Right of serving line	DF	Café	C		522
20	20	BSMS-20-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room	C		523
21	21	BSMS-21-FC	Sink	FC	B124 Work Room - Main Office	C		604
22	22	BSMS-22-FC	Sink	FC	A200 Teacher Lounge (2nd Floor)	C		515
23	23	BSMS-23-FC	Sink	FC	A202 Privacy Room (2nd Floor)	C		515

157
2AC

38 Benjamin Stoddert Middle School

First Draw

2040 St. Thomas Drive Waldorf, MD 20602

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM.
WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush 60820

Lab No	Sample No	Sample ID	Outlet Description	Category	Location	Flush	Sample Time	Notes
24	24	BSMS-24-DF	Water Fountain (Low)	DF	Corridor (2nd Floor)	C	5:46	
25	25	BSMS-25-DF-C	Water Fountain (High)	DF-C	Corridor (2nd Floor)	C	5:46	
26	26	BSMS-26-BF-C	Bottle Filler	BF-C	Corridor (2nd Floor)	C	5:46	
27	27	BSMS-27-DF	Water Fountain (Low)	DF	Corridor (2nd Floor)	C	5:47	
28	28	BSMS-28-DF-C	Water Fountain (High)	DF-C	Corridor (2nd Floor)	C	5:47	NOT WORK
29	29	BSMS-29-BF-C	Bottle Filler	BF-C	Corridor (2nd Floor)	C	5:47	NOT WORK
30	30	BSMS-30-DF	Water Fountain (Low) Left of serving line	DF	Café (2nd Floor)	C	5:40	
31	31	BSMS-31-DF-C	Water Fountain (High) Left of serving line	DF-C	Café (2nd Floor)	C	5:40	
32	32	BSMS-32-BF-C	Bottle Filler - Left of serving line	BF-C	Café (2nd Floor)	C	5:40	
33	33	BSMS-33-BF-C	Bottle Filler - Right of serving line	BF-C	Café (2nd Floor)	C	5:40	
34	34	BSMS-34-DF-C	Water Fountain (High) Right of serving line	DF-C	Café (2nd Floor)	C	5:40	5:40 DRN
35	35	BSMS-35-DF	Water Fountain (Low) Right of serving line	DF	Café (2nd Floor)	C	5:40	
36	36	BSMS-36-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room (2nd Floor)	C	5:43	
37	37	BSMS-37-FC	Sink	FC	A300 Teacher Lounge (3rd Floor)	C	5:49	
38	38	BSMS-38-FC	Sink	FC	A302 Privacy Room (3rd Floor)	C	5:49	
39	39	BSMS-39-DF	Water Fountain (Low)	DF	Corridor (3rd Floor)	C	5:58	
40	40	BSMS-40-DF-C	Water Fountain (High)	DF-C	Corridor (2nd Floor)	C	5:58	
41	41	BSMS-41-BF-C	Bottle Filler	BF-C	Corridor (3rd Floor)	C	5:58	
42	42	BSMS-42-DF	Water Fountain (Low)	DF	Corridor (3rd Floor)	C	6:00	
43	43	BSMS-43-DF-C	Water Fountain (High)	DF-C	Corridor (3rd Floor)	C	6:00	
44	44	BSMS-44-BF-C	Bottle Filler	BF-C	Corridor (3rd Floor)	C	6:00	
45	45	BSMS-45-DF	Water Fountain (Low) Left of serving line	DF	Café (3rd Floor)	C	5:58	
46	46	BSMS-46-DF-C	Water Fountain (High) Left of serving line	DF-C	Café (3rd Floor)	C	5:58	
47	47	BSMS-47-BF-C	Bottle Filler - Left of serving line	BF-C	Café (3rd Floor)	C	5:58	
48	48	BSMS-48-BF-C	Bottle Filler - Right of serving line	BF-C	Café (3rd Floor)	C	5:58	
49	49	BSMS-49-DF-C	Water Fountain (High) Right of serving line	DF-C	Café (3rd Floor)	C	5:58	
50	50	BSMS-50-DF	Water Fountain (Low) Right of serving line	DF	Café (3rd Floor)	C	5:58	
51	51	BSMS-51-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room (3rd Floor)	C	5:57	
52	52	BSMS-52-FC	Sink	FC	C131 Privacy Room	C	6:07	
53	53	BSMS-53-FC	Sink	FC	C130 Teacher Work Room	C	6:07	
54	54	BSMS-54-DF-C	Water Fountain (High)	DF-C	Corridor	C	NA	NOT WORK

2nd
3rd
1st

38 Benjamin Stoddert Middle School

First Draw

2040 St. Thomas Drive Waldorf, MD 20602

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM.
WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush 60820

55	55	BSMS-55-BF-C	Bottle Filler	BF-C	Corridor	C			NOTW
56	56	BSMS-56-DF	Water Fountain (Low)	DF	Corridor	C			NOTW
	57	BSMS-57-DF	Water Fountain (Low)	DF	Corridor	C			6:10
	58	BSMS-58-DF-C	Water Fountain (High)	DF-C	Corridor	C			6:10
	59	BSMS-59-BF-C	Bottle Filler	BF-C	Corridor	C			6:10
	60	BSMS-60-FC	Sink	FC	C119 Life Skills	C			6:15
	61	BSMS-61-FC	Sink	FC	C116 Life Skills	C			6:15
	62	BSMS-62-FC	Sink	FC	C122 Life Skills	C			6:15
	63	BSMS-63-FC	Sink	FC	105 Staff Lounge	C			6:16
	64	BSMS-64-DF	Water Fountain (Low)	DF	Corridor	C			6:19
	65	BSMS-65-DF-C	Water Fountain (High)	DF-C	Corridor	C			6:19
	66	BSMS-66-BF-C	Bottle Filler	BF-C	Corridor	C			6:19
	67	BSMS-67-DF-C	Water Fountain (High)	DF-C	Corridor	C			6:20
	68	BSMS-68-DF	Water Fountain (Low)	DF	Corridor	C			6:20
	69	BSMS-69-BF-C	Bottle Filler	BF-C	Corridor	C			6:20
	70	BSMS-70-FC	Sink	FC	B114 Nurse	C			6:21
	71	1F	BSMS-1F-FC-COMP	2 Comp Sink	FC-COMP	Kitchen	C	X	FLUSH
	72	2F	BSMS-2F-IM	Ice Machine	IM	Kitchen	C	X	FLUSH
	73	3F	BSMS-3F-KK	Kettle	KK	Kitchen	C	X	FLUSH
	74	4F	BSMS-4F-FC-COMP	3 comp sink right fixture	FC-COMP	Kitchen	C	X	FLUSH
	75	5F	BSMS-5F-FC-COMP	3 comp sink left fixture	FC-COMP	Kitchen	C	X	FLUSH
	76	70F	BSMS-70F-FC	Sink	FC	B114 Nurse	C	X	FLUSH
	77	20F	BSMS-20F-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room	C	X	FLUSH
	78	36F	BSMS-36F-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room (2nd Floor)	C	X	FLUSH
	79	51F	BSMS-51F-FC-COMP	2 Comp Sink	FC-COMP	Kitchen - Prep Room (3rd Floor)	C	X	FLUSH

1ST
1ST
2nd
3rd

6:19
6:20
6:21
6:23
6:23
6:23
6:26
6:29
6:45
6:50