



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779  
T: 631.580.3191 • F: 631.580.3195 • W: [envirohealth.org](http://envirohealth.org)

June 9, 2023

Mr. Ray Renda  
Edgemont UFSD  
300 White Oak Lane  
Scarsdale, NY 10583

Re: **Lead in Drinking Water Sampling & Analysis 2023-2025**

Dear Mr. Renda,

On June 7th, 2023, EnviroScience Consultants performed limited water sampling events at the Edgemont Union Free School District. Samples were collected at both the Edgemont Jr./Sr. High School & Greenville Elementary School.

First draw samples were collected in wide-mouth 250 milliliter containers during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb).

The following locations were below the current limit:

- Greenville Elementary School Water Fountain by classroom B5/B7 (FS 1029)
- Jr./Sr. High School: Arts Building Lobby Water Fountain/Bottle Filler (FS 1006) & Building B Hallway by Main Entry Water Fountain/Bottle Filler (FS 1015)

Please see the attached lab reports for results. These locations have satisfied the requirement for the 2023 -2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

Drew Cheskin

## Laboratory Report

NYE Report #: 232882-25412

June 8, 2023

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Greenville Elementary School; 100 Glendale Road Scarsdale, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 07, 2023. New York Environmental analyzed the samples on June 08, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	07 Jun 2023
Date Received:	07 Jun 2023
Date Analyzed:	08 Jun 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230607N062	1	Hallway @ Classrooms B5/B7, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

**POTABLE WATER SAMPLING FOR LEAD CONCENTRATION  
SAMPLE COLLECTION FORM**

74149

230607N062

**CLIENT INFORMATION**

Name: Enviroscience Consultants, Inc	
Address: 2150 Smithtown Avenue. Ronkonkoma, NY 11779	
Client Rep: John Driscoll	W.O. No.

**CONSULTANT INFORMATION**

Name: Enviroscience Consultants, Inc	
Address: 2150 Smithtown Avenue. Ronkonkoma, NY 11779	
Project Manager: John Driscoll	Project No.: 23148
Inspector: Drew Cheskin	Field Tech: Drew Cheskin

**PROJECT INFORMATION**

BLDG ID:	BLDG No./Name: Greenville Elementary School	BLDG Address: 100 Glendale Road, Scarsdale, NY 10583						
GEO. DIST.	JUR. DIST.	Sq. Ft. (000):	(0) Year Built	(1) Year 1 <sup>st</sup> Add.	(2) Year 2 <sup>nd</sup> Add.	(3) Year 1 <sup>st</sup> Mod.	(4) Year 2 <sup>nd</sup> Mod.	DATE OF SAMPLING: 06.07.2023

**SAMPLE DATA**

Sample Description/ID (ID must match container label)						OUTLET INFORMATION			CONTAINER INFO.		SAMPLE TYPE			Lead Conc. (ppb)		
Floor	Functional Space Code	IN/BY	Room No.	Construction Code	Sample /Outlet Code	Type (Enter Code)	MFS/ Model	Serial #	Date of Installation	Size	#	Preservatives	Initial		Follow-up	Length of Flush
	1029					WF				250 ml	1	HNO <sub>3</sub>	X			07:45
										250 ml		HNO <sub>3</sub>				
										250 ml		HNO <sub>3</sub>				
										250 ml		HNO <sub>3</sub>				
										250 ml		HNO <sub>3</sub>				

232882



**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Date:	Time:
I. <i>[Signature]</i>	Alvin Lee	06/07/2023	11:15 AM
II.			
III.			

**LABORATORY INFORMATION**

Lab Name: NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC	Date:	Time:	Method of Analysis:
Analyzed By: Alvin Lee	06/08/23	8:00 AM	200.9
QC By:			
Method of shipment/delivery: <input type="checkbox"/> US Mail <input type="checkbox"/> UPS <input type="checkbox"/> Fed-Ex <input type="checkbox"/> Courier			
<input checked="" type="checkbox"/> Hand Delivery <input type="checkbox"/> Other:			

**INSTRUCTIONS TO THE LABORATORY**

Turnaround Time	<input type="checkbox"/> Analyze follow-up sample(s) ONLY when initial sample exceeds 15 pbb	Report Results ASAP To: Susan Richter
<input type="checkbox"/> RUSH <input checked="" type="checkbox"/> 24 HOUR <input type="checkbox"/> 48 Hour	<input type="checkbox"/> Analyze both initial and follow up samples	<input type="checkbox"/> Phone (631) 580-3191 <input type="checkbox"/> Fax:
<input type="checkbox"/> OTHER:	<input type="checkbox"/> Other:	<input type="checkbox"/> Email: srichter@envirohealth.org <input type="checkbox"/> Mail report to above address

*Recertified 06/07/2023 12:00 PM  
lot: 22050043*

## Laboratory Report

NYE Report #: 232871-25401

June 8, 2023

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edgemont Junior/Senior HS; 200 White Oak Lane Scarsdale, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 07, 2023. New York Environmental analyzed the samples on June 08, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	07 Jun 2023
Date Received:	07 Jun 2023
Date Analyzed:	08 Jun 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230607M001	1	Arts Building - Lobby WF; Initial	0.001	<0.001	mg/L	
230607M002	2	Arts Building - Lobby BF; Initial	0.001	<0.001	mg/L	
230607M003	3	Building B - Hallway @ Main Entry WF; Initial	0.001	<0.001	mg/L	
230607M004	4	Building B - Hallway @ Main Entry BF; Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

**POTABLE WATER SAMPLING FOR LEAD CONCENTRATION  
SAMPLE COLLECTION FORM**

*74147 230607 Mod1-Mod4*

**CLIENT INFORMATION**

Name: **Enviroscience Consultants, Inc**  
 Address:  
**2150 Smithtown Avenue. Ronkonkoma, NY 11779**  
 Client Rep: **John Driscoll** W.O. No.

**CONSULTANT INFORMATION**

Name: **Enviroscience Consultants, Inc**  
 Address: **2150 Smithtown Avenue. Ronkonkoma, NY 11779**  
 Project Manager: **John Driscoll** Project No.: **23148**  
 Inspector: **Drew Cheskin** Field Tech **Drew Cheskin**

**PROJECT INFORMATION**

BLDG ID: BLDG No./Name: **Edgemont Junior/Senior High School** BLDG Address: **200 White Oak Lane, Scarsdale, NY 10583**  
 GEO. DIST. JUR. DIST. Sq. Ft. (000): (0) Year Built (1) Year 1<sup>st</sup> Add. (2) Year 2<sup>nd</sup> Add. (3) Year 1<sup>st</sup> Mod. (4) Year 2<sup>nd</sup> Mod. DATE OF SAMPLING: **06.07.2023**

**SAMPLE DATA**

Sample Description/ID (ID must match container label)				SAMPLED OUTLET LOCATION/ COORDINATES	OUTLET INFORMATION			CONTAINER INFO.		SAMPLE TYPE		Length of Flush	Time of Collection	Lead Conc. (ppb)
Floor	Functional Space Code	IN/BY	Room No		Type (Enter Code)	MFS/ Model	Serial #	Date of Installation	Size	#	Preservatives			
	<b>1006</b>			<b>Arts Building - Lobby</b>	<b>WF</b>			250 ml	<b>1</b>	<b>HNO<sub>3</sub></b>	<b>X</b>		<b>07:23</b>	
	<b>1006</b>			<b>Arts Building - Lobby</b>	<b>BF</b>			250 ml	<b>2</b>	<b>HNO<sub>3</sub></b>	<b>X</b>		<b>07:23</b>	
	<b>1015</b>			<b>Building B - Hallway @ Main Entry</b>	<b>WF</b>			250 ml	<b>3</b>	<b>HNO<sub>3</sub></b>	<b>X</b>		<b>07:28</b>	
	<b>1015</b>			<b>Building B - Hallway @ Main Entry</b>	<b>BF</b>			250 ml	<b>4</b>	<b>HNO<sub>3</sub></b>	<b>X</b>		<b>07:28</b>	
								250 ml		<b>HNO<sub>3</sub></b>				

*232871*



**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Date:	Time:
<i>D</i>	<i>Alvin Lee</i>	<i>06/07/2023</i>	<i>11:15 AM</i>
II.			
III.			

**LABORATORY INFORMATION**

Lab Name: **NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC** Date: **06/08/23** Time: **8:00 AM** Method of Analysis: **200.9**  
 Analyzed By: *Alvin Lee*  
 QC By:  
 Method of shipment/delivery:  US Mail  UPS  Fed-Ex  Courier  
 Hand Delivery  Other:

**INSTRUCTIONS TO THE LABORATORY**

Turnaround Time  Analyze follow-up sample(s) **ONLY** when initial sample exceeds 15 pbb Report Results ASAP To: **Susan Richter**  
 RUSH  24 HOUR  48 Hour  Analyze both initial and follow up samples  Phone (631) 580-3191  Fax:  
 OTHER:  Other:  Email **srichter@envirohealth.org**  Mail report to above address

*acidified 06/07/2023 12:00pm  
lot: 22050003*