

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: CPE - Lead & Coppers
Lab Order: 1611270

Date: 22-Nov-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:42 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-01

Collection Date: 11/4/2016 6:54:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26704

Source: City Water

Sample Location: Rm 10 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.18		0.00515	mg/L	10	11/17/2016	A
Lead	0.000832		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-02

Collection Date: 11/4/2016 6:55:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26749

Source: City Water

Sample Location: Rm 10 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.14		0.00515	mg/L	10	11/17/2016	A
Lead	0.000754		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-03

Collection Date: 11/4/2016 6:51:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26702

Source: City Water

Sample Location: Rm 13 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.780		0.000515	mg/L	1	11/15/2016	A
Lead	0.000528		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-04

Collection Date: 11/4/2016 6:51:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26708

Source: City Water

Sample Location: Rm 13 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.829		0.000515	mg/L	1	11/15/2016	A
Lead	0.00163		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-05

Collection Date: 11/4/2016 6:57:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26705

Source: City Water

Sample Location: Rm 11 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.856		0.000515	mg/L	1	11/15/2016	A
Lead	0.00319		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:42 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-06

Collection Date: 11/4/2016 6:57:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26750

Source: City Water

Sample Location: Rm 11 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.783		0.000515	mg/L	1	11/15/2016	A
Lead	0.000914		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-07

Collection Date: 11/4/2016 6:46:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26739

Source: City Water

Sample Location: Rm 14 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.801		0.000515	mg/L	1	11/15/2016	A
Lead	0.000413		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-08

Collection Date: 11/4/2016 6:46:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26756

Source: City Water

Sample Location: Rm 14 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.980		0.00515	mg/L	10	11/17/2016	A
Lead	0.00202		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-09

Collection Date: 11/4/2016 6:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26703

Source: City Water

Sample Location: Rm 12 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.935		0.00515	mg/L	10	11/17/2016	A
Lead	0.000576		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-10

Collection Date: 11/4/2016 6:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26748

Source: City Water

Sample Location: Rm 12 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.00		0.00515	mg/L	10	11/17/2016	A
Lead	0.00192		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-11

Collection Date: 11/4/2016 6:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26746

Source: City Water

Sample Location: Rm 15 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.698		0.000515	mg/L	1	11/15/2016	A
Lead	0.000540		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-12

Collection Date: 11/4/2016 6:49:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26738

Source: City Water

Sample Location: Rm 15 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.755		0.000515	mg/L	1	11/15/2016	A
Lead	0.00174		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-13

Collection Date: 11/4/2016 6:29:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26711

Source: City Water

Sample Location: Rm 19 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.771		0.000515	mg/L	1	11/15/2016	A
Lead	0.00131		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-14

Collection Date: 11/4/2016 6:30:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26741

Source: City Water

Sample Location: Rm 19 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.777		0.000515	mg/L	1	11/15/2016	A
Lead	0.000353		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-15

Collection Date: 11/4/2016 6:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26759

Source: City Water

Sample Location: Rm 16 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.741		0.000515	mg/L	1	11/15/2016	A
Lead	0.000483		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-16

Collection Date: 11/4/2016 6:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26758

Source: City Water

Sample Location: Rm 16 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.734		0.000515	mg/L	1	11/15/2016	A
Lead	0.00145		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-17

Collection Date: 11/4/2016 6:31:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26710

Source: City Water

Sample Location: Rm 18 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.887		0.000515	mg/L	1	11/15/2016	A
Lead	0.00100		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-18

Collection Date: 11/4/2016 6:31:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26713

Source: City Water

Sample Location: Rm 18 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.770		0.000515	mg/L	1	11/15/2016	A
Lead	0.000197		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-19

Collection Date: 11/4/2016 6:34:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26727

Source: City Water

Sample Location: Rm 17 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.766		0.000515	mg/L	1	11/15/2016	A
Lead	0.00159		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-20

Collection Date: 11/4/2016 6:34:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26724

Source: City Water

Sample Location: Rm 17 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.817		0.000515	mg/L	1	11/15/2016	A
Lead	0.000334		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-21

Collection Date: 11/4/2016 6:43:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26751

Source: City Water

Sample Location: WW Boys Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.640		0.000515	mg/L	1	11/15/2016	A
Lead	0.000806		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-22

Collection Date: 11/4/2016 6:44:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26755

Source: City Water

Sample Location: WW Boys Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.647		0.000515	mg/L	1	11/15/2016	A
Lead	0.00353		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-23

Collection Date: 11/4/2016 6:45:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26752

Source: City Water

Sample Location: WW Boys Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.757		0.000515	mg/L	1	11/15/2016	A
Lead	0.00475		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-24

Collection Date: 11/4/2016 6:40:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26736

Source: City Water

Sample Location: WW Girls Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.675		0.000515	mg/L	1	11/15/2016	A
Lead	0.000841		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-25

Collection Date: 11/4/2016 6:41:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26740

Source: City Water

Sample Location: WW Girls Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.619		0.000515	mg/L	1	11/15/2016	A
Lead	0.000608		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-26

Collection Date: 11/4/2016 6:42:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26723

Source: City Water

Sample Location: WW Girls Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.725		0.000515	mg/L	1	11/15/2016	A
Lead	0.000742		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-27

Collection Date: 11/4/2016 6:35:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26754

Source: City Water

Sample Location: WW Staff Rm Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.646		0.000515	mg/L	1	11/15/2016	A
Lead	0.00136		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-28

Collection Date: 11/4/2016 6:36:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26747

Source: City Water

Sample Location: WW Staff Bath

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.750		0.000515	mg/L	1	11/15/2016	A
Lead	0.000308		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-29

Collection Date: 11/4/2016 6:37:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26742

Source: City Water

Sample Location: WW DF #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.648		0.000515	mg/L	1	11/15/2016	A
Lead	0.000345		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-30

Collection Date: 11/4/2016 6:39:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26757

Source: City Water

Sample Location: WW DF #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.651		0.000515	mg/L	1	11/15/2016	A
Lead	0.000345		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: CPE - Lead & Coppers

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Lab ID: 1611270-31

Collection Date: 11/5/2016 10:10:00 AM

Matrix:

Client Sample ID: Bottle #27384

Source City Water

Sample Location: Rm 1 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.776		0.000515	mg/L	1	11/15/2016	A
Lead	0.00116		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-32

Collection Date: 11/5/2016 10:10:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27273

Source City Water

Sample Location: Rm 1 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.766		0.000515	mg/L	1	11/15/2016	A
Lead	0.000421		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-33

Collection Date: 11/5/2016 10:03:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27660

Source City Water

Sample Location: EW Girls RR #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.779		0.000515	mg/L	1	11/15/2016	A
Lead	0.000488		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-34

Collection Date: 11/5/2016 10:04:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27653

Source City Water

Sample Location: EW Girls RR #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.874		0.000515	mg/L	1	11/15/2016	A
Lead	0.00158		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-35

Collection Date: 11/5/2016 9:55:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27665

Source City Water

Sample Location: EW DF #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.878		0.000515	mg/L	1	11/15/2016	A
Lead	0.000474		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: CPE - Lead & Coppers

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Lab ID: 1611270-36

Collection Date: 11/5/2016 10:14:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27308

Source: City Water

Sample Location: Student Services RR

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.562		0.000515	mg/L	1	11/15/2016	A
Lead	0.000634		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-37

Collection Date: 11/5/2016 10:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27381

Source: City Water

Sample Location: Kitchen Sink #4

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.489		0.000515	mg/L	1	11/15/2016	A
Lead	0.00125		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-38

Collection Date: 11/5/2016 10:35:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27275

Source: City Water

Sample Location: Kitchen RR

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.711		0.000515	mg/L	1	11/15/2016	A
Lead	0.000755		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-39

Collection Date: 11/5/2016 10:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27379

Source: City Water

Sample Location: Kitchen Sink #5

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.501		0.000515	mg/L	1	11/15/2016	A
Lead	0.00242		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-40

Collection Date: 11/5/2016 10:37:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27378

Source: City Water

Sample Location: Outside Boys RR #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.471		0.000515	mg/L	1	11/15/2016	A
Lead	0.000460		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: CPE - Lead & Coppers

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Lab ID: 1611270-41

Collection Date: 11/5/2016 10:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27658

Source: City Water

Sample Location: EW Boys RR #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.749		0.000515	mg/L	1	11/15/2016	A
Lead	0.000546		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-42

Collection Date: 11/5/2016 10:01:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27662

Source: City Water

Sample Location: EW Boys RR #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.753		0.000515	mg/L	1	11/15/2016	A
Lead	0.000211		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-43

Collection Date: 11/5/2016 9:59:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27649

Source: City Water

Sample Location: EW Boys RR #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.831		0.000515	mg/L	1	11/15/2016	A
Lead	0.00135		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-44

Collection Date: 11/5/2016 10:20:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27318

Source: City Water

Sample Location: Health Exam #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.454		0.000515	mg/L	1	11/15/2016	A
Lead	0.00121		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-45

Collection Date: 11/5/2016 10:24:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27386

Source: City Water

Sample Location: Rm 29 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.885		0.000515	mg/L	1	11/15/2016	A
Lead	0.000554		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-46

Collection Date: 11/5/2016 10:25:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27214

Source: City Water

Sample Location: Rm 29 Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.06		0.00515	mg/L	10	11/17/2016	A
Lead	0.0198		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-47

Collection Date: 11/5/2016 10:24:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27312

Source: City Water

Sample Location: Rm 29 Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.08		0.00515	mg/L	10	11/17/2016	A
Lead	0.00733		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-48

Collection Date: 11/5/2016 9:58:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27694

Source: City Water

Sample Location: EW Staff RR

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.06		0.00515	mg/L	10	11/17/2016	A
Lead	0.000530		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-49

Collection Date: 11/5/2016 10:08:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27216

Source: City Water

Sample Location: Rm 2 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.751		0.000515	mg/L	1	11/15/2016	A
Lead	0.00585		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-50

Collection Date: 11/5/2016 10:18:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27304

Source: City Water

Sample Location: Office Staff Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.603		0.000515	mg/L	1	11/15/2016	A
Lead	0.000826		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA QR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-51

Collection Date: 11/5/2016 10:34:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27211

Source: City Water

Sample Location: Kitchen Sink #6

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.323		0.000515	mg/L	1	11/15/2016	A
Lead	0.00265		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-52

Collection Date: 11/5/2016 9:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27703

Source: City Water

Sample Location: Rm 7 DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.952		0.00515	mg/L	10	11/17/2016	A
Lead	0.000611		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-53

Collection Date: 11/5/2016 10:27:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27309

Source: City Water

Sample Location: Gym DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.427		0.000515	mg/L	1	11/15/2016	A
Lead	0.000322		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-54

Collection Date: 11/5/2016 10:06:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27639

Source: City Water

Sample Location: Rm 4 DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.755		0.000515	mg/L	1	11/15/2016	A
Lead	0.000535		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-55

Collection Date: 11/5/2016 9:49:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27666

Source: City Water

Sample Location: Rm 8 DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.847		0.000515	mg/L	1	11/15/2016	A
Lead	0.000615		0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: CPE - Lead & Coppers

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Lab ID: 1611270-56

Collection Date: 11/5/2016 10:31:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27020

Source: City Water

Sample Location: Kitchen Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.120		0.000515	mg/L	1	11/15/2016	A
Lead	0.00944		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-57

Collection Date: 11/5/2016 10:31:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27207

Source: City Water

Sample Location: Kitchen Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.419		0.000515	mg/L	1	11/15/2016	A
Lead	0.00204		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-58

Collection Date: 11/5/2016 10:21:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27210

Source: City Water

Sample Location: Health Exam #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.652		0.000515	mg/L	1	11/15/2016	A
Lead	0.00199		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611270-59

Collection Date: 11/5/2016 10:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27657

Source: City Water

Sample Location: Rm 4 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.755		0.000515	mg/L	1	11/16/2016	A
Lead	0.00231		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-60

Collection Date: 11/5/2016 9:53:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27700

Source: City Water

Sample Location: Rm 5 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.843		0.000515	mg/L	1	11/16/2016	A
Lead	0.000283		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-61

Collection Date: 11/5/2016 9:49:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27663

Source: City Water

Sample Location: Rm 7 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.960		0.00515	mg/L	10	11/17/2016	A
Lead	0.00233		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-62

Collection Date: 11/5/2016 9:49:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27629

Source: City Water

Sample Location: Rm 8 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.834		0.000515	mg/L	1	11/16/2016	A
Lead	0.00139		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-63

Collection Date: 11/5/2016 10:30:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27010

Source: City Water

Sample Location: Kitchen Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.505		0.000515	mg/L	1	11/16/2016	A
Lead	0.00353		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-64

Collection Date: 11/5/2016 9:53:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27221

Source: City Water

Sample Location: Rm 5-7 RR Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.767		0.000515	mg/L	1	11/16/2016	A
Lead	0.000604		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-65

Collection Date: 11/5/2016 10:11:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27274

Source: City Water

Sample Location: Rm 1-3 RR Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.817		0.000515	mg/L	1	11/16/2016	A
Lead	0.000643		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:43 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-66

Collection Date: 11/5/2016 10:05:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27676

Source: City Water

Sample Location: Rm 3 DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.686		0.000515	mg/L	1	11/16/2016	A
Lead	0.000318		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-67

Collection Date: 11/5/2016 9:56:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27652

Source: City Water

Sample Location: EW DF #2

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.863		0.000515	mg/L	1	11/16/2016	A
Lead	0.000234		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-68

Collection Date: 11/5/2016 9:51:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27690

Source: City Water

Sample Location: Rm 6 DF

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.726		0.000515	mg/L	1	11/16/2016	A
Lead	0.000531		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-69

Collection Date: 11/5/2016 10:38:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27040

Source: City Water

Sample Location: Outside DF 1

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.386		0.000515	mg/L	1	11/16/2016	A
Lead	0.000673		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-70

Collection Date: 11/5/2016 10:39:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27377

Source: City Water

Sample Location: Outside DF 2

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.447		0.000515	mg/L	1	11/16/2016	A
Lead	0.000552		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: CPE - Lead & Coppers

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:44 AM

Lab ID: 1611270-71

Collection Date: 11/5/2016 9:51:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27647

Source: City Water

Sample Location: Rm 6 Sink

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.729		0.000515	mg/L	1	11/16/2016	A
Lead	0.00236		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-72

Collection Date: 11/5/2016 10:19:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27316

Source: City Water

Sample Location: Office Mail Rm Sink

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.834		0.000515	mg/L	1	11/16/2016	A
Lead	0.000928		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-73

Collection Date: 11/5/2016 10:05:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27689

Source: City Water

Sample Location: Rm 3 Sink

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.783		0.000515	mg/L	1	11/16/2016	A
Lead	0.00167		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-74

Collection Date: 11/5/2016 9:57:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27650

Source: City Water

Sample Location: EW Staff Sink

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.797		0.000515	mg/L	1	11/16/2016	A
Lead	0.00228		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-75

Collection Date: 11/5/2016 10:08:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27217

Source: City Water

Sample Location: Rm 2 DF

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.822		0.000515	mg/L	1	11/16/2016	A
Lead	0.000832		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611270

Received Date: 11/7/2016 8:52:00 AM

Reported Date: 11/22/2016 8:31:44 AM

Sample Information: CPE - Lead & Coppers

Lab ID: 1611270-76

Collection Date: 11/5/2016 10:20:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27310

Source: City Water

Sample Location: Health RR

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.539		0.000515	mg/L	1	11/16/2016	A
Lead	0.00107		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-77

Collection Date: 11/5/2016 9:52:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27683

Source: City Water

Sample Location: Rm 5 Sink

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.760		0.000515	mg/L	1	11/16/2016	A
Lead	0.00147		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611270-78

Collection Date: 11/5/2016 10:02:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27664

Source: City Water

Sample Location: EW Girls RR #1

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.762		0.000515	mg/L	1	11/16/2016	A
Lead	0.000819		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit