

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School - Lead & Coppers
Lab Order: 1611222

Date: 21-Nov-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:27 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-01

Collection Date: 11/4/2016 5:36:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26716

Source: City Water

Sample Location: B-7 Front Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.35	CF*	0.00515	mg/L	10	11/10/2016	A
Lead	0.0877	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-02

Collection Date: 11/4/2016 5:37:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26717

Source: City Water

Sample Location: B-7 Left Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0996		0.000515	mg/L	1	11/9/2016	A
Lead	0.0234	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-03

Collection Date: 11/4/2016 5:38:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26729

Source: City Water

Sample Location: B-7 Left Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.111		0.000515	mg/L	1	11/9/2016	A
Lead	0.103	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-04

Collection Date: 11/4/2016 5:39:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26725

Source: City Water

Sample Location: B-7 Left Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0501		0.000515	mg/L	1	11/9/2016	A
Lead	0.0360	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-05

Collection Date: 11/4/2016 5:40:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26730

Source: City Water

Sample Location: B-7 Right Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0226		0.000515	mg/L	1	11/9/2016	A
Lead	0.0154	CF	0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-06

Collection Date: 11/4/2016 5:41:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26731

Source: City Water

Sample Location: B-7 Right Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0353		0.000515	mg/L	1	11/9/2016	A
Lead	0.0259	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-07

Collection Date: 11/4/2016 5:41:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26735

Source: City Water

Sample Location: B-7 Right Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0560		0.000515	mg/L	1	11/9/2016	A
Lead	0.0263	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-08

Collection Date: 11/4/2016 5:22:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26733

Source: City Water

Sample Location: B-3 Left Sink #1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0697		0.000515	mg/L	1	11/9/2016	A
Lead	0.0247	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-09

Collection Date: 11/4/2016 5:23:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26732

Source: City Water

Sample Location: B-3 Left Sink #2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.123		0.000515	mg/L	1	11/9/2016	A
Lead	0.0227	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-10

Collection Date: 11/4/2016 5:24:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26718

Source: City Water

Sample Location: B-3 Left Sink #3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0766		0.000515	mg/L	1	11/9/2016	A
Lead	0.0503	CF*	0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

Lab Order: 1611222

300 Ash St.

Received Date: 11/4/2016 8:22:00 AM

Central Point, OR 97502

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-11

Collection Date: 11/3/2016 6:16:00 AM

Client Sample ID: Bottle #26370

Source: City Water

Matrix: DRINKING WATER

Sample Location: D-3 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0449		0.000515	mg/L	1	11/9/2016	A
Lead	0.0210	CF*	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-12

Collection Date: 11/3/2016 6:28:00 AM

Client Sample ID: Bottle #26362

Source: City Water

Matrix: DRINKING WATER

Sample Location: C-5 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.357		0.000515	mg/L	1	11/9/2016	A
Lead	0.0121		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-13

Collection Date: 11/3/2016 6:25:00 AM

Client Sample ID: Bottle #26413

Source: City Water

Matrix: DRINKING WATER

Sample Location: C-4 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0293		0.000515	mg/L	1	11/9/2016	A
Lead	0.0150	CF	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-14

Collection Date: 11/3/2016 6:23:00 AM

Client Sample ID: Bottle #26414

Source: City Water

Matrix: DRINKING WATER

Sample Location: C-1 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.617		0.000515	mg/L	1	11/9/2016	A
Lead	0.00399		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-15

Collection Date: 11/3/2016 6:31:00 AM

Client Sample ID: Bottle #26373

Source: City Water

Matrix: DRINKING WATER

Sample Location: Scenic Staff Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0706		0.000515	mg/L	1	11/9/2016	A
Lead	0.00528		0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

Lab Order: 1611222

300 Ash St.

Received Date: 11/4/2016 8:22:00 AM

Central Point, OR 97502

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-16

Collection Date: 11/3/2016 6:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26426

Source: City Water

Sample Location: Scenic Counselor

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.158		0.000515	mg/L	1	11/9/2016	A
Lead	0.0100		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-17

Collection Date: 11/4/2016 5:16:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26734

Source: City Water

Sample Location: B-2 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.296		0.000515	mg/L	1	11/9/2016	A
Lead	0.00992		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-18

Collection Date: 11/4/2016 5:18:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26720

Source: City Water

Sample Location: N B-Hall DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.110		0.000515	mg/L	1	11/9/2016	A
Lead	0.00977		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-19

Collection Date: 11/4/2016 5:45:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26744

Source: City Water

Sample Location: S B-Hall DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0419		0.000515	mg/L	1	11/9/2016	A
Lead	0.0119		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-20

Collection Date: 11/4/2016 5:35:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26714

Source: City Water

Sample Location: B-6 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.541		0.000515	mg/L	1	11/9/2016	A
Lead	0.0154	CF	0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-21

Collection Date: 11/3/2016 6:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26419

Source: City Water

Sample Location: E-3 Exam 1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.242		0.000515	mg/L	1	11/9/2016	A
Lead	0.00701		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-22

Collection Date: 11/3/2016 6:03:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26406

Source: City Water

Sample Location: E-3 Bathroom

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.194		0.000515	mg/L	1	11/9/2016	A
Lead	0.00140		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-23

Collection Date: 11/3/2016 6:05:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26416

Source: City Water

Sample Location: E-3 Exam 2 OK

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.272		0.000515	mg/L	1	11/9/2016	A
Lead	0.0150		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-24

Collection Date: 11/3/2016 6:07:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26565

Source: City Water

Sample Location: E-2 Sink 2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.523		0.000515	mg/L	1	11/9/2016	A
Lead	0.00176		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-25

Collection Date: 11/3/2016 6:08:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26350

Source: City Water

Sample Location: E-2 Sink 1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.788		0.000515	mg/L	1	11/9/2016	A
Lead	0.00208		0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-26

Collection Date: 11/3/2016 6:09:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26541

Source: City Water

Sample Location: E-2 DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.396		0.000515	mg/L	1	11/9/2016	A
Lead	0.00135		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-27

Collection Date: 11/3/2016 6:17:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26353

Source: City Water

Sample Location: D-1 Sink 1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0593		0.000515	mg/L	1	11/9/2016	A
Lead	0.0155	OK	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-28

Collection Date: 11/3/2016 6:17:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26436

Source: City Water

Sample Location: D-1 Sink 2 OK

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0180	OK	0.000515	mg/L	1	11/9/2016	A
Lead	0.0143		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-29

Collection Date: 11/3/2016 6:11:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26438

Source: City Water

Sample Location: D-2 Sink 1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0175		0.000515	mg/L	1	11/9/2016	A
Lead	0.0171	CF	0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-30

Collection Date: 11/3/2016 6:12:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26357

Source: City Water

Sample Location: D-2 Sink 2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0847		0.000515	mg/L	1	11/9/2016	A
Lead	0.0123		0.000103	mg/L	1	11/9/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-31

Collection Date: 11/3/2016 5:43:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26325
Source: City Water
Sample Location: Team Rm Coaches Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0218		0.000515	mg/L	1	11/9/2016	A
Lead	0.00717		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-32

Collection Date: 11/3/2016 5:26:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26341
Source: City Water
Sample Location: Girls LR South R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0148		0.000515	mg/L	1	11/9/2016	A
Lead	0.000936		0.000103	mg/L	1	11/9/2016	A

Lab ID: 1611222-33

Collection Date: 11/3/2016 5:25:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26334
Source: City Water
Sample Location: Girls LR South L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00995		0.000515	mg/L	1	11/10/2016	A
Lead	0.00138		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-34

Collection Date: 11/3/2016 5:45:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26440
Source: City Water
Sample Location: Team Rm Coaches L Showe

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0251		0.000515	mg/L	1	11/10/2016	A
Lead	0.0109		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-35

Collection Date: 11/3/2016 5:23:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26327
Source: City Water
Sample Location: Girls LR Coaches Shower

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0140		0.000515	mg/L	1	11/10/2016	A
Lead	0.00768		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-36

Collection Date: 11/3/2016 5:29:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26395

Source: City Water

Sample Location: Boys LR Outer Bath R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0636		0.000515	mg/L	1	11/10/2016	A
Lead	0.00308		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-37

Collection Date: 11/3/2016 5:16:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26517

Source: City Water

Sample Location: Girls LR Bath L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0675		0.000515	mg/L	1	11/10/2016	A
Lead	0.00106		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-38

Collection Date: 11/3/2016 5:17:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26667

Source: City Water

Sample Location: Girls LR Bath R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0366		0.000515	mg/L	1	11/10/2016	A
Lead	0.00109		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-39

Collection Date: 11/3/2016 5:44:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26322

Source: City Water

Sample Location: Team Rm Coaches R Shwr

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0147		0.000515	mg/L	1	11/10/2016	A
Lead	0.0131		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-40

Collection Date: 11/3/2016 5:20:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26375

Source: City Water

Sample Location: Girls LR DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0297		0.000515	mg/L	1	11/10/2016	A
Lead	0.00423		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-41

Collection Date: 11/3/2016 5:38:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26359

Source: City Water

Sample Location: Boys LR R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0146		0.000515	mg/L	1	11/10/2016	A
Lead	0.00346		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-42

Collection Date: 11/3/2016 6:09:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26332

Source: City Water

Sample Location: E-1 East L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.335		0.000515	mg/L	1	11/10/2016	A
Lead	0.00103		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-43

Collection Date: 11/3/2016 6:07:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26400

Source: City Water

Sample Location: E-1 Sink 5

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.547		0.000515	mg/L	1	11/10/2016	A
Lead	0.000716		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-44

Collection Date: 11/3/2016 6:10:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26364

Source: City Water

Sample Location: E-1 East R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.411		0.000515	mg/L	1	11/10/2016	A
Lead	0.000778		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-45

Collection Date: 11/3/2016 6:32:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26356

Source: City Water

Sample Location: Staff Mens Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0140		0.000515	mg/L	1	11/10/2016	A
Lead	0.00110		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
J	Analyte detected below quantitation limits	ND	Not Detected at the Minimum Reporting Limit
S	Spike Recovery outside accepted recovery limits		

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-46

Collection Date: 11/3/2016 5:46:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26333

Source: City Water

Sample Location: Team Rm R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0276		0.000515	mg/L	1	11/10/2016	A
Lead	0.00502		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-47

Collection Date: 11/3/2016 5:38:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26435

Source: City Water

Sample Location: Boys LR Bath L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0195		0.000515	mg/L	1	11/10/2016	A
Lead	0.00189		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-48

Collection Date: 11/2/2016 5:35:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26520

Source: City Water

Sample Location: Boys LR Coaches Shower

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00735		0.000515	mg/L	1	11/10/2016	A
Lead	0.00213		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-49

Collection Date: 11/2/2016 5:22:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26423

Source: City Water

Sample Location: Girls LR Coaches Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0700		0.000515	mg/L	1	11/10/2016	A
Lead	0.00192		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-50

Collection Date: 11/3/2016 6:12:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26354

Source: City Water

Sample Location: E-1 South L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.566		0.000515	mg/L	1	11/10/2016	A
Lead	0.00146		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:28 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-51

Collection Date: 11/3/2016 5:59:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26374

Source: City Water

Sample Location: East Gym DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.277		0.000515	mg/L	1	11/10/2016	A
Lead	0.00153		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-52

Collection Date: 11/3/2016 5:33:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26347

Source: City Water

Sample Location: Boys LR DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0114		0.000515	mg/L	1	11/10/2016	A
Lead	0.00486		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-53

Collection Date: 11/3/2016 5:36:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26329

Source: City Water

Sample Location: West Gym DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.133		0.000515	mg/L	1	11/10/2016	A
Lead	0.00270		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-54

Collection Date: 11/3/2016 5:51:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26361

Source: City Water

Sample Location: Weight Rm DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0799		0.000515	mg/L	1	11/10/2016	A
Lead	0.00956		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-55

Collection Date: 11/3/2016 5:36:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26427

Source: City Water

Sample Location: Boys LR Coaches Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0296		0.000515	mg/L	1	11/10/2016	A
Lead	0.00545		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-56

Collection Date: 11/3/2016 5:48:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26330

Source: City Water

Sample Location: Team Rm DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredite
Copper	0.210		0.000515	mg/L	1	11/10/2016	
Lead	0.0142		0.000103	mg/L	1	11/10/2016	

Lab ID: 1611222-57

Collection Date: 11/3/2016 5:42:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26324

Source: City Water

Sample Location: Team Rm L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed
Copper	0.0328		0.000515	mg/L	1	11/10/2016
Lead	0.00745		0.000103	mg/L	1	11/10/2016

Lab ID: 1611222-58

Collection Date: 11/3/2016 6:38:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26366

Source: City Water

Sample Location: Office Outside

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed
Copper	0.349		0.000515	mg/L	1	11/10/2016
Lead	0.000735		0.000103	mg/L	1	11/10/2016

Lab ID: 1611222-59

Collection Date: 11/3/2016 6:23:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26366

Source: City Water

Sample Location: Office Outside

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units
Copper	0.00533		0.000515	mg/L
Lead	0.000694		0.000103	mg/L

Lab ID: 1611222-60

Collection Date: 11/3/2016 6:22:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26366

Source: City Water

Sample Location: Office Outside

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL
Copper	0.0156		0.000515
Lead	0.00113		0.000103

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-61

Collection Date: 11/3/2016 6:20:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26425

Source: City Water

Sample Location: C-Wing Girls Bath R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00929		0.000515	mg/L	1	11/10/2016	A
Lead	0.00298		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-62

Collection Date: 11/3/2016 6:19:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26397

Source: City Water

Sample Location: C-Wing Girls Bath L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0144		0.000515	mg/L	1	11/10/2016	A
Lead	0.00262		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-63

Collection Date: 11/3/2016 6:11:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26352

Source: City Water

Sample Location: E-1 South R Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.378		0.000515	mg/L	1	11/10/2016	A
Lead	0.000801		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-64

Collection Date: 11/3/2016 5:29:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26390

Source: City Water

Sample Location: Boys LR Outside Bath L Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.275		0.000515	mg/L	1	11/10/2016	A
Lead	0.00142		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-65

Collection Date: 11/4/2016 5:25:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26719

Source: City Water

Sample Location: B-3 R Sink 1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.121		0.000515	mg/L	1	11/10/2016	A
Lead	0.0243	CF*	0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-66

Collection Date: 11/4/2016 5:26:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26722

Source: City Water

Sample Location: B-3 R Sink 2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.103		0.000515	mg/L	1	11/10/2016	A
Lead	0.0271	CF*	0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-67

Collection Date: 11/4/2016 5:27:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26721

Source: City Water

Sample Location: B-3 R Sink 3

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0341		0.000515	mg/L	1	11/10/2016	A
Lead	0.0265	CF*	0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-68

Collection Date: 11/4/2016 5:36:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26715

Source: City Water

Sample Location: B-6 Sink 2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0883		0.000515	mg/L	1	11/10/2016	A
Lead	0.0342	CF*	0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-69

Collection Date: 11/3/2016 6:12:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26367

Source: City Water

Sample Location: Girls RR Sink RHA Hall

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0198		0.000515	mg/L	1	11/10/2016	A
Lead	0.00555		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-70

Collection Date: 11/3/2016 6:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26339

Source: City Water

Sample Location: Staff Rm Sink Betwn A-1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.446		0.000515	mg/L	1	11/10/2016	A
Lead	0.00426		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-71

Collection Date: 11/3/2016 6:12:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26394

Source: City Water

Sample Location: Girls RR Sink LH A Hall

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0152		0.000515	mg/L	1	11/10/2016	A
Lead	0.00284		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-72

Collection Date: 11/3/2016 6:05:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26379

Source: City Water

Sample Location: A4B Conference Rm

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00873		0.000515	mg/L	1	11/10/2016	A
Lead	0.00756		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-73

Collection Date: 11/3/2016 5:33:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26345

Source: City Water

Sample Location: Rm G2 Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0393		0.000515	mg/L	1	11/10/2016	A
Lead	0.0132		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-74

Collection Date: 11/3/2016 5:40:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26387

Source: City Water

Sample Location: H1 Sink Small Faucet

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00348		0.000515	mg/L	1	11/10/2016	A
Lead	0.00673		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-75

Collection Date: 11/3/2016 5:40:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26342

Source: City Water

Sample Location: H1 Sink Large Faucet

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0119		0.000515	mg/L	1	11/10/2016	A
Lead	0.00496		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-76

Collection Date: 11/3/2016 5:15:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26349

Source: City Water

Sample Location: Hand Wash Sink Kitchen

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.413		0.000515	mg/L	1	11/10/2016	A
Lead	0.00213		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-77

Collection Date: 11/3/2016 5:17:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26418

Source: City Water

Sample Location: Spray Nozzle Pot Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.148		0.000515	mg/L	1	11/10/2016	A
Lead	0.00262		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-78

Collection Date: 11/3/2016 5:22:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26402

Source: City Water

Sample Location: Kitchen Large Soup Pot

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0252		0.000515	mg/L	1	11/10/2016	A
Lead	0.00920		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-79

Collection Date: 11/3/2016 5:25:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26336

Source: City Water

Sample Location: Cafeteria DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0140		0.000515	mg/L	1	11/10/2016	A
Lead	0.00715		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-80

Collection Date: 11/3/2016 5:21:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26335

Source: City Water

Sample Location: RR Sink Kitchen

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0225		0.000515	mg/L	1	11/10/2016	A
Lead	0.00186		0.000103	mg/L	1	11/10/2016	A

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-81

Collection Date: 11/3/2016 5:15:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26343

Source: City Water

Sample Location: Dishwasher Spray Table Kit

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	1.00		0.00515	mg/L	10	11/11/2016	A
Lead	0.00211		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-82

Collection Date: 11/3/2016 6:15:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26382

Source: City Water

Sample Location: A Hall End DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.196		0.000515	mg/L	1	11/10/2016	A
Lead	0.00111		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-83

Collection Date: 11/3/2016 5:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26434

Source: City Water

Sample Location: I 2 Rm DF

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.800		0.000515	mg/L	1	11/10/2016	A
Lead	0.000362		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-84

Collection Date: 11/3/2016 5:35:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26326

Source: City Water

Sample Location: Band Rm Sink G1

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00470		0.000515	mg/L	1	11/10/2016	A
Lead	0.0209	CF*	0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-85

Collection Date: 11/3/2016 6:10:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26337

Source: City Water

Sample Location: Boys RR Sink LH A Hall

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0306		0.000515	mg/L	1	11/10/2016	A
Lead	0.00898		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-86

Collection Date: 11/3/2016 5:30:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26377

Source City Water

Sample Location: Student Store Sink

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0116		0.000515	mg/L	1	11/10/2016	A
Lead	0.0145		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-87

Collection Date: 11/3/2016 6:25:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26328

Source City Water

Sample Location: DF Next to LAC

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.187		0.000515	mg/L	1	11/10/2016	A
Lead	0.0105		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-88

Collection Date: 11/3/2016 5:20:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26358

Source City Water

Sample Location: Prep Sink Kitchen

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0116		0.000515	mg/L	1	11/10/2016	A
Lead	0.0121		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-89

Collection Date: 11/3/2016 5:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26338

Source City Water

Sample Location: Rm I 2 Bath Sink

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.595		0.000515	mg/L	1	11/10/2016	A
Lead	0.00119		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-90

Collection Date: 11/3/2016 5:55:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26344

Source City Water

Sample Location: Rm I 1 Bath Sink/Storage

Trace Metals by EPA 200.8 ICP-MS							
Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.582		0.000515	mg/L	1	11/10/2016	A
Lead	0.00143		0.000103	mg/L	1	11/10/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: 1611222

Received Date: 11/4/2016 8:22:00 AM

Reported Date: 11/21/2016 11:02:29 AM

Sample Information: Scenic Middle School - Lead & Coppers

Lab ID: 1611222-91

Collection Date: 11/3/2016 5:45:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26340

Source: City Water

Sample Location: Library Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0290		0.000515	mg/L	1	11/10/2016	A
Lead	0.00531		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-92

Collection Date: 11/3/2016 6:10:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26424

Source: City Water

Sample Location: Boys RR Sink RH A Hall

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.00728		0.000515	mg/L	1	11/10/2016	A
Lead	0.00927		0.000103	mg/L	1	11/10/2016	A

Lab ID: 1611222-93

Collection Date: 11/3/2016 6:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26351

Source: City Water

Sample Location: Staff Rm Sink Btwn A5

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.397		0.000515	mg/L	1	11/15/2016	A
Lead	0.00427		0.000103	mg/L	1	11/15/2016	A

Lab ID: 1611222-94

Collection Date: 11/3/2016 6:30:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26360

Source: City Water

Sample Location: Copy Rm Sink Main Office

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.0296		0.000515	mg/L	1	11/15/2016	A
Lead	0.0296	CF*	0.000103	mg/L	1	11/15/2016	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit