



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

**MEMBER
ACIL**

www.mvttl.com

Report Date: 22 Aug 2019

Work Order #: 12-13482
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 19 Aug 2019
Date Sampled: 14 Aug 2019
Time Sampled: 7:50
Temperature at Receipt: AMBIENT

PROJECT NAME: PINWOOD KITCHEN

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
19-A41783	USB UPPER STEAMER BAFFLE FAUCET	5.48 ug/L	15.0	21 Aug 19	KAM
19-A41784	USNB UPPER STEAMER NO BAFFLE	13.1 ug/L	15.0	21 Aug 19	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response
CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER