



Lead in Water Sample Results

For

Monticello Public School District
Monticello Middle School
2020 Testing and Follow Up



137 23rd St. South Suite 201 Sartell, MN 56377
(320) 255-3236 | Toll Free (888) 447-7032
Fax (320) 255-2998 | www.resourcecoop-mn.gov



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 7 Dec 2020

Work Order #: 12-16592
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 11 Nov 2020
Date Sampled: 6 Nov 2020
Time Sampled: 6:00
Temperature at Receipt: 17.7C

PROJECT NAME: MONTICELLO MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
20-A55967	1. CUSTODIAL ROOM	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55968	2. COMMONS FOUNTAIN	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55969	3. SCIENCE LAB	23.9 ug/L	15.0	20 Nov 20	KAM
20-A55970	4. 6TH GRADE #27	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55971	5. #24 SCIENCE SINK	35.6 ug/L	15.0	20 Nov 20	KAM
20-A55972	6. 6TH GRADE #34	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55973	7. ROOM #22	8.99 ug/L	15.0	20 Nov 20	KAM
20-A55974	8. NORTH WALL ROOM 19	2.58 ug/L	15.0	20 Nov 20	KAM
20-A55975	9. 6TH GRADE WEST	1.37 ug/L	15.0	20 Nov 20	KAM
20-A55976	10. D.O. KITCHEN	9.23 ug/L	15.0	20 Nov 20	KAM
20-A55977	11. D.O. FOUNTAIN	6.57 ug/L	15.0	20 Nov 20	KAM
20-A55978	12. ROOM #9	2.02 ug/L	15.0	20 Nov 20	KAM
20-A55979	13. FOUNDATIONS 2	0.65 ug/L	15.0	20 Nov 20	KAM
20-A55980	14. WEST GYM	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55981	15. BAND ROOM	< 0.5 ug/L	15.0	20 Nov 20	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 7 Dec 2020

Work Order #: 12-16592
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 11 Nov 2020
Date Sampled: 6 Nov 2020
Time Sampled: 6:00
Temperature at Receipt: 17.7C

PROJECT NAME: MONTICELLO MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
20-A55982	16. POOL WEST	0.60 ug/L	15.0	20 Nov 20	KAM
20-A55983	17. POOL SOUTH	8.23 ug/L	15.0	20 Nov 20	KAM
20-A55984	18. AUDITORIUM	0.52 ug/L	15.0	20 Nov 20	KAM
20-A55985	19. BOYS POOL LOCKER	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55986	20. GIRLS POOL LOCKER	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55987	21. ARENA WEST	10.6 ug/L	15.0	20 Nov 20	KAM
20-A55988	22. ARENA EAST	4.81 ug/L	15.0	20 Nov 20	KAM
20-A55989	23. ARENA ENTRANCE WOMEN	8.65 ug/L	15.0	20 Nov 20	KAM
20-A55990	24. ARENA ENTRANCE MENS	1.31 ug/L	15.0	20 Nov 20	KAM
20-A55991	25. ARENA CONCESSIONS	4.94 ug/L	15.0	20 Nov 20	KAM
20-A55992	26. KITCHEN	4.32 ug/L	15.0	20 Nov 20	KAM
20-A55993	27. KITCHEN PREP	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55994	28. KITCHEN HAND WASH	0.51 ug/L	15.0	20 Nov 20	KAM
20-A55995	29. NURSES OFFICE	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A55996	30. MS OFFICE	2.33 ug/L	15.0	20 Nov 20	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 7 Dec 2020

Work Order #: 12-16592
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 11 Nov 2020
Date Sampled: 6 Nov 2020
Time Sampled: 6:00
Temperature at Receipt: 17.7C

PROJECT NAME: MONTICELLO MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
20-A55997	31. MAIL ROOM	4.97 ug/L	15.0	20 Nov 20	KAM
20-A55998	32. TEACHERS LOUNGE	2.00 ug/L	15.0	20 Nov 20	KAM
20-A55999	33. ROOM 103	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A56000	34. FACS WEST SINK 1	3.15 ug/L	15.0	20 Nov 20	KAM
20-A56001	35. FACS WEST SINK 2	10.9 ug/L	15.0	20 Nov 20	KAM
20-A56002	36. FACS NORTH SINK 3	14.7 ug/L	15.0	20 Nov 20	KAM
20-A56003	37. FACS EAST WALL SINK 4	10.6 ug/L	15.0	20 Nov 20	KAM
20-A56004	38. FACS EAST WALL SINK 5	25.0 ug/L	15.0	20 Nov 20	KAM
20-A56005	39. FACS SOUTH SINK 6	16.4 ug/L	15.0	20 Nov 20	KAM
20-A56006	40. FACS SOUTH SINK 7	9.36 ug/L	15.0	20 Nov 20	KAM
20-A56007	41. ROOM 111	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A56008	42. ROOM 112	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A56009	43. ROOM 121	3.69 ug/L	15.0	20 Nov 20	KAM
20-A56010	44. ROOM 201	< 0.5 ug/L	15.0	20 Nov 20	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 7 Dec 2020

Work Order #: 12-16592
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 11 Nov 2020
Date Sampled: 6 Nov 2020
Time Sampled: 6:00
Temperature at Receipt: 17.7C

PROJECT NAME: MONTICELLO MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
20-A56011	45. ROOM 204	0.90 ug/L	15.0	20 Nov 20	KAM
20-A56012	46. MEDIA CENTER	3.42 ug/L	15.0	20 Nov 20	KAM
20-A56013	47. NE STAIR	27.5 ug/L	15.0	20 Nov 20	KAM
20-A56014	48. SE STAIR	3.31 ug/L	15.0	20 Nov 20	KAM
20-A56015	49. BASEMENT SOUTH	< 0.5 ug/L	15.0	20 Nov 20	KAM
20-A56016	50. BASEMENT WEST	16.2 ug/L	15.0	20 Nov 20	KAM
20-A56017	51. KITCHEN STEAMER	5.88 ug/L	15.0	20 Nov 20	KAM
20-A56018	52. 6TH GRADE GIRLS	13.1 ug/L	15.0	4 Dec 20	KAM
20-A56019	53. 6TH GRADE BOYS	13.3 ug/L	15.0	20 Nov 20	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 28 Jan 2021

Work Order #: 12-4614
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 20 Jan 2021
Temperature at Receipt: AMBIENT

PROJECT NAME: MONTICELLO MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A2528	MMS 55 FACS NORTH SINK #3 1ST PULL	0.99 ug/L	15.0	25 Jan 21	KAM
21-A2529	MMS 56 FACS EAST #5 1ST PULL	7.63 ug/L	15.0	25 Jan 21	KAM
21-A2530	MMS 57 FACS SOUTH SINK #6 1ST PULL	7.81 ug/L	15.0	25 Jan 21	KAM
21-A2531	MMS 58 FACS EAST SINK #5 2ND PULL	2.53 ug/L	15.0	25 Jan 21	KAM
21-A2532	MMS 59 FACS NORTH SINK #3 2ND PULL	2.64 ug/L	15.0	25 Jan 21	KAM
21-A2533	MMS 60 FACS SOUTH SINK #6 2ND PULL	2.62 ug/L	15.0	25 Jan 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response
CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER