



Lead in Water Sample Results

For

Monticello Public School District
High School
2021 Testing



137 23rd St. South Suite 201 Sartell, MN 56377
(320) 255-3236 | Toll Free (888) 447-7032
Fax (320) 255-2998 | www.resourcecoop-mn.gov



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 24 Nov 2021

Work Order #: 12-17542
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 3 Nov 2021
Date Sampled: 2 Oct 2021
Time Sampled: 6:00
Temperature at Receipt: 17.8C

PROJECT NAME: MONTICELLO H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A57665	#1 KITCHEN SINK BY COOLER	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57666	#2 KITCHEN SINK BY STORAGE	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57667	#3 STEAM KETTLE WEST	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57668	#4 STEAM KETTLE EAST	1.17 ug/L	15.0	22 Nov 21	KAM
21-A57669	#5 TEACHERS LOUNGE	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57670	#6 DF BY LOUNGE	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57671	#7 DF MAIN STREET WEST HIGH	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57672	#8 DF MAIN STREET WEST LAV	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57673	#9 DF BY BAND HIGH	0.86 ug/L	15.0	22 Nov 21	KAM
21-A57674	#10 DF BY BAND LOW	< 0.5 ug/L	15.0	22 Nov 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 24 Nov 2021

Work Order #: 12-17542
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 3 Nov 2021
Date Sampled: 2 Oct 2021
Time Sampled: 6:00
Temperature at Receipt: 17.8C

PROJECT NAME: MONTICELLO H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A57675	#12 MAIN ST EAST HIGH	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57676	#13 MAIN ST EAST LOW	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57677	#14 GIRLS LOCKER ROOM HIGH	0.55 ug/L	15.0	22 Nov 21	KAM
21-A57678	#15 GIRLS LOCKER ROOM LOW	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57679	#16 CONCESSIONS	2.57 ug/L	15.0	22 Nov 21	KAM
21-A57680	#17 FIELD HOUSE	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57681	#18 BOYS LOCKER HIGH	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57682	#19 BOYS LOCKER LOW	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57683	#20 LANGUAGE POD HIGH	0.60 ug/L	15.0	22 Nov 21	KAM
21-A57684	#21 LANGUAGE POD LOW	0.62 ug/L	15.0	22 Nov 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 24 Nov 2021

Work Order #: 12-17542
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 3 Nov 2021
Date Sampled: 2 Oct 2021
Time Sampled: 6:00
Temperature at Receipt: 17.8C

PROJECT NAME: MONTICELLO H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A57685	#22 FOUNTAIN DOOR 2	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57686	#23 SPEC ED KITCHEN	0.56 ug/L	15.0	22 Nov 21	KAM
21-A57687	#24 FOUNTAIN DOOR 5	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57688	#25 FACS BLACK	0.71 ug/L	15.0	22 Nov 21	KAM
21-A57689	#26 FACS GREEN	0.52 ug/L	15.0	22 Nov 21	KAM
21-A57690	#27 FACS YELLOW	0.69 ug/L	15.0	22 Nov 21	KAM
21-A57691	#28 FACS BLUE	0.71 ug/L	15.0	22 Nov 21	KAM
21-A57692	#29 FACS RED	0.77 ug/L	15.0	22 Nov 21	KAM
21-A57693	#30 FACS PURPLE	0.74 ug/L	15.0	22 Nov 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

MEMBER
ACIL

www.mvttl.com

Report Date: 24 Nov 2021

Work Order #: 12-17542
Account #: 019442

JOSH BAUMANN
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 3 Nov 2021
Date Sampled: 2 Oct 2021
Time Sampled: 6:00
Temperature at Receipt: 17.8C

PROJECT NAME: MONTICELLO H.S.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
21-A57694	#31 FACS ORANGE	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57695	#32 MATH POD	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57696	#33 OFFICE WORKROOM	0.81 ug/L	15.0	22 Nov 21	KAM
21-A57697	#34 ENGLISH POD	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57698	#35 SPECIAL ED POD	0.61 ug/L	15.0	22 Nov 21	KAM
21-A57699	#36 MEDIA CENTER EAST	< 0.5 ug/L	15.0	22 Nov 21	KAM
21-A57700	#37 MEDIA CENTER WEST	< 0.5 ug/L	15.0	22 Nov 21	KAM

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response
CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER



**Minnesota Department of Health
Environmental Laboratory Accreditation Program**

Issues accreditation to

State Laboratory ID: 027-015-125

EPA Lab Code: MN00008

Minnesota Valley Testing Laboratories, Inc.

1126 N Front St

New Ulm, MN 56073

for fields of accreditation listed on the laboratory's accompanying Scope of Certification
in accordance with the provisions in Minnesota Laws and Rules.

Continued accreditation is contingent upon successful on-going compliance with Minnesota Statutes 144.97 to 144.98, 2009 TNI Standard and applicable Minnesota Rules 4740.2010 to 4740.2120. The laboratory's Scope of Certification cites the specific programs, methods, analytes and matrices for which MDH issues this accreditation.

This certificate is valid proof of accreditation only when associated with its accompanying Scope of Certification.

The Scope of Certification and reports of on-site assessments are on file at the Minnesota Department of Health, 601 Robert Street North, Saint Paul, Minnesota. Customers may verify the laboratory's accreditation status in Minnesota by contacting MNELAP at (651) 201-5324.

Effective Date: 12/01/2020

Expires: 12/31/2021

Certificate Number: 1981273



Issued under the authority
delegated by the
Commissioner of Health,
State of Minnesota