

School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

Instructions

1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
2. Include this form, raw data (e.g. laboratory report) and a building map.
3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
4. Email information to health.indoorair@state.mn.us.

Contact Information

Name: <i>Wendy German</i>	
Mailing Address: <i>7362 East Point Douglas Rd S, Cottage Grove, MN 55016</i>	
Phone: <i>320-224-1908</i>	Email: <i>wgerman@sowashco.org</i>

Initial Radon Testing Information

School Building Name: <i>Cottage Grove Middle School</i>	
School District & District Number: <i>South Washington County Schools - District 833</i>	
Building Address: <i>9775 Indian Blvd S, Cottage Grove, MN 55016</i>	
Test Kit Manufacturer: <i>AirChek</i>	Device Name: <i>Pro Chek</i>
Date of Kit Retrieval (DD/MM/YY): <i>03/22/19</i>	Length of Test (days): <i>3</i>
How many rooms were tested? <i>62</i>	
Does the test period include weekends? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Does the test period include school breaks or holidays? <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact rooms tested?¹ Yes No
 If no, did you attempt to test all frequently occupied ground contact rooms, meaning test kits were placed in all these rooms? Yes No

How many rooms had results ≥ 4 pCi/L?: 0

Were the results reported at a school board meeting? Yes No *Scheduled for upcoming meeting*

Follow-up Testing, Mitigation, & Post-Mitigation Testing

If one or more rooms tested ≥ 4 pCi/L, please answer the questions below:

How many rooms had follow-up testing?:

Number of rooms with follow-up results	≥ 4 pCi/L:	< 4 pCi/L:
--	-----------------	------------

Of the rooms that had test results ≥ 4 pCi/L, how many rooms were:

mitigated by HVAC balancing or operational changes? :

mitigated by installation of active soil depressurization?:

addressed through other corrective measures?²:

What was the cost of the installation and/or HVAC service work, to mitigate radon? \$

What is the known or anticipated annual operating cost of mitigation (estimate)? \$

After radon mitigation, how many rooms were retested?:

Post mitigation results (# of rooms)	≥ 4 pCi/L:	< 4 pCi/L:
--------------------------------------	-----------------	------------

¹ This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

² 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

Radon test result report for:**COTTAGE GROVE MIDDLE**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9197524	A105	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197525	A114	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	0.5 ± 0.5	2019-03-27
9197522	A116	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197516	A120	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197521	A123	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	0.5 ± 0.5	2019-03-27
9197520	A130	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197519	A131	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197518	A132	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197517	A133	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197514	A134	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	0.6 ± 0.5	2019-03-27
9197513	A135	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197510	A136	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197509	A137	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197512	A139	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197511	A144	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197538	B101	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197537	B102	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197536	B103	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197535	B105	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197534	B106	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197533	B108	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197532	B109	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197531	B110	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197529	B121	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197548	C101	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197550	C102	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197553	C103	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197554	C104	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197551	C105	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197552	C107	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197555	C113	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197556	C114	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197557	C115	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197558	C116	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197559	C117	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197560	C118	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197561	C119	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27

March 27, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

COTTAGE GROVE MIDDLE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9197562	C120	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197515	D104	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197508	D130 NURSE	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197506	D134	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197507	D138	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197503	D139	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197504	D143	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197505	D144	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197566	E126 CUSTODIANS	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197567	G106	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197564	G108	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197565	GYM	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197530	H103	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197528	H10I	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197568	H130	2019-03-19 @ 1:00 pm	2019-03-22 @ 3:00 pm	< 0.3	2019-03-27
9197570	H131	2019-03-19 @ 1:00 pm	2019-03-22 @ 3:00 pm	< 0.3	2019-03-27
9197539	J102	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197540	J104	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197541	J105	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197542	J106	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197543	J108	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197544	J109	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197547	J110	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197545	J111	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197546	J112	2019-03-19 @ 12:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27
9197501	MAIN OFFICE 1	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197502	MAIN OFFICE 2	2019-03-19 @ 12:00 pm	2019-03-22 @ 11:00 am	< 0.3	2019-03-27
9197563	MEDIA CENTRR	2019-03-19 @ 1:00 pm	2019-03-22 @ 12:00 pm	< 0.3	2019-03-27