

# School Radon Testing Reporting Form

According to Minnesota Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health. Please use this form to submit information about the most recent round or cycle of testing conducted for each building.

## Instructions

1. Complete one form for each building tested. In this case, a building is defined as an occupied facility with a unique address. This includes administrative buildings.
2. Include this form, raw data (e.g. laboratory report) and a building map.
3. Submit this form when all work is completed for a round of testing. This includes reporting to the school board, and follow-up testing and post-mitigation testing, if applicable.
4. Email information to [health.indoorair@state.mn.us](mailto:health.indoorair@state.mn.us).

## Contact Information

Name: <i>Wendy German</i>	
Mailing Address: <i>7362 East Point Douglas Rd, Cottage Grove, MN 55016</i>	
Phone: <i>320-224-1908</i>	Email: <i>wgerman@sowashco.org</i>

## Initial Radon Testing Information

School Building Name: <i>Hillside Elementary</i>	
School District & District Number: <i>South Washington County Schools- District 833</i>	
Building Address: <i>8177 Hillside Trail S, Cottage Grove, MN 55016</i>	
Test Kit Manufacturer: <i>Air Check</i>	Device Name: <i>Pro Check</i>
Date of Kit Retrieval (DD/MM/YY): <i>03/22/19</i>	Length of Test (days): <i>3</i>
How many rooms were tested? <i>40</i>	
Does the test period include weekends? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Does the test period include school breaks or holidays? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

SCHOOL RADON TESTING REPORTING FORM

Were all frequently-occupied ground contact rooms tested?<sup>1</sup>  Yes  No  
 If no, did you attempt to test all frequently occupied ground contact rooms, meaning test kits were placed in all these rooms?  Yes  No

How many rooms had results  $\geq 4$  pCi/L?:

Were the results reported at a school board meeting?  Yes  No *scheduled for upcoming meeting*

### Follow-up Testing, Mitigation, & Post-Mitigation Testing

If one or more rooms tested  $\geq 4$  pCi/L, please answer the questions below:

How many rooms had follow-up testing?:

Number of rooms with follow-up results	$\geq 4$ pCi/L:	< 4 pCi/L:
--	-----------------	------------

Of the rooms that had test results  $\geq 4$  pCi/L, how many rooms were:

mitigated by HVAC balancing or operational changes? :

mitigated by installation of active soil depressurization?:

addressed through other corrective measures?<sup>2</sup>:

What was the cost of the installation and/or HVAC service work, to mitigate radon? \$

What is the known or anticipated annual operating cost of mitigation (estimate)? \$

After radon mitigation, how many rooms were retested?:

Post mitigation results (# of rooms)	$\geq 4$ pCi/L:	< 4 pCi/L:
--------------------------------------	-----------------	------------

<sup>1</sup> This includes classrooms, offices, break rooms, laboratories, cafeterias, libraries, auditoriums, gymnasiums, etc. It includes rooms on grade and rooms above unoccupied spaces that are in contact with the ground, such as rooms above storage rooms, crawl spaces, tunnels, and boiler rooms. If only a sample or portion of rooms were tested, then respond with 'no'.

<sup>2</sup> 'Other corrective measures' could include moving staff out of a room and making a room unoccupied or trying to seal radon entry points.

Radon test result report for:

**HILLSIDE ELEMENTARY**

<b>Kit.#</b>	<b>Room-Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9197780	100	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197779	100A	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197781	100B	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197896	101	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197782	102	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197795	103	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197783	104	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197793	105	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197784	106	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197792	107	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197785	108	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197791	109	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197786	110	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197790	111	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197787	112	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197789	113	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197788	114	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197887	200	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197888	202	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197671	203	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197796	204	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197670	205	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197889	206	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197669	207	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197895	208	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197668	209	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197893	210	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197667	211	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197894	212	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197666	213	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197662	214	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197665	215	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197663	216	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197664	217	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197778	COINSELOR	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197673	GYMS	2019-03-19 @ 11:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197794	MEDIA CENTER	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27

---

March 27, 2019

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**HILLSIDE ELEMENTARY**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9197672	MUSIC	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197800	NURSE	2019-03-19 @ 10:00 am	2019-03-22 @ 10:00 am	< 0.3	2019-03-27
9197797	OFFICE	2019-03-19 @ 10:00 am	2019-03-22 @ 9:00 am	< 0.3	2019-03-27
9197798	OFFICE 2	2019-03-19 @ 10:00 am	2019-03-22 @ 9:00 am	< 0.3	2019-03-27
9197799	PRINCIPAL	2019-03-19 @ 10:00 am	2019-03-22 @ 9:00 am	< 0.3	2019-03-27

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498