



NOTES:
 - The curb cut for building and field access does not meet current ADA standards.

Field and Building Access Photo Locations

Site Access Plan
 Karshner Elementary School
 1328 8th Ave. N.W.
 Puyallup, WA 98371

Scale:
 NTS

Drawn By:
 RG

Date:
 April 2019

Site/ Bldg/ Floor No.
 04-Site

Range/ Township/ Section:
 04-20-28

Parcel Number(s):
 4920000491

Sheet No.

Karshner Field and Building Access Picture Index

1



ADA stalls in parking lot. Crosswalk to sidewalk missing.

2



There is currently no curb cut. However, there is an asphalt ramp which can be used to gain access to the sidewalk.

3



Once on the sidewalk, turn left and a sign directs you to the field. The east end door is locked at all times, but staff often allows parents to enter at the start and end of a school day using the ramp on the end of the classroom wings. For access during the rest of the day, enter the building through the front door (north side) by the main office.

4



The front door on 8th Ave N.W. is locked during school hours, ring bell to acquire access. Note that the ramp does not meet ADA standards.