



1. FIRE PROTECTION PERFORMANCE CRITERIA PLAN - FIRST FLOOR
1/8" = 1'-0"

SPRINKLER COVERAGE
ALL AREAS SHALL BE AUTOMATICALLY SPRINKLERED UNLESS OTHERWISE NOTED TO THE CONTRARY.
SPRINKLER COVERAGE DENSITY: 0.15 GPM/FT²
HOSE ALLOWANCE: 100 GPM

SPRINKLER COVERAGE
ALL AREAS SHALL BE AUTOMATICALLY SPRINKLERED UNLESS OTHERWISE NOTED TO THE CONTRARY.
SPRINKLER COVERAGE DENSITY: 0.15 GPM/FT²
HOSE ALLOWANCE: 200 GPM

FIRE PROTECTION LEGEND
1/8" = 1'-0"

FIRE PROTECTION PERFORMANCE CRITERIA - LEVEL ONE

SHEET TITLE: FIRE PROTECTION PERFORMANCE CRITERIA - LEVEL ONE

SHEET NO.: F101

DATE: 02/20/04

MUSSMAN ARCHITECTS
610 N. MAIN STREET CHARLOTTE, NC 27601
PH: 848-6230 email: jason@mussmanarchitects.com

DESIGNED BY: JAMES F. TURNER, P.E.
CHECKED BY: JAMES F. TURNER, P.E.
DATE: 02/20/04



TCCA HIGH SCHOOL BUILDING
1400 SE CORE RD
STUART FLORIDA 34997

NO.	DATE	DESCRIPTION	BY