

Bethany

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen	22430400-001KF23A	6/2/2023	0.347
Cafeteria	22430400-002DW23A	6/2/2023	ND
Main Corridor	22430400-003WB23A	6/2/2023	ND
Main Corridor	22430400-004DW23A	6/2/2023	ND
Gym	22430400-005DW23A	6/2/2023	ND
Staff Lounge Water Cooler	22430400-006WB23A	6/2/2023	ND
Staff Lounge	22430400-007SF23A	6/2/2023	0.21
Staff Lounge Filtered Water By Sink	22430400-008WB23A	6/2/2023	ND
Nurse's Office	22430400-009NS23A	6/2/2023	0.762
Principal's Office	22430400-010SF23A	6/2/2023	1.32
A100	22430400-011CF23A	6/2/2023	0.802
A100	22430400-012DW23A	6/2/2023	2.3
A102	22430400-013CF23A	6/2/2023	0.352
A102	22430400-014DW23A	6/2/2023	0.35
A104	22430400-015CF23A	6/2/2023	1.58
A104	22430400-016DW23A	6/2/2023	1.61
A107	22430400-017CF23A	6/2/2023	0.318
A106	22430400-018CF23A	6/2/2023	ND
A106	22430400-019DW23A	6/2/2023	1.83
A108	22430400-020CF23A	6/2/2023	ND
A108	22430400-021DW23A	6/2/2023	0.502
A110	22430400-022CF23A	6/2/2023	0.346
A110	22430400-023DW23A	6/2/2023	0.305
A112	22430400-024CF23A	6/2/2023	0.241
A112	22430400-025DW23A	6/2/2023	0.589
A114	22430400-026CF23A	6/2/2023	0.538
A114	22430400-027DW23A	6/2/2023	0.227
A116	22430400-028CF23A	6/2/2023	0.671
A116	22430400-029DW23A	6/2/2023	0.667
A118	22430400-030CF23A	6/2/2023	13
A118	22430400-031DW23A	6/2/2023	1.28
A120	22430400-032CF23A	6/2/2023	ND
A120	22430400-033DW23A	6/2/2023	2.54
A122	22430400-034CF23A	6/2/2023	0.464
A122	22430400-035DW23A	6/2/2023	0.826
A Hall	22430400-036WB23A	6/2/2023	ND
A Hall	22430400-037DW23A	6/2/2023	ND
Staff / B100	22430400-038CF23A	6/2/2023	0.527
Staff / B100	22430400-039DW23A	6/2/2023	1.29
B112	22430400-040CF23A	6/2/2023	0.487
B112	22430400-041DW23A	6/2/2023	1.19
B114	22430400-044CF23A	6/2/2023	ND
B114	22430400-044CF23A D	6/2/2023	ND
B116	22430400-045DW23A	6/2/2023	0.436

B116	22430400-045DW23A D	6/2/2023	0.633
B118	22430400-046CF23A	6/2/2023	0.351
B118	22430400-047DW23A	6/2/2023	0.507
B120	22430400-048CF23A	6/2/2023	ND
B120	22430400-049DW23A	6/2/2023	ND
B122	22430400-050CF23A	6/2/2023	ND
B122	22430400-051DW23A	6/2/2023	0.395
B124	22430400-052CF23A	6/2/2023	ND
B124	22430400-053DW23A	6/2/2023	ND
B126	22430400-054CF23A	6/2/2023	0.352
B126	22430400-055DW23A	6/2/2023	0.333
B128	22430400-056CF23A	6/2/2023	ND
B128	22430400-057DW23A	6/2/2023	ND