

Kinnaman

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen	22431400-001KF23A	4/28/2023	0.93
Kitchen	22431400-002KF23A	4/28/2023	3.17
Main Hall	22431400-003DW23A	4/28/2023	0.71
Nurse	22431400-004NS23A	4/28/2023	1.48
A100	22431400-005CF23A	4/28/2023	2.67
A100	22431400-006DW23A	4/28/2023	0.244
A102	22431400-007CF23A	4/28/2023	0.511
A102	22431400-008DW23A	4/28/2023	1.01
A104	22431400-009CF23A	4/28/2023	6.23
A104	22431400-010DW23A	4/28/2023	0.634
A106	22431400-011CF23A	4/28/2023	3.86
A106	22431400-012DW23A	4/28/2023	1.61
A108	22431400-013CF23A	4/28/2023	3.86
A108	22431400-014DW23A	4/28/2023	1.79
A110	22431400-015DW23A	4/28/2023	7.09
A110	22431400-016DW23A	4/28/2023	0.94
A112	22431400-017CF23A	4/28/2023	5.6
A114	22431400-018CF23A	4/28/2023	2.31
A114	22431400-019DW23A	4/28/2023	1.17
A116	22431400-020CF23A	4/28/2023	8.55
A116	22431400-021DW23A	4/28/2023	0.553
A118	22431400-022CF23A	4/28/2023	8.83
A118	22431400-023DW23A	4/28/2023	0.511
A120	22431400-024CF23A	4/28/2023	4.67
A120	22431400-025DW23A	4/28/2023	0.32
A122	22431400-026CF23A	4/28/2023	6.18
A122	22431400-027DW23A	4/28/2023	0.934
A124	22431400-028CF23A	4/28/2023	7.74
A124	22431400-029DW23A	4/28/2023	0.796
GYM	22431400-030DW23A	4/28/2023	0.637
B100	22431400-031CF23A	4/28/2023	3.77
B100	22431400-032DW23A	4/28/2023	7.31
B102	22431400-033CF23A	4/28/2023	4.94
B102	22431400-034DW23A	4/28/2023	3.09
B104	22431400-035CF23A	4/28/2023	4.61
B104	22431400-036DW23A	4/28/2023	9.43
C100	22431400-037CF23A	4/28/2023	0.962
C100	22431400-038DW23A	4/28/2023	0.345
C102	22431400-039CF23A	4/28/2023	1.29
C102	22431400-040DW23A	4/28/2023	0.224
C104	22431400-041CF23A	4/28/2023	1.91
C104	22431400-042DW23A	4/28/2023	0.273
C106	22431400-043CF23A	4/28/2023	2.62

C106	22431400-044DW23A	4/28/2023	0.275
C108	22431400-045CF23A	4/28/2023	1.37
C108	22431400-046DW23A	4/28/2023	0.643
C110	22431400-047CF23A	4/28/2023	2.33
C110	22431400-048DW23A	4/28/2023	0.463
C112	22431400-049CF23A	4/28/2023	2.04
C112	22431400-050DW23A	4/28/2023	0.35
C114	22431400-051CF23A	4/28/2023	7.09
C114	22431400-052DW23A	4/28/2023	1.84
C116	22431400-053CF23A	4/28/2023	1.61
C116	22431400-054DW23A	4/28/2023	0.25
C118	22431400-055CF23A	4/28/2023	4.16
C118	22431400-056DW23A	4/28/2023	0.999
C120	22431400-057CF23A	4/28/2023	3.02
C120	22431400-058DW23A	4/28/2023	0.285
C122	22431400-059CF23A	4/28/2023	4.73
C122	22431400-060DW23A	4/28/2023	0.844
C124	22431400-061CF23A	4/28/2023	3.02
C124	22431400-062DW23A	4/28/2023	0.548
C126	22431400-063CF23A	4/28/2023	3.17
C126	22431400-064DW23A	4/28/2023	7.53
C128	22431400-065CF23A	4/28/2023	1.4
C128	22431400-066DW23A	4/28/2023	0.398
C HALL	22431400-068DW23A	4/28/2023	1.3
C HALL	22431400-069DW23A	4/28/2023	1.12
B106	22431400-070CF23A	4/28/2023	5.75
B106	22431400-071DW23A	4/28/2023	4.25
B108	22431400-072CF23A	4/28/2023	2.17
B108	22431400-073DW23A	4/28/2023	3.74
B110	22431400-074CF23A	4/28/2023	1.35
B110	22431400-075DW23A	4/28/2023	6.4
B Hall	22431400-076DW23A	4/28/2023	0.757
B112	22431400-077WB23A	4/28/2023	ND
B112	22431400-078SF23A	4/28/2023	0.447
C124 South Wall	22431400-079CF23A	6/8/2023	0.239
C124 South Wall	22431400-080DW23A	6/8/2023	0.516
C124 West Wall	22431400-081DW23A	6/8/2023	3.49