

	Solicitation # Date Issued Procurement Officer Phone Email	FAC2223-05 February 14, 2022 Laurie O Lane 843-398-2249 Laurie.lane@darlington.k12.sc.us
--	--	--

Addendum #1

Description of solicitation: DHS Bldg 1 Split Systems Replacement

You must acknowledge this amendment on the Invitation For Bid (page 1) for your bid to be considered.

**AMENDMENTS TO SOLICITATION** a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <http://www.darlington.k12.sc.us> Click Departments, Click Finance & Procurement, Click Solicitations, Click 2022-23 Operations Solicitations, (b) Bidders shall acknowledge receipt of any Amendment to this solicitation (1) by signing and returning the Amendment, (2) by letter, or (3) by submitting a bid that indicates in some way that the bidder received the amendment.

Solicitation has been amended as follows:

**Q: Are the contractors allowed to use existing line sets for the split systems?**

A: DCSD will allow the use of the existing line sets under the following conditions.

The lines must be flushed with a R11 type cleaner. After the lines are flushed out, they are to be pressurized and left to set overnight to test. If these lines hold the pressure overnight, then they can be used. If a leak is detected or a bad spot appears, then the lines must be changed out.

**Q: Can the contractors use any other manufacturer than was specified in the scope?**

The contractors brought up lead times and unit availability.

A: We will allow only the manufacturers specified in the scope. However, it is ok to use for example, with the 23 package units, 10 Carrier and 13 Trane units. As long as the units are Trane, (American Standard), or Carrier type it is ok to mix.