

	Solicitation # Date Issued Procurement Officer Phone Email	FAC2223-07 March 1, 2023 Laurie O Lane 843-398-2249 laurie.lane@darlington.k12.sc.us
---	--	--

Addendum #2

Description of solicitation: HHS Bldg 3 HVAC Replacement

You must acknowledge this amendment on the Invitation For Bid (page 1) for your bid to be considered.

AMENDMENTS TO SOLICITATION a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <http://www.darlington.k12.sc.us> Click Departments, Click Finance & Procurement, Click Solicitations, Click 2022-23 Operations Solicitations, (b) Bidders shall acknowledge receipt of any Amendment to this solicitation (1) by signing and returning the Amendment, (2) by letter, or (3) by submitting a bid that indicates in some way that the bidder received the amendment.

Solicitation has been amended as follows:

The following model numbers were incorrect on the original bid paperwork, please note the changes below.

Incorrect number Room 319 50TCQA06A2A5A0A0 Correct number Room 319 50TCQA04A2A5A0A0 3 ton unit

Model number on Room 313 is correct but tonnage is incorrect on bid. This is a 5 ton unit.

Total units on roof are (7) 3 ton units and (2) 5 ton units.