



**SOUTH RIVER PUBLIC SCHOOLS
LEAD IN DRINKING WATER
FIRST & FLUSH DRAW SAMPLING REPORT**

PERFORMED FOR:

SOUTH RIVER PUBLIC SCHOOLS
15 MONTGOMERY STREET
SOUTH RIVER, NJ 08882

PERFORMED BY:

WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380

JUNE 2022



June 15, 2022

Mr. Steven Blajda
South River Public Schools
15 Montgomery Street
South River, NJ 08882

Re: FIRST & FLUSH DRAW LEAD IN DRINKING WATER REPORT

Dear Mr. Blajda;

Please find enclosed the report for the Lead in Drinking Water First & Flush Draw Sampling conducted for South River Public Schools.

If you have any questions, please don't hesitate to contact me at 610-431-7545 or email me at nabraham@WestChesterEnvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', followed by a horizontal line.

Noel Abraham
Environmental Specialist



TABLE OF CONTENTS

SOUTH RIVER PUBLIC SCHOOLS

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	7
4.0	DISCUSSION & RECOMMENDATIONS.....	8
5.0	DISCLAIMER.....	9

Appendix I – Water Sampling Chains-of-Custody & Laboratory Reports



1.0 INTRODUCTION

Westchester Environmental, LLC was contracted by Mr. Steven Blajda to conduct Drinking Water Sampling at the South River Public Schools.

The purpose of the sampling was to collect first draw and flush draw drinking water samples at predetermined locations in the facility and have them analyzed for lead levels.

The water sampling was performed on April 12, 2022 by Noel Abraham and Chris Piccininni of Westchester Environmental, LLC.

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

-END OF SECTION-

2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Tables 1-3 below show the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1: Primary School

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
1	SRPS--- Field Blank	<1.00	15.5	No
2	SRPS-GF-S-Main Office Bathroom	<1.00	15.5	No
3	SRPS-GF-WC-Hall o/s Main Office	<1.00	15.5	No
4	SRPS-1FL-WC- Hall o/s 104	<1.00	15.5	No
5	SRPS-1FL-DW-Nurse	22.9	15.5	Yes
6	SRPS-1FL-WC-Hall o/s Rm 115	<1.00	15.5	No
7	SRPS-1FL-WC-Hall o/s Cafe-1	<1.00	15.5	No
8	SRPS-1FL-WC-Hall o/s Cafe-2	<1.00	15.5	No
9	SRPS-1FL-WC-Cafe-1	<1.00	15.5	No
10	SRPS-1FL-WC-Cafe-2	<1.00	15.5	No
11	SRPS-1FL-FP-Kitchen	2.75	15.5	No
12	SRPS-2FL-WC-Media Center-2	<1.00	15.5	No
13	SRPS-2FL-WC-Hall o/s 209	<1.00	15.5	No
14	SRPS-2FL-WC-Hall o/s Media Ctr-1	<1.00	15.5	No
15	SRPS-2FL-WC-Hall o/s Media Ctr-2	<1.00	15.5	No
16	SRPS-2FL-WC-o/s Rm 202	<1.00	15.5	No



Table 2: Elementary/Middle School

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
17	SRE/MS-2FL-POE-2nd Floor	<1.00	15.5	No
18	SRE/MS-2FL-DW-Music	6.71	15.5	No
19	SRE/MS-2FL-WC-Hall o/s Rm 212-1	<1.00	15.5	No
20	SRE/MS-2FL-DW-Rm 215	<1.00	15.5	No
21	SRE/MS-2FL-DW-Rm 214	<1.00	15.5	No
22	SRE/MS-2FL-DW-Rm 216	1.03	15.5	No
23	SRE/MS-2FL-DW-Rm 217	3.22	15.5	No
24	SRE/MS-2FL-DW-Rm 219	1.92	15.5	No
25	SRE/MS-2FL-DW-Rm 221	<1.00	15.5	No
26	SRE/MS-2FL-WC- Hallway side Rm 220-1	<1.00	15.5	No
27	SRE/MS-2FL-WC- Hall o/s Rm 210-1	<1.00	15.5	No
28	SRE/MS-2FL-DW- Rm 209	1.04	15.5	No
29	SRE/MS-2FL-DW- Rm 208	<1.00	15.5	No
30	SRE/MS-2FL-DW- Rm 207	<1.00	15.5	No
31	SRE/MS-2FL-DW- Rm 206	<1.00	15.5	No
32	SRE/MS-2FL-DW- Rm 205	1.09	15.5	No
33	SRE/MS-2FL-DW- Rm 204	<1.00	15.5	No
34	SRE/MS-2FL-DW- Rm 202	2.22	15.5	No
35	SRE/MS-2FL-DW- Rm 203	<1.00	15.5	No
36	SRE/MS-2FL-FS- Faculty Loungs	<1.00	15.5	No
37	SRE/MS-2FL-NS-Nurse Office-1	1.87	15.5	No
38	SRE/MS-2FL-NS-Nurse Office-2	<1.00	15.5	No
39	SRE/MS-2FL-WC-Hall o/s Faculty-1	<1.00	15.5	No
40	SRE/MS-2FL-WC-O/S Stage-1	<1.00	15.5	No
41	SRE/MS-2FL-WC-Hall o/s 224-1	<1.00	15.5	No
42	SRE/MS-2FL-WC-Cafe-1	<1.00	15.5	No
43	SRE/MS-2FL-WC-Cafe-2	<1.00	15.5	No
44	SRE/MS-2FL-S-Cafe Faculty	<1.00	15.5	No
45	SRE/MS-2FL-FP-Kitchen-1	<1.00	15.5	No
46	SRE/MS-2FL-FP-Kitchen-2	4.76	15.5	No
47	SRE/MS-2FL-FP-Kitchen-3	2.56	15.5	No
48	SRE/MS-2FL-FP-Kitchen-4	48.7	15.5	Yes
49	SRE/MS-3FL-WC-Hall o/s 302-1	<1.00	15.5	No
50	SRE/MS-3FL-S-Mid Main Office-1	<1.00	15.5	No
51	SRE/MS-3FL-FS-Mid Teachers Lounge	<1.00	15.5	No
52	SRE/MS-3FL-NS-Nurse-1	<1.00	15.5	No



	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
53	SRE/MS-3FL-NS-Nurse-2	2.56	15.5	No
54	SRE/MS-3FL-WC-O/S Nurse-1	<1.00	15.5	No
55	SRE/MS-3FL-DW-Rm 320	<1.00	15.5	No
56	SRE/MS-3FL-DW-Rm 318	6.43	15.5	No
57	SRE/MS-3FL-S-Rm 319-1	4.05	15.5	No
58	SRE/MS-3FL-S-Rm 319-2	<1.00	15.5	No
59	SRE/MS-3FL-DW-Rm 317	3.63	15.5	No
60	SRE/MS-3FL-DW-Rm 316	1.33	15.5	No
61	SRE/MS-3FL-DW-Rm 313	1.26	15.5	No
62	SRE/MS-3FL-WC-Hall o/s Elevator-1	<1.00	15.5	No
63	SRE/MS-1FL-DW-Rm 105	3.78	15.5	No
64	SRE/MS-1FL-DW-Rm 104	<1.00	15.5	No
65	SRE/MS-1FL-DW-Rm 106	1.8	15.5	No
66	SRE/MS-1FL-DW-Rm 109	1.22	15.5	No
67	SRE/MS-1FL-DW-Rm 110	1.87	15.5	No
68	SRE/MS-1FL-DW-Rm 111	<1.00	15.5	No
69	SRE/MS-1FL-DW-Rm 113	3.05	15.5	No
70	SRE/MS-1FL-DW-Rm 114	1.51	15.5	No
71	SRE/MS-1FL-WC-Hall o/s Rm 114-1	<1.00	15.5	No
72	SRE/MS-1FL-WC-Aux Gym A	<1.00	15.5	No
73	SRE/MS-1FL-WC-Hall o/s Girls LR-1	<1.00	15.5	No
74	SRE/MS-1FL-WC-Hall o/s 100B-1	<1.00	15.5	No
75	SRE/MS-1FL-DW-Rm 117	8.9	15.5	No
76	SRE/MS-1FL-DW-Rm 119	<1.00	15.5	No
77	SRE/MS-1FL-DW-Rm 118	2.25	15.5	No
78	SRE/MS-1FL-DW-Rm 120	<1.00	15.5	No
79	SRE/MS-1FL-DW-Rm 121	3.27	15.5	No
80	SRE/MS-1FL-DW-Rm 123	2.15	15.5	No
81	SRE/MS-1FL-DW-Rm 122	9.14	15.5	No
82	SRE/MS-1FL-DW-Rm 125	3.62	15.5	No
83	SRE/MS-1FL-WC-Hall o/s Rm 125-1	<1.00	15.5	No
84	Field Blank	<1.00	15.5	No



Table 3: High School

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
85	SRHS--- Field Blank	<1.00	15.5	No
86	SRHS-1FL-POE-Main(140)	<1.00	15.5	No
87	SRHS-1FL-WC-Hall o/s Rm 141	<1.00	15.5	No
88	SRHS-1FL-WC-Hall o/s Rm 213-1	<1.00	15.5	No
89	SRHS-1FL-FS-Teachers Lounge	2.89	15.5	No
90	SRHS-1FL-FP-Main Office Kitchen	3.25	15.5	No
91	SRHS-1FL-NS-Nurse Office	<1.00	15.5	No
92	SRHS-1FL-WC-Hall o/s Auditorium	<1.00	15.5	No
93	SRHS-1FL-WC-Hall o/s Cust. Office	<1.00	15.5	No
94	SRHS-1FL-WC-Cafeteria	<1.00	15.5	No
95	SRHS-1FL-FP-Kitchen-1	17.2	15.5	Yes
96	SRHS-1FL-FP-Kitchen-2	2.85	15.5	No
97	SRHS-1FL-FP-Kitchen-3	36	15.5	No
98	SRHS-1FL-FP-Life Skills Rm 110-1	2.57	15.5	No
99	SRHS-1FL-FP-Life Skills Rm 110-2	2.26	15.5	No
100	SRHS-1FL-FP-Life Skills Rm 110-3	1.69	15.5	No
101	SRHS-1FL-DW-Girls Locker	<1.00	15.5	No
102	SRHS-1FL-DW-Hall o/s Gym	<1.00	15.5	No
103	SRHS-1FL-HB-Trainers Rm	1.8	15.5	No
104	SRHS-1FL-DW-Boys Locker	<1.00	15.5	No
105	SRHS-1FL-IM-Trainers Rm	<1.00	15.5	No
106	SRCS-1FL-S-Conc	3190	15.5	Yes
107	SRCS-1FL-IM-Conc	956	15.5	Yes



In instances where the first draw exceeded the action level, the corresponding flush draw sample was activated for analysis. Tables 4-6 compare the results of the flush sample to its corresponding first draw sample and also compares the FLUSH samples against the lead action limit. Those samples that exceeded the lead action limit are yellow highlighted in these tables.

Table 4: Primary School

Location Code		First Draw Result (ppb)	Flush Draw Result (ppb)	Action Limit (ppb)
5	SRPS-1FL-DW-Nurse	22.9	23.4	15.5

Table 5: Elementary/Middle School

Location Code		First Draw Result (ppb)	Flush Draw Result (ppb)	Action Limit (ppb)
48	SRE/MS-2FL-FP-Kitchen-4	48.7	8.98	15.5

Table 6: High School

Location Code		First Draw Result (ppb)	Flush Draw Result (ppb)	Action Limit (ppb)
95	SRHS-1FL-FP-Kitchen-1	17.2	<1.00	15.5
106	SRCS-1FL-S-Conc	3190	2.95	15.5

-END OF SECTION-



3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

One hundred and four (104) first draw and flush draw samples were collected, along with three field blanks for quality control purposes. All first draw samples were analyzed. Flush samples were held by the lab pending first draw results and then activated for locations with first draw exceedances.

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

-END OF SECTION-

4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Based on laboratory analysis of the samples analyzed, five (5) first draw samples exceeded the action limit. One corresponding flush draw sample also exceeded the action limit with the remaining analyzed flush samples falling below the action limit.

Immediate / Short Term Action Required:

1. Immediately discontinue using water at locations where the first draw sample exceeded the NJDEP 15.5 ppb Action Level. If this location is going to be remediated for future use it will need to be re-tested prior to being put in service to make sure the remedial work was successful.
2. Refer to EPA's "**for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location and are reflective of the conditions at that time of collection.

It is important to note that the Lead Hazard Assessment was a snap shot of the conditions existing at the time of the assessment and conditions may vary with time.

-END OF SECTION-



5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', followed by a horizontal line.

Noel Abraham
Environmental Specialist

-END OF REPORT-

APPENDIX I

LEAD IN DRINKING WATER SAMPLING CHAINS-OF-CUSTODY & LAB REPORTS



Results Report

Order ID: 2D04116

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD-Primary
22 David St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04116-01		Site: SRPS--- Field Blank		Sample ID: Field Blank					
Collector: NPA		Collect Date: 04/12/2022 12:45 pm		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 RMB 04/25/22 10:00 MKR

Sample Number: 2D04116-02		Site: SRPS-GF-S-Main Office Bathroom		Sample ID: Main Office Bathroom					
Collector: NPA		Collect Date: 04/12/2022 12:46 pm		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 RMB 04/25/22 11:40 MKR

Sample Number: 2D04116-03		Site: SRPS-GF-WC-Hall o/s Main Office		Sample ID: Hall o/s Main Office					
Collector: NPA		Collect Date: 04/12/2022 12:47 pm		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/27/22 JNM 04/27/22 14:02 MKS

Sample Number: 2D04116-04		Site: SRPS-1FL-WC- Hall o/s 104		Sample ID: Hall o/s 104					
Collector: NPA		Collect Date: 04/12/2022 12:48 pm		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 RMB 04/25/22 12:40 MKR

Sample Number: 2D04116-05		Site: SRPS-1FL-DW-Nurse		Sample ID: Nurse (Rm 111)					
Collector: NPA		Collect Date: 04/12/2022 12:49 pm		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead 22.9 µg/L EPA 200.8 1.00 1 04/25/22 RMB 04/25/22 13:21 MKR

Report Generated On: 05/09/2022 9:18 am
STL_Results Revision #2.0

2D04116
Effective: 04/20/2022



SUBURBAN TESTING LABS

Sample Number: 2D04116-06	Site: SRPS-1FL-WC-Hall o/s Rm 115	Sample ID: Hall o/s Rm 115
Collector: NPA	Collect Date: 04/12/2022 12:50 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 13:00	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-07	Site: SRPS-1FL-WC-Hall o/s Cafe-1	Sample ID: Hall o/s Cafe-1
Collector: NPA	Collect Date: 04/12/2022 12:51 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 11:12	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-08	Site: SRPS-1FL-WC-Hall o/s Cafe-2	Sample ID: Hall o/s Cafe-2
Collector: NPA	Collect Date: 04/12/2022 12:52 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 11:14	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-09	Site: SRPS-1FL-WC-Cafe-1	Sample ID: Cafe-1
Collector: NPA	Collect Date: 04/12/2022 12:53 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:26	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-10	Site: SRPS-1FL-WC-Cafe-2	Sample ID: Cafe-2
Collector: NPA	Collect Date: 04/12/2022 12:54 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 12:52	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-11	Site: SRPS-1FL-FP-Kitchen	Sample ID: Kitchen
Collector: NPA	Collect Date: 04/12/2022 12:55 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.75	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 13:11	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/09/2022 9:18 am 2D04116
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04116-12	Site: SRPS-2FL-WC-Media Center-2	Sample ID: Media Center-2
Collector: NPA	Collect Date: 04/12/2022 12:56 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 13:13	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-13	Site: SRPS-2FL-WC-Hall o/s 209	Sample ID: Hall o/s 209
Collector: NPA	Collect Date: 04/12/2022 12:57 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 12:48	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-14	Site: SRPS-2FL-WC-Hall o/s Media Ctr-1	Sample ID: Hall o/s Media Ctr-1
Collector: NPA	Collect Date: 04/12/2022 12:58 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 12:56	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04116-15	Site: SRPS-2FL-WC-Hall o/s Media Ctr-2	Sample ID: Hall o/s Media Ctr-2
Collector: NPA	Collect Date: 04/12/2022 12:59 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 10:31	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent

Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Report Generated On: 05/09/2022 9:18 am

STL_Results Revision #2.0

2D04116

Effective: 04/20/2022






SUBURBAN
TESTING LABS

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/09/2022 9:18 am 2D04116
STL_Results Revision #2.0 Effective: 04/20/2022





COC Pg 1

2D04116
Lisa F. Care

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.comTAT (Check One) Standard 24HR 48HR 72HR Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	Sout River Primary School
	West Chester, PA 19380				22 David St., South River, NJ 08882
Contact Name:	Noel Abraham	Email:	nabraham@westchesterenviromental.com	Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
	Field Blank	04/12/22	12:45 PM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRPS---Field Blank
Flush	Main Office Bathroom	04/12/22	12:46 PM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRPS-GF-S-Main Office Bathroom
First	Hall o/s Main Office	04/12/22	12:47 PM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	SRPS-GF-WC-Hall o/s Main Office
First	Hall o/s 104	04/12/22	12:48 PM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s 104
First	Nurse(Rm 111)	04/12/22	12:49 PM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-DW-Nurse
First	Hall o/s Rm 115	04/12/22	12:50 PM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Rm 115
First	Hall o/s Cafe-1	04/12/22	12:51 PM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Cafe-1
First	Hall o/s Cafe-2	04/12/22	12:52 PM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Cafe-2
First	Cafe-1	04/12/22	12:53 PM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Cafe-1
First	Cafe-2	04/12/22	12:54 PM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Cafe-2

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: 2:11

Time: 4/13/22

Date: 4/14/22 Temp °C: 22.6

Time: 1830 Acceptable Y / N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y / N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <u>Y/N</u>	NPW = Non-Potable Water	P = Plastic	SWDA Reporting
Submitted as container match <u>Y/N</u>	Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l)	G = Glass	Fax
Submitted as container match <u>Y/N</u>	PW = Potable Water (not for SWDA compliance)	O = Other	Email
All containers intact <u>Y/N</u>	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
Tests within holding times <u>Y/N</u>	Sample Type Key	H = Sodium Thiosulfate	
40 ml. WDA vials free of headspace? <u>Y/N</u>	SWDA Sample Type	A = Ascorbic Acid	
	G = Grab	H = HNO3	
	D = Distribution	S =	
	E = Entry Point	H2SO4	
	R = Raw	O = Other	
	C = Check		
	S = Special		
	M = Maximum Residence		

(10) 250 mL P HNO3



2D04116
Lisa F. Care

COC Pg 2

SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com		TAT (Check One) Standard 24hr 48hr 72hr Other	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane			Address:	Sout River Primary School
	West Chester, PA 19380				22 David St., South River, NJ 08882
Contact Name:	Noel Abraham			Email:	nabraham@westchesterenviromental.com
Comments:				Payment / P.O. Info:	

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Kitchen	04/12/22	12:55 PM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-FP-Kitchen
First	Media Center-2	04/12/22	12:56 PM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Media Center-2
First	Hall o/s 209	04/12/22	12:57 PM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s 209
First	Hall o/s Media Ctr-1	04/12/22	12:58 PM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s Media Ctr-1
First	Hall o/s Media Ctr-2	04/12/22	12:59 PM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s Media Ctr-2

Relinquished by:

Date: 2/11

Time: 4/13/22

Received By:

2000w 160g

Date: 4/14/22 Temp °C: 22.0

Time: 1030 Acceptable: Y/N

Relinquished by:

2000w 110g

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable: Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable: Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Substrate w/ COC	NPW = Non-Potable Water	P = Plastic	SWDA
	Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l)	G = Glass	Residual
	PW = Potable Water (not for SWDA compliance)	On Other	Fee
	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	Email
		H = Sodium	
All containers intact	Sample Type Key	Thiosulphate	A = Ascorbic
	D = Distillation	AsC	H = HNO3
	G = Grab	G = HCl	S =
	E = Enrichment	H2SO4	OH = NaOH
	C = Check	G = Other	HA =
	S = Special	None	
	M = Maximum	Required	
	Residence		

(S) 250 mL P HNO3



Results Report

Order ID: 2D04106

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD Elem/Middle
3 Montgomery St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04106-01
Collector: NPA

Site: SRE/MS-2FL-POE-2nd Floor
Collect Date: 04/12/2022 10:40 am

Sample ID: 2nd Floor
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/26/22 YBZ 04/26/22 8:33 MKR

Sample Number: 2D04106-02
Collector: NPA

Site: SRE/MS-2FL-DW-Music
Collect Date: 04/12/2022 10:41 am

Sample ID: Music
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.71 µg/L EPA 200.8 1.00 1 04/25/22 YBZ 04/25/22 14:12 RPV

Sample Number: 2D04106-03
Collector: NPA

Site: SRE/MS-2FL-WC-Hall o/s Rm 212-1
Collect Date: 04/12/2022 10:42 am

Sample ID: Hall o/s Rm 212-1
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/26/22 YBZ 04/26/22 11:40 MKR

Sample Number: 2D04106-04
Collector: NPA

Site: SRE/MS-2FL-DW-Rm 215
Collect Date: 04/12/2022 10:43 am

Sample ID: Rm 215
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 YBZ 04/25/22 10:35 MKR

Sample Number: 2D04106-05
Collector: NPA

Site: SRE/MS-2FL-DW-Rm 214
Collect Date: 04/12/2022 10:44 am

Sample ID: Rm 214
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 YBZ 04/25/22 13:23 MKR

Report Generated On: 05/04/2022 6:25 pm
STL_Results Revision #2.0

2D04106
Effective: 04/20/2022



SUBURBAN TESTING LABS

Sample Number: 2D04106-06	Site: SRE/MS-2FL-DW-Rm 216	Sample ID: Rm 216
Collector: NPA	Collect Date: 04/12/2022 10:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.03	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:57	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-07	Site: SRE/MS-2FL-DW-Rm 217	Sample ID: Rm 217
Collector: NPA	Collect Date: 04/12/2022 10:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.22	µg/L	EPA 200.8	1.00	1	04/29/22	RPV	04/29/22 8:44	MKS
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 2D04106-08	Site: SRE/MS-2FL-DW-Rm 219	Sample ID: Rm 219
Collector: NPA	Collect Date: 04/12/2022 10:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.92	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:17	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-09	Site: SRE/MS-2FL-DW-Rm 221	Sample ID: Rm 221
Collector: NPA	Collect Date: 04/12/2022 10:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:38	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-10	Site: SRE/MS-2FL-WC- Hallway side Rm 220	Sample ID: Hallway side Rm 220-1
Collector: NPA	Collect Date: 04/12/2022 10:49 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:26	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-11	Site: SRE/MS-2FL-WC- Hall o/s Rm 210-1	Sample ID: Hall o/s Rm 210-1
Collector: NPA	Collect Date: 04/12/2022 10:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:28	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-12	Site: SRE/MS-2FL-DW- Rm 209	Sample ID: Rm 209
Collector: NPA	Collect Date: 04/12/2022 10:51 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.04	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:58	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-13	Site: SRE/MS-2FL-DW- Rm 208	Sample ID: Rm 208
Collector: NPA	Collect Date: 04/12/2022 10:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	RPV	04/26/22 15:54	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-14	Site: SRE/MS-2FL-DW- Rm 207	Sample ID: Rm 207
Collector: NPA	Collect Date: 04/12/2022 10:53 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:19	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-15	Site: SRE/MS-2FL-DW- Rm 206	Sample ID: Rm 206
Collector: NPA	Collect Date: 04/12/2022 10:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:36	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-16	Site: SRE/MS-2FL-DW- Rm 205	Sample ID: Rm 205
Collector: NPA	Collect Date: 04/12/2022 10:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.09	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:30	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-17	Site: SRE/MS-2FL-DW- Rm 204	Sample ID: Rm 204
Collector: NPA	Collect Date: 04/12/2022 10:56 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:36	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-18	Site: SRE/MS-2FL-DW- Rm 202	Sample ID: Rm 202
Collector: NPA	Collect Date: 04/12/2022 10:57 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.22	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:40	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-19	Site: SRE/MS-2FL-DW- Rm 203	Sample ID: Rm 203
Collector: NPA	Collect Date: 04/12/2022 10:58 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:20	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-20	Site: SRE/MS-2FL-FS- Faculty Loungs	Sample ID: Faculty Loungs
Collector: NPA	Collect Date: 04/12/2022 10:59 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:29	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-21	Site: SRE/MS-2FL-NS-Nurse Office-1	Sample ID: Nurse Office-1
Collector: NPA	Collect Date: 04/12/2022 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.87	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:26	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-22	Site: SRE/MS-2FL-NS-Nurse Office-2	Sample ID: Nurse Office-2
Collector: NPA	Collect Date: 04/12/2022 11:01 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 10:51	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-23	Site: SRE/MS-2FL-WC-Hall o/s Faculty-1	Sample ID: Hall o/s Faculty-1
Collector: NPA	Collect Date: 04/12/2022 11:02 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:00	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-24	Site: SRE/MS-2FL-WC-O/S Stage-1	Sample ID: O/S Stage-1
Collector: NPA	Collect Date: 04/12/2022 11:03 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:02	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-25	Site: SRE/MS-2FL-WC-Hall o/s 224-1	Sample ID: Hall o/s 224-1
Collector: NPA	Collect Date: 04/12/2022 11:04 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:39	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-26	Site: SRE/MS-2FL-WC-Cafe-1	Sample ID: Cafe-1
Collector: NPA	Collect Date: 04/12/2022 11:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:43	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-27	Site: SRE/MS-2FL-WC-Cafe-2	Sample ID: Cafe-2
Collector: NPA	Collect Date: 04/12/2022 11:06 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:19	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-28	Site: SRE/MS-2FL-S-Cafe Faculty	Sample ID: Cafe Faculty
Collector: NPA	Collect Date: 04/12/2022 11:07 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:11	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-29	Site: SRE/MS-2FL-FP-Kitchen-1	Sample ID: Kitchen-1
Collector: NPA	Collect Date: 04/12/2022 11:08 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:03	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-30	Site: SRE/MS-2FL-FP-Kitchen-2	Sample ID: Kitchen-2
Collector: NPA	Collect Date: 04/12/2022 11:09 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.76	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:42	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-31	Site: SRE/MS-2FL-FP-Kitchen-3	Sample ID: Kitchen-3
Collector: NPA	Collect Date: 04/12/2022 11:10 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.56	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:22	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-32	Site: SRE/MS-2FL-FP-Kitchen-4	Sample ID: Kitchen-4
Collector: NPA	Collect Date: 04/12/2022 11:11 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	48.7	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:23	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-33	Site: SRE/MS-3FL-WC-Hall o/s 302-1	Sample ID: Hall o/s 302-1
Collector: NPA	Collect Date: 04/12/2022 11:12 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:31	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-34	Site: SRE/MS-3FL-S-Mid Main Office-1	Sample ID: Mid Main Office-1
Collector: NPA	Collect Date: 04/12/2022 11:13 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:23	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-35	Site: SRE/MS-3FL-FS-Mid Teachers Lounge	Sample ID: Mid Teachers Lounge
Collector: NPA	Collect Date: 04/12/2022 11:14 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:44	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-36	Site: SRE/MS-3FL-NS-Nurse-1	Sample ID: Nurse-1
Collector: NPA	Collect Date: 04/12/2022 11:15 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:05	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-37	Site: SRE/MS-3FL-NS-Nurse-2	Sample ID: Nurse-2
Collector: NPA	Collect Date: 04/12/2022 11:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.56	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:25	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-38	Site: SRE/MS-3FL-WC-O/S Nurse-1	Sample ID: O/S Nurse-1
Collector: NPA	Collect Date: 04/12/2022 11:17 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:20	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-39	Site: SRE/MS-3FL-DW-Rm 320	Sample ID: Rm 320
Collector: NPA	Collect Date: 04/12/2022 11:18 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:41	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-40	Site: SRE/MS-3FL-DW-Rm 318	Sample ID: Rm 318
Collector: NPA	Collect Date: 04/12/2022 11:19 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	6.43	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:26	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-41	Site: SRE/MS-3FL-S-Rm 319-1	Sample ID: Rm 319-1
Collector: NPA	Collect Date: 04/12/2022 11:20 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.05	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:46	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-42	Site: SRE/MS-3FL-S-Rm 319-2	Sample ID: Rm 319-2
Collector: NPA	Collect Date: 04/12/2022 11:21 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:48	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-43	Site: SRE/MS-3FL-DW-Rm 317	Sample ID: Rm 317
Collector: NPA	Collect Date: 04/12/2022 11:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.63	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:34	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-44	Site: SRE/MS-3FL-DW-Rm 316	Sample ID: Rm 316
Collector: NPA	Collect Date: 04/12/2022 11:23 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.33	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:31	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-45	Site: SRE/MS-3FL-DW-Rm 313	Sample ID: Rm 313
Collector: NPA	Collect Date: 04/12/2022 11:24 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.26	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 14:46	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-46	Site: SRE/MS-3FL-WC-Hall o/s Elevator-1	Sample ID: Hall o/s Elevator-1
Collector: NPA	Collect Date: 04/12/2022 11:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:33	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-47	Site: SRE/MS-1FL-DW-Rm 105	Sample ID: Rm 105
Collector: NPA	Collect Date: 04/12/2022 11:26 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.78	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:09	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-48	Site: SRE/MS-1FL-DW-Rm 104	Sample ID: Rm 104
Collector: NPA	Collect Date: 04/12/2022 11:27 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RPV	04/25/22 15:11	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-49	Site: SRE/MS-1FL-DW-Rm 106	Sample ID: Rm 106
Collector: NPA	Collect Date: 04/12/2022 11:28 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.80	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:54	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-50	Site: SRE/MS-1FL-DW-Rm 109	Sample ID: Rm 109
Collector: NPA	Collect Date: 04/12/2022 11:29 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.22	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:56	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-51	Site: SRE/MS-1FL-DW-Rm 110	Sample ID: Rm 110
Collector: NPA	Collect Date: 04/12/2022 11:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.87	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:42	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-52	Site: SRE/MS-1FL-DW-Rm 111	Sample ID: Rm 111
Collector: NPA	Collect Date: 04/12/2022 11:31 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:01	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-53	Site: SRE/MS-1FL-DW-Rm 113	Sample ID: Rm 113
Collector: NPA	Collect Date: 04/12/2022 11:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.05	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:38	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-54	Site: SRE/MS-1FL-DW-Rm 114	Sample ID: Rm 114
Collector: NPA	Collect Date: 04/12/2022 11:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.51	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:04	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-55	Site: SRE/MS-1FL-WC-Hall o/s Rm 114-1	Sample ID: Hall o/s 114-1
Collector: NPA	Collect Date: 04/12/2022 11:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:03	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-56	Site: SRE/MS-1FL-WC-Aux Gym A	Sample ID: Aux Gym A
Collector: NPA	Collect Date: 04/12/2022 11:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:05	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-57	Site: SRE/MS-1FL-WC-Hall o/s Girls LR-1	Sample ID: Hall o/s Girls LR-1
Collector: NPA	Collect Date: 04/12/2022 11:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:07	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-58	Site: SRE/MS-1FL-WC-Hall o/s 100B-1	Sample ID: Hall o/s 100B-1
Collector: NPA	Collect Date: 04/12/2022 11:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 14:09	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-59	Site: SRE/MS-1FL-DW-Rm 117	Sample ID: Rm 117
Collector: NPA	Collect Date: 04/12/2022 11:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	8.90	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:07	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-60	Site: SRE/MS-1FL-DW-Rm 119	Sample ID: Rm 119
Collector: NPA	Collect Date: 04/12/2022 11:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:09	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-61	Site: SRE/MS-1FL-DW-Rm 118	Sample ID: Rm 118
Collector: NPA	Collect Date: 04/12/2022 11:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.25	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:56	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-62	Site: SRE/MS-1FL-DW-Rm 120	Sample ID: Rm 120
Collector: NPA	Collect Date: 04/12/2022 11:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 11:59	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-63	Site: SRE/MS-1FL-DW-Rm 121	Sample ID: Rm 121
Collector: NPA	Collect Date: 04/12/2022 11:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.27	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:18	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-64	Site: SRE/MS-1FL-DW-Rm 123	Sample ID: Rm 123
Collector: NPA	Collect Date: 04/12/2022 11:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.15	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:53	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04106-65	Site: SRE/MS-1FL-DW-Rm 122	Sample ID: Rm 122
Collector: NPA	Collect Date: 04/12/2022 11:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.14	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:20	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2D04106-66	Site: SRE/MS-1FL-DW-Rm 125	Sample ID: Rm 125
Collector: NPA	Collect Date: 04/12/2022 11:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	3.62	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:22	MKR

Sample Number: 2D04106-67	Site: SRE/MS-1FL-WC-Hall o/s Rm 125-1	Sample ID: Rm 125-1
Collector: NPA	Collect Date: 04/12/2022 11:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/26/22	YBZ	04/26/22 12:24	MKR

Sample Number: 2D04106-68	Site: Field Blank	Sample ID: Field Blank
Collector: NPA	Collect Date: 04/12/2022 11:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 13:51	MKR

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/04/2022 6:25 pm 2D04106
STL_Results Revision #2.0 Effective: 04/20/2022





2D04106
Lisa F. Care

COC Pg 1

SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST – Fax: 610-375-4090 – suburbantestinglabs.com		TAT (Check One) <u>Standard</u> 24hr 48hr 72hr Other	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-2FL-POE-2nd Floor	04/12/22	10:40 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	2nd Floor
First	SRE/MS-2FL-DW-Music	04/12/22	10:41 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Music
First	SRE/MS-2FL-WC-Hall o/s Rm	04/12/22	10:42 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 212-1
First	SRE/MS-2FL-DW-Rm 215	04/12/22	10:43 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Rm 215
First	SRE/MS-2FL-DW-Rm 214	04/12/22	10:44 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Rm 214
First	SRE/MS-2FL-DW-Rm 216	04/12/22	10:45 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Rm 216
First	SRE/MS-2FL-DW-Rm 217	04/12/22	10:46 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Rm 217
First	SRE/MS-2FL-DW-Rm 219	04/12/22	10:47 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Rm 219
First	SRE/MS-2FL-DW-Rm 221	04/12/22	10:48 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Rm 221
First	SRE/MS-2FL-WC-Hallway side	04/12/22	10:49 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Hallway side Rm 220-1

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date:

4/13/22

Time:

17:20

Date:

4/14/22

Time:

1030

Date:

4/14/22

Time:

1550

Date:

4/14/22

Time:

1550

Temp °C:

22.6

Temp °C:

24.1

Acceptable

Y/N

Acceptable

Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non Potable Water	P = Plastic
Maximum no containers match number on COC <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Distillates, Sludge sol. etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding time <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act	Preservative Key
40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Possible Sample	H = Sodium Thiosulfate
	Sample Type Key	Ascorbic Acid
	G = Grab	C = HCl
	8 HC = 8 Hour Composite	H ₂ SO ₄
	E = Entry Point	D = Other
	R = Raw	None Required
	C = Check	
	S = Special	
	M = Maximum Residence	

(10)250 mL P HNO₃



COC Pg 2

2D04106
Lisa F. Care**SUBURBAN
TESTING LABS****TESTING LABS****Chain of Custody Record**1037F MacArthur Road, Reading, PA 19605
610-375-TEST -- Fax: 610-375-4090 -- suburbantestinglabs.com

TAT (Check One)



24hr

48hr

72hr

Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-2FL-WC-Hall o/s R	04/12/22	10:50 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 210-1
First	SRE/MS-2FL-DW-Rm 209	04/12/22	10:51 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	Rm 209
First	SRE/MS-2FL-DW-Rm 208	04/12/22	10:52 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	Rm 208
First	SRE/MS-2FL-DW-Rm 207	04/12/22	10:53 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	Rm 207
First	SRE/MS-2FL-DW-Rm 206	04/12/22	10:54 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	Rm 206
First	SRE/MS-2FL-DW-Rm 205	04/12/22	10:55 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	Rm 205
First	SRE/MS-2FL-DW-Rm 204	04/12/22	10:56 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	Rm 204
First	SRE/MS-2FL-DW-Rm 202	04/12/22	10:57 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	Rm 202
First	SRE/MS-2FL-DW-Rm 203	04/12/22	10:58 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	Rm 203
First	SRE/MS-2FL-FS-Faculty Lo	04/12/22	10:59 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	Faculty Loungs

Relinquished by:

Date: 4/13/23

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6°C

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1530 Acceptable Y/N


Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1850 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Residuals in containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Solid = Raw Sludge, Sewerage, Sludge, etc. (reported as mg/L)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	Q = Other
Taste when holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SWDA = Safe Drinking Water Act	Preservative Key
40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Potable Sample	H = Sodium
	Sample Type Key	Thiosulfate A = Ascorbic
	G = Grab	Acid H = HNO ₃
	D = Distribution	C = HCl
	E = Empty Point	H ₂ SO ₄ S =
	R = Raw	Q = Other
	C = Check	OH = NaOH
	S = Special	None
	M = Maximum	Required
	Residence	

(10) 250 mL P HNO₃



COC Pg 3

2D04108
Lisa F. Care

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.comTAT (Check One) ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-2FL-NS-Nurse Off	04/12/22	11:00 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	Nurse Office-1
First	SRE/MS-2FL-NS-Nurse Off	04/12/22	11:01 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	Nurse Office-2
First	SRE/MS-2FL-WC-Hall o/s F	04/12/22	11:02 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Faculty-1
First	SRE/MS-2FL-WC-O/S Stag	04/12/22	11:03 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	O/S Stage-1
First	SRE/MS-2FL-WC-Hall o/s 2	04/12/22	11:04 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 224-1
First	SRE/MS-2FL-WC-Cafe-1	04/12/22	11:05 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	Cafe-1
First	SRE/MS-2FL-WC-Cafe-2	04/12/22	11:06 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	Cafe-2
First	SRE/MS-2FL-S-Cafe Facult	04/12/22	11:07 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	Cafe Faculty
First	SRE/MS-2FL-FP-Kitchen-1	04/12/22	11:08 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	Kitchen-1
First	SRE/MS-2FL-FP-Kitchen-2	04/12/22	11:09 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	Kitchen-2

Relinquished by:

Date: 4/13/22

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="radio"/> Y <input type="radio"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC <input checked="" type="radio"/> Y <input type="radio"/> N	Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="radio"/> Y <input type="radio"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="radio"/> Y <input type="radio"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml VOA vials free of headspace? <input checked="" type="radio"/> Y <input type="radio"/> N	Sample Type Key (SWDA Sample Type)	H = Sodium Hydroxide
	G = Grab	A = Ascorbic Acid
	6 HC = 6 Hour Composite	H = HNO ₃
	R = Raw	C = HCl
	OC = Onsite	H ₂ SO ₄
	SB = Special	U = Urine
	M = Maximum	None Required
	Residence	

(10) 250 ml P HNO₃



2D04106
Lisa F. Care

COC Pg 4

SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST – Fax: 610-375-4090 – suburbantestinglabs.com		TAT (Check One) <u>Standard</u> 24hr 48hr 72hr Other	
Client Name: Westchester Environmental LLC.		Project Name: South River SD			
Address: 1248 Wrights Lane		Phone: 610-431-7545		Address: Elementary/Middle	
Contact Name: Noel Abraham		Email: nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882	
		Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-2FL-FP-Kitchen-3	04/12/22	11:10 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	Kitchen-3
First	SRE/MS-2FL-FP-Kitchen-4	04/12/22	11:11 AM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	Kitchen-4
First	SRE/MS-3FL-WC-Hall o/s	04/12/22	11:12 AM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 302-1
First	SRE/MS-3FL-S-Mid Main C	04/12/22	11:13 AM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	Mid Main Office-1
First	SRE/MS-3FL-FS-Mid Teac	04/12/22	11:14 AM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	Mid Teachers Lounge
First	SRE/MS-3FL-NS-Nurse-1	04/12/22	11:15 AM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	Nurse-1
First	SRE/MS-3FL-NS-Nurse-2	04/12/22	11:16 AM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	Nurse-2
First	SRE/MS-3FL-WC-O/S Nur	04/12/22	11:17 AM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	O/S Nurse-1
First	SRE/MS-3FL-DW-Rm 320	04/12/22	11:18 AM	NPA	039	Pb EPA 200.8	1	PW	G	P	H	Rm 320
First	SRE/MS-3FL-DW-Rm 318	04/12/22	11:19 AM	NPA	040	Pb EPA 200.8	1	PW	G	P	H	Rm 318

Relinquished by:

Date: 4/13/22

Time: 12:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <u>Y/N</u>	NPW = Non-Potable Water	P = Plastic
Integrity for containers match <u>Y/N</u>	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mgt)	G = Glass
All containers intact <u>Y/N</u>	PW = Potable Water (not for SWDA compliance)	D = Other
Tests within holding time <u>Y/N</u>	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	H = Sodium Thiosulfate
	G = Grab	A = Ascorbic Acid
	B HC = 8 Hour Composite	H = HNO3
	E = Entry Point	C = HCl
	R = Raw	H2SO4
	C = Check	O = Other
	S = Special	None Required
	M = Maximum Residence	

(10) 250 mL P HNO3



2D04106
Lisa F. Care

COC Pg 5



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-3FL-S-Rm 319-1	04/12/22	11:20 AM	NPA	041	Pb EPA 200.8	1	PW	G	P	H	Rm 319-1
First	SRE/MS-3FL-S-Rm 319-2	04/12/22	11:21 AM	NPA	042	Pb EPA 200.8	1	PW	G	P	H	Rm 319-2
First	SRE/MS-3FL-DW-Rm 317	04/12/22	11:22 AM	NPA	043	Pb EPA 200.8	1	PW	G	P	H	Rm 317
First	SRE/MS-3FL-DW-Rm 316	04/12/22	11:23 AM	NPA	044	Pb EPA 200.8	1	PW	G	P	H	Rm 316
First	SRE/MS-3FL-DW-Rm 313	04/12/22	11:24 AM	NPA	045	Pb EPA 200.8	1	PW	G	P	H	Rm 313
First	SRE/MS-3FL-WC-Hall o/s E	04/12/22	11:25 AM	NPA	046	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Elevator-1
First	SRE/MS-1FL-DW-Rm 105	04/12/22	11:26 AM	NPA	047	Pb EPA 200.8	1	PW	G	P	H	Rm 105
First	SRE/MS-1FL-DW-Rm 104	04/12/22	11:27 AM	NPA	048	Pb EPA 200.8	1	PW	G	P	H	Rm 104
First	SRE/MS-1FL-DW-Rm 106	04/12/22	11:28 AM	NPA	049	Pb EPA 200.8	1	PW	G	P	H	Rm 106
First	SRE/MS-1FL-DW-Rm 109	04/12/22	11:29 AM	NPA	050	Pb EPA 200.8	1	PW	G	P	H	Rm 109

Relinquished by:

Date: 4/13/22

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ CDC <u>Y/N</u>	NFW = Non Potable Water	P = Plastic	SWDA Reporting <u>PW SD</u>
Received in containers marked number per CDC <u>Y/N</u>	Sludge = Raw Sludge, Sewerage Sludge, etc. (reported as mg/L)	G = Glass	Fax
All containers intact <u>Y/N</u>	PW = Potable Water (not for SWDA compliance)	On Other	Email
Tests within holding times <u>Y/N</u>	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	Other
40 mL VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	H = Sodium	Return a copy of this form with Report
	G = Grab	Thiosulfate	
	24 HC = 24 Hour Composite	AsH	
	24 HC = 24 Hour Composite	A = Ascorbic	
		H = HNO3	
		G = HCl	
		H2SO4	
		Q = Other	
		None Required	

(10) 250 mL P HNO3



2D04106
Lisa F. Care

COC Pg 6



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One)

☒ Standard

☐ 24hr

☐ 40hr

☐ 12hr

☐ Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-1FL-DW-Rm 110	04/12/22	11:30 AM	NPA	051	Pb EPA 200.8	1	PW	G	P	H	Rm 110
First	SRE/MS-1FL-DW-Rm 111	04/12/22	11:31 AM	NPA	052	Pb EPA 200.8	1	PW	G	P	H	Rm 111
First	SRE/MS-1FL-DW-Rm 113	04/12/22	11:32 AM	NPA	053	Pb EPA 200.8	1	PW	G	P	H	Rm 113
First	SRE/MS-1FL-DW-Rm 114	04/12/22	11:33 AM	NPA	054	Pb EPA 200.8	1	PW	G	P	H	Rm 114
First	SRE/MS-1FL-WC-Hall o/s	04/12/22	11:34 AM	NPA	055	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 114-1
First	SRE/MS-1FL-WC-Aux Gym	04/12/22	11:35 AM	NPA	056	Pb EPA 200.8	1	PW	G	P	H	Aux Gym A
First	SRE/MS-1FL-WC-Hall o/s	04/12/22	11:36 AM	NPA	057	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Girl's LR-1
First	SRE/MS-1FL-WC-Hall o/s	04/12/22	11:37 AM	NPA	058	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 100B-1
First	SRE/MS-1FL-DW-Rm 117	04/12/22	11:38 AM	NPA	059	Pb EPA 200.8	1	PW	G	P	H	Rm 117
First	SRE/MS-1FL-DW-Rm 119	04/12/22	11:39 AM	NPA	060	Pb EPA 200.8	1	PW	G	P	H	Rm 119

Relinquished by:

Date: 4/13/22
Time: 17:00

Received By:

2006/11/10/22

Date: 4/14/22 Temp °C: 22.6
Time: 1030 Acceptable Y/N

Relinquished by:

2006/11/14/22

Date: 4/14/22 Temp °C: 24.1
Time: 1530 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1
Time: 1530 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Material in containers match number on COC? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	Q = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Sample Type Key	H = Sodium Hydroxide
	D = Distribution	A = Ascorbic Acid
	E = Entry Point	H = HNO3
	R = Raw	S = Sulfuric Acid
	C = Check	H2SO4 = NaOH
	S = Special	Q = Other
	M = Maximum Residence	



COC Pg 7

2D04108
Lisa F. Care

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.comTAT (Check One) ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	SRE/MS-1FL-DW-Rm 118	04/12/22	11:40 AM	NPA	61	Pb EPA 200.8	1	PW	G	P	H	Rm 118
First	SRE/MS-1FL-DW-Rm 120	04/12/22	11:41 AM	NPA	62	Pb EPA 200.8	1	PW	G	P	H	Rm 120
First	SRE/MS-1FL-DW-Rm 121	04/12/22	11:42 AM	NPA	63	Pb EPA 200.8	1	PW	G	P	H	Rm 121
First	SRE/MS-1FL-DW-Rm 123	04/12/22	11:43 AM	NPA	64	Pb EPA 200.8	1	PW	G	P	H	Rm 123
First	SRE/MS-1FL-DW-Rm 122	04/12/22	11:44 AM	NPA	65	Pb EPA 200.8	1	PW	G	P	H	Rm 122
First	SRE/MS-1FL-DW-Rm 125	04/12/22	11:45 AM	NPA	66	Pb EPA 200.8	1	PW	G	P	H	Rm 125
First	SRE/MS-1FL-WC-Hall o/s Rm 125	04/12/22	11:46 AM	NPA	67	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 125-1
First	Field Blank	04/12/22	11:47 AM	NPA	68	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by:

Date: 4/13/22

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable ☒ N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable ☒ N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable ☒ N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="radio"/> Y <input type="radio"/> N	NFW = Non-Potable Water	P = Plastic
Residue in container match number on min 2 <input checked="" type="radio"/> Y <input type="radio"/> N	SWS = Raw Sludge, Distilled Sludge, etc. (report as high)	G = Glass
All containers intact <input checked="" type="radio"/> Y <input type="radio"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="radio"/> Y <input type="radio"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 mL VOA vials free of headspace? <input checked="" type="radio"/> Y <input type="radio"/> N	Sample Type Key	H = Sodium Thiosulfate
	G = Grab	A = Ascorbic Acid
	D = Distribution	H = HNO ₃
	E = Entry Point	C = HCl
	R = Raw	H ₂ SO ₄
	C = Check	OH = NaOH
	S = Spacer	NA = None Required
	M = Maximum Residence	

(8) 250 mL P HNO₃



Results Report

Order ID: 2D04114

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD-South River High
11 Montgomery St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04114-01		Site: SRHS--- Field Blank		Sample ID: Field Blank						
Collector: NPA		Collect Date: 04/12/2022 9:31 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 YBZ 04/25/22 14:02 MKR

Sample Number: 2D04114-02		Site: SRHS-1FL-POE-Main(140)		Sample ID: Main(140)						
Collector: NPA		Collect Date: 04/12/2022 9:32 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 JED 04/25/22 12:15 MKR

Sample Number: 2D04114-03		Site: SRHS-1FL-WC-Hall o/s Rm 141		Sample ID: Hall o/s Rm 141					
Collector: NPA		Collect Date: 04/12/2022 9:33 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 JED 04/25/22 12:01 MKR

Sample Number: 2D04114-04		Site: SRHS-1FL-WC-Hall o/s Rm 213-1		Sample ID: Hall o/s Rm 213-1					
Collector: NPA		Collect Date: 04/12/2022 9:34 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/25/22 JED 04/25/22 11:56 MKR

Sample Number: 2D04114-05		Site: SRHS-1FL-FS-Teachers Lounge		Sample ID: Teachers Lounge					
Collector: NPA		Collect Date: 04/12/2022 9:35 am		Sample Type: Grab					
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead 2.89 µg/L EPA 200.8 1.00 1 04/25/22 JED 04/25/22 12:30 MKR

Report Generated On: 04/26/2022 2:28 pm
STL_Results Revision #1.9

2D04114
Effective: 04/16/2020



SUBURBAN TESTING LABS

Sample Number: 2D04114-06	Site: SRHS-1FL-FP-Main Office Kitchen	Sample ID: Main Office Kitchen
Collector: NPA	Collect Date: 04/12/2022 9:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.25	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:03	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-07	Site: SRHS-1FL-NS-Nurse Office	Sample ID: Nurse Office
Collector: NPA	Collect Date: 04/12/2022 9:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	YBZ	04/25/22 10:42	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-08	Site: SRHS-1FL-WC-Hall o/s Auditorium	Sample ID: Hall o/s Auditorium
Collector: NPA	Collect Date: 04/12/2022 9:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:13	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-09	Site: SRHS-1FL-WC-Hall o/s Cust. Office	Sample ID: Hall o/s Cust. Office
Collector: NPA	Collect Date: 04/12/2022 9:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:28	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-10	Site: SRHS-1FL-WC-Cafeteria	Sample ID: Cafeteria
Collector: NPA	Collect Date: 04/12/2022 9:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:05	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-11	Site: SRHS-1FL-FP-Kitchen-1	Sample ID: Kitchen-1
Collector: NPA	Collect Date: 04/12/2022 9:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	17.2	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 11:58	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/26/2022 2:28 pm 2D04114
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 2D04114-12	Site: SRHS-1FL-FP-Kitchen-2	Sample ID: Kitchen-2
Collector: NPA	Collect Date: 04/12/2022 9:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.85	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:07	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-13	Site: SRHS-1FL-FP-Kitchen-3	Sample ID: Kitchen-3
Collector: NPA	Collect Date: 04/12/2022 9:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	36.0	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:32	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-14	Site: SRHS-1FL-FP-Life Skills Rm 110-1	Sample ID: Life Skills Rm 110-1
Collector: NPA	Collect Date: 04/12/2022 9:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.57	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:36	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-15	Site: SRHS-1FL-FP-Life Skills Rm 110-2	Sample ID: Life Skills Rm 110-2
Collector: NPA	Collect Date: 04/12/2022 9:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.26	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:26	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-16	Site: SRHS-1FL-FP-Life Skills Rm 110-3	Sample ID: Life Skills Rm 110-3
Collector: NPA	Collect Date: 04/12/2022 9:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.69	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:09	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-17	Site: SRHS-1FL-DW-Girls Locker	Sample ID: Girls Locker
Collector: NPA	Collect Date: 04/12/2022 9:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:11	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/26/2022 2:28 pm 2D04114
STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 2D04114-18	Site: SRHS-1FL-DW-Hall o/s Gym	Sample ID: Hall o/s Gym
Collector: NPA	Collect Date: 04/12/2022 9:49 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 13:17	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-19	Site: SRHS-1FL-HB-Trainers Rm	Sample ID: Trainers Hose Bib
Collector: NPA	Collect Date: 04/12/2022 9:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.80	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 12:21	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-20	Site: SRHS-1FL-DW-Boys Locker	Sample ID: Boys Locker
Collector: NPA	Collect Date: 04/12/2022 9:51 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	RMB	04/25/22 12:58	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D04114-21	Site: SRHS-1FL-IM-Trainers Rm	Sample ID: Trainers Rm
Collector: NPA	Collect Date: 04/12/2022 9:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/25/22	JED	04/25/22 10:16	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent

Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Report Generated On: 04/26/2022 2:28 pm

STL_Results Revision #1.9

2D04114

Effective: 04/16/2020



SUBURBAN
TESTING LABS

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 04/26/2022 2:28 pm 2D04114
STL_Results Revision #1.9 Effective: 04/16/2020





2D04114
Lisa F. Care

COC Pg 1

 SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com		TAT (Check One) <u>Standard</u> 24hr 48hr 72hr Other	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	South River High
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		11 Montgomery St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
	Field Blank	04/12/22	09:31 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRHS---Field Blank
Flush	Main (140)	04/12/22	09:32 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-POE-Main (140)
First	Hall o/s Rm 141	04/12/22	09:33 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Rm 141
First	Hall o/s Rm 213-1	04/12/22	09:34 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	SRHS-2FL-WC-Hall o/s Rm 213-1
First	Teachers Lounge	04/12/22	09:35 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FS-Teachers Lounge
First	Main Office Kitchen	04/12/22	09:36 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Main Office Kitchen
First	Nurse Office	04/12/22	09:37 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-NS-Nurse Office
First	Hall o/s Auditorium	04/12/22	09:38 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Auditorium
First	Hall o/s Cust. Office	04/12/22	09:39 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Cust. Office
First	Cafeteria	04/12/22	09:40 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Cafeteria

Relinquished by:

Chip Kim

Date: ~~2/15~~ 2:15

Time: 4/13/22

Received By:

William Murray 2:00 PM 1 bag

Date: 4/14/22 Temp °C: 22.6

Time: 1036 Acceptable Y/N

Relinquished by:

William Murray 2:00 PM 1 bag

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

mf

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SWDA Reportin
Submitted w/ container match <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/L)	G = Glass	<input type="checkbox"/> Fax
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	Or Other	<input type="checkbox"/> Email
Tests within holding time <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
60 ml WDA violation of headspace? <input checked="" type="checkbox"/> Y/N	Sample Type Key	H = Sodium Thiosulfate	
	G = Grab	Asd	A = Ascorbic
	B NC = 8 Hour Composite	G = HCl	H = HNO3
	C = Check	H2SO4	S =
	S = Special	Q = Other	Cl = NaOH
	M = Maximum Residence	None Required	NA =

(10) 250 mL P HNO3



COC Pg 2

2D04114
Lisa F. Care**SUBURBAN
TESTING LABS****TESTING LABS****Chain of Custody Record**1037F MacArthur Road, Reading, PA 19605
610-375-TEST -- Fax: 610-375-4090 -- suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	South River High
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		11 Montgomery St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Kitchen-1	04/12/22	09:41 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-1
First	Kitchen-2	04/12/22	09:42 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-2
First	Kitchen-3	04/12/22	09:43 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-3
First	Life Skills Rm 110-1	04/12/22	09:44 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-1
First	Life Skills Rm 110-2	04/12/22	09:45 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-2
First	Life Skills Rm 110-3	04/12/22	09:46 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-3
First	Girls Locker	04/12/22	09:48 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-DW-Girls Locker
First	Hall o/s Gym	04/12/22	09:49 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-DW-Hall o/s Gym
First	Trainers Hose Bib	04/12/22	09:50 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-HB-Trainers Rm
First	Boys Locker	04/12/22	09:51 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-DW-Boys Locker

Relinquished by:

Date: 2:15

Time: 4/13/22

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable ☒ N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable ☒ N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable ☒ N

1550

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge and, etc. (reported as mg/l)	P = Plastic G = Glass O = Other	<input type="checkbox"/> SWDA <input type="checkbox"/> Residual
Number of containers match number on CRF? <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulfate Ascorbic D = HCl H ₂ SO ₄ G = Other	<input type="checkbox"/> Fee <input type="checkbox"/> Email
All containers intact <input checked="" type="checkbox"/> Y/N	Sample Type Key G = Grab B HC = B Flow Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point H = Hot C = Check S = Special M = Maximum Residence	<input type="checkbox"/> Other
Tests within holding times <input checked="" type="checkbox"/> Y/N		None Required	<input type="checkbox"/> Possible in copy of this form
40 mL VOA held free of headspace? <input checked="" type="checkbox"/> Y/N			

(10) 250 mL P HNO₃



COC Pg 3

2D04114
Lisa F. Care

Chain of Custody Record

TAT (Check One)

Standard

4111

7011

1037F MacArthur Road, Reading, PA 19605

610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	South River High
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		11 Montgomery St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Trainers Rm	04/12/22	09:52 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-IM-Trainers Rm

Relinquished by:

Date: 2:15

Time: 4/13/22

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 10:10 Acceptable (Y) N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1:50 Acceptable (Y) N

Received in Lab By:

Date: 4.14.22 Temp °C: 24.1

Time: 1:50 Acceptable (Y) N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ CDC	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> S&A
	S&D = Raw Sludge, Dewatered	G = Glass	<input type="checkbox"/> Reporting
	Sludge, soil, etc. (reported as mg/l)	O = Other	<input type="checkbox"/> Fax
Review w/ containers match number on CDC	PW = Potable Water		<input type="checkbox"/> Email
	(not for SWDA compliance)	Preservative Key	
	SWDA = Safe Drinking Water Act	H = Sodium	
	Potable Sample	Thiosulfate	A = Ascorbic
All containers intact	Sample Type Key	Ascl	H = HNO3
	G = Grab	C = HCl	S =
	D = Distribution	H2SO4	Cl = NaOH
	E = Entry Point	O = Other	NA =
	R = Raw		
Tests within holding times	C = Check		
	Composite		
	S = Spigot		
40 ml VDA vials free of headspace?	M = Maximum		
	Residence		
		None Required	



Results Report

Order ID: 2D04961

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD-Primary
22 David St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04961-01
Collector: NPA

Site: SRCS-1FL-S-Conc
Collect Date: 04/15/2022 8:00 am

Sample ID: Concession
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3190	µg/L	EPA 200.8	1.00	1	05/03/22	MKS	05/03/22 9:42	MKS
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 2D04961-02
Collector: NPA

Site: SRCS-1FL-IM-Conc
Collect Date: 04/15/2022 8:05 am

Sample ID: Concession
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	956	µg/L	EPA 200.8	2.00	2	05/05/22	MKS	05/05/22 9:19	MKS
------	-----	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 2D04961-03
Collector: NPA

Site: SRPS-2FL-WC-o/s Rm 202
Collect Date: 04/15/2022 8:15 am

Sample ID: Hall O/S Rm 202
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/02/22	YBZ	05/02/22 12:25	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Report Generated On: 05/09/2022 1:35 pm
STL_Results Revision #2.0

2D04961
Effective: 04/20/2022



The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:


Lisa F. Care
Project Manager II

Report Generated On: 05/09/2022 1:35 pm 2D04961
STL_Results Revision #2.0 Effective: 04/20/2022





2D04961
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAI (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	Sout River Primary School
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		22 David St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Concession	04/15/22	08:00 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRCS-1FL-S-Conc
First	Concession	04/15/22	08:05 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRCS-1FL-IM-Conc
First	Hall O/S Rm 202	04/15/22	08:15 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s Rm 202

Relinquished by:

Date: 4/20/22

Time: 8:00

Received By:

Date: Temp °C:

Time: Acceptable Y / N

Relinquished by:

Date: Temp °C:

Time: Acceptable Y / N

Received in Lab By:

Date: Temp °C:

Time: Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <u>Y/N</u>	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SWDA Reportin
Number of containers match number on COC? <u>Y/N</u>	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass	<input type="checkbox"/> Fax
All containers intact <u>Y/N</u>	PW = Potable Water (not for SWDA compliance)	O = Other	<input type="checkbox"/> Email
Tests within holding times <u>Y/N</u>	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> Other
40 ml VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	H = Sodium Thiosulphate	<input type="checkbox"/> Return a copy of this form
	G = Grab	A = Ascorbic Acid	
	8 HC = 8 Hour Composite	H = HNO3	
	24 HC = 24 Hour Composite	S = S	
		C = HCl	
		H2SO4	
		OH = NaOH	
		None Required	



Results Report

Order ID: 2D04078

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD-Primary
22 David St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04078-03
Collector: NPA

Site: SRPS-1FL-DW-Nurse-F
Collect Date: 04/12/2022 12:49 pm

Sample ID: Nurse (Rm 111)
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	23.4	µg/L	EPA 200.8	1.00	1	05/26/22	RPV	05/26/22 13:13	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/27/2022 2:11 pm
STL_Results Revision #2.0

2D04078
Effective: 04/20/2022





2D04078
Lisa F. Care

COC Pg 1

SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com		TAT (Check One) Standard 24hr 48hr 72hr (Other) <u>ICSL</u>	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	Sout River Primary School
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		22 David St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
Flush	Hall o/s Main Office	04/12/22	12:47 PM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRPS-GF-WC-Hall o/s Main Office-F
Flush	Hall o/s 104	04/12/22	12:48 PM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s 104-F
Flush	Nurse(Rm 111)	04/12/22	12:49 PM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-DW-Nurse-F
Flush	Hall o/s Rm 115	04/12/22	12:50 PM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Rm 115-F
Flush	Hall o/s Cafe-1	04/12/22	12:51 PM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Cafe-1-F
Flush	Hall o/s Cafe-2	04/12/22	12:52 PM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Hall o/s Cafe-2-F
Flush	Cafe-1	04/12/22	12:53 PM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Cafe-1-F
Flush	Cafe-2	04/12/22	12:54 PM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-WC-Cafe-2-F
Flush	Kitchen	04/12/22	12:55 PM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	SRPS-1FL-FP-Kitchen-F
Flush	Media Center-2	04/12/22	12:56 PM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Media Center-2-F

Relinquished by:

Date: 2:12

Time: 4/13/22

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1 °C

Time: 1650 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ CDC	NPW = Non-Potable Water	P = Plastic	SWDA Reporting
Submitted in container's match	Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/L)	G = Glass	Fee
All containers intact	PW = Potable Water (not for SWDA compliance)	O = Other	Email
Tests within holding times	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
40 ml. WDA with free of headspace?	Sample Type Key	H = Sodium Thiosulfate	
	G = Grab	A = Ascorbic Acid	
	24 HC = 24 Hour Composite	H = HNO3	
	C = Check	G = HCl	
	25 = Special	H2SO4	
	3M = Maximum Residence	O = Other	
		OH = NaOH	
		None Required	
		NA =	Product is copy of

(10)250 mL P HNO3



2D04078
Lisa F. Care

COC Pg 2

SUBURBAN TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com		TAT (Check One) Standard 24hr 48hr 72hr <u>Other</u> <i>28hr</i>	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	Sout River Primary School
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		22 David St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
Flush	Hall o/s 209	04/12/22	12:57 PM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s 209-F
Flush	Hall o/s Media Ctr-1	04/12/22	12:58 PM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s Media Ctr-1-F
Flush	Hall o/s Media Ctr-2	04/12/22	12:59 PM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-Hall o/s Media Ctr-2-F

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: *2/12*

Time: *4/13/22*

Date: *4/14/22* Temp °C: *22.6*

Time: *1036* Acceptable *Y/N*

Date: *4/14/22* Temp °C: *24.1*

Time: *155* Acceptable *Y/N*

Date: *4-14-22* Temp °C: *24.1*

Time: *1550* Acceptable *Y/N*

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <i>Y/N</i>	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SWDA Reportin
PERFORMED BY: <i>Y/N</i>	Solid = Raw Sludge, Distilled Sludge, etc. (reported as req'd)	G = Glass	<input type="checkbox"/> Fax
CONTAINER MATCH: <i>Y/N</i>	PW = Potable Water (not for SWDA compliance)	Or Other	<input type="checkbox"/> Email
All containers intact <i>Y/N</i>	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
Tests within holding times <i>Y/N</i>	Sample Type Key	H = Sodium Thiocyanate	A = Ascorbic Acid
40 mL VOA vials free of headspace? <i>Y/N</i>	D = Distribution	C = HCl	H = HNO3
	24 HG = 24 Hour Composite	H2SO4	S =
		Q = Other	OH = NaOH
			NA =
			Return # copy of this form:

(3) 250 mL P HNO3



Results Report

Order ID: 2D04110

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD
3 Montgomery Street
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04110-31
Collector: NPA

Site: SRE/MS-2FL-FP-Kitchen-4-F
Collect Date: 04/12/2022 11:11 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	8.98	µg/L	EPA 200.8	1.00	1	05/26/22	RPV	05/26/22 13:27	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/27/2022 2:10 pm
STL_Results Revision #2.0

2D04110
Effective: 04/20/2022



2D04110
Lisa F. Care

Standard 24hr 48hr 72hr

Other

16061



**SUBURBAN
TESTING LABS**

TESTING LABS

10377 MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-2FL-DW-Music-F	04/12/22	10:41 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	Music
Flush	SRE/MS-2FL-WC-Hall o/s Rm	04/12/22	10:42 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 212-1
Flush	SRE/MS-2FL-DW-Rm 215-F	04/12/22	10:43 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Rm 215
Flush	SRE/MS-2FL-DW-Rm 214-F	04/12/22	10:44 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Rm 214
Flush	SRE/MS-2FL-DW-Rm 216-F	04/12/22	10:45 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Rm 216
Flush	SRE/MS-2FL-DW-Rm 217-F	04/12/22	10:46 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Rm 217
Flush	SRE/MS-2FL-DW-Rm 219-F	04/12/22	10:47 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Rm 219
Flush	SRE/MS-2FL-DW-Rm 221-F	04/12/22	10:48 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Rm 221
Flush	SRE/MS-2FL-WC-Hallway side	04/12/22	10:49 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Hallway side Rm 220-1
Flush	SRE/MS-2FL-WC-Hall o/s Rm	04/12/22	10:50 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 210-1

Relinquished by:

Date: 4/13/2022

Time: 17:00

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CDC	NPW = Non-Potable Water	P = Plastic
Sludge = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l)		G = Glass
		O = Other
Preservative Key		
PW = Potable Water (not for SWDA compliance)		
SWDA = Safe Drinking Water Act		
Potable Sample		
All containers intact	Sample Type Key	SWDA Sample Type
Tests within holding time	G = Grab	D = Distribution
40 mL VDA vials free of headspace?	6 HC = 6 Hour Composite	E = Entry Point
	24 HC = 24 Hour Composite	R = Raw
		C = Check
		S = Special
		M = Maximum Residence

(10) 250 mL HNO₃



2D04110
Lisa F. Care



TESTING LABS

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Standard 24hr 48hr 72hr Other

1610

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-2FL-DW-Rm 209-F	04/12/22	10:51 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	Rm 209
Flush	SRE/MS-2FL-DW-Rm 208-F	04/12/22	10:52 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	Rm 208
Flush	SRE/MS-2FL-DW-Rm 207-F	04/12/22	10:53 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	Rm 207
Flush	SRE/MS-2FL-DW-Rm 206-F	04/12/22	10:54 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	Rm 206
Flush	SRE/MS-2FL-DW-Rm 205-F	04/12/22	10:55 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	Rm 205
Flush	SRE/MS-2FL-DW-Rm 204-F	04/12/22	10:56 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	Rm 204
Flush	SRE/MS-2FL-DW-Rm 202-F	04/12/22	10:57 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	Rm 202
Flush	SRE/MS-2FL-DW-Rm 203-F	04/12/22	10:58 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	Rm 203
Flush	SRE/MS-2FL-FS-Faculty Lo	04/12/22	10:59 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	Faculty Loungs
Flush	SRE/MS-2FL-NS-Nurse Offi	04/12/22	11:00 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	Nurse Office-1

Relinquished by:

Received By:

2 cooler bag

Relinquished by:

2 cooler bag

Received in Lab By:

Date: 4/13/2022

Time: 17:00

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1530 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Not Potable Water	P = Plastic
Container is container's match <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Unsettled Sludge, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Notable Sample	H = Sodium Hydroxide
	Sample Type Key	AS = Ascorbic Acid
	G = Grab	H = HNO3
	D = Distribution	S = H2O2
	E = Empty Point	OH = NaOH
	R = Raw	None Required
	C = Check	
	S = Special	
	M = Maximum Residence	

(10) 250 mL P HNO3



2D04110
Lisa F. Care



TESTING LABS

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-2FL-NS-Nurse Off	04/12/22	11:01 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	Nurse Office-2
Flush	SRE/MS-2FL-WC-Hall o/s F	04/12/22	11:02 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Faculty-1
Flush	SRE/MS-2FL-WC-O/S Stag	04/12/22	11:03 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	O/S Stage-1
Flush	SRE/MS-2FL-WC-Hall o/s 2	04/12/22	11:04 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 224-1
Flush	SRE/MS-2FL-WC-Cafe-1-F	04/12/22	11:05 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	Cafe-1
Flush	SRE/MS-2FL-WC-Cafe-2-F	04/12/22	11:06 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	Cafe-2
Flush	SRE/MS-2FL-S-Cafe Facult	04/12/22	11:07 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	Cafe Faculty
Flush	SRE/MS-2FL-FP-Kitchen-1	04/12/22	11:08 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	Kitchen-1
Flush	SRE/MS-2FL-FP-Kitchen-2	04/12/22	11:09 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	Kitchen-2
Flush	SRE/MS-2FL-FP-Kitchen-3	04/12/22	11:10 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	Kitchen-3

Relinquished by:

Date: 4/13/2022

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
number in containers match number on label <input checked="" type="checkbox"/> Y/N	Solid = Raw Sample, Dissolved Sample, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	Q = Other
Tests within holding time <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml WDA water free of headspace? <input checked="" type="checkbox"/> Y/N	Sample Type Key	H = Sodium Thiosulfate
	G = Grab	A = Ascorbic Acid
	6 HC = 6 Hour Composite	H = HNO ₃
	24 HC = 24 Hour Composite	S = H ₂ SO ₄
		OH = NaOH
		NA = None Required

(10) 250 ml P HNO₃



2D04110
Lisa F. Care

Standard 24hr 48hr 72hr Other

Gold



TESTING LABS

10377 MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-2FL-FP-Kitchen-4	04/12/22	11:11 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	Kitchen-4
Flush	SRE/MS-3FL-WC-Hall o/s	04/12/22	11:12 AM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 302-1
Flush	SRE/MS-3FL-S-Mid Main C	04/12/22	11:13 AM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	Mid Main Office-1
Flush	SRE/MS-3FL-FS-Mid Teac	04/12/22	11:14 AM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	Mid Teachers Lounge
Flush	SRE/MS-3FL-NS-Nurse-1-	04/12/22	11:15 AM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	Nurse-1
Flush	SRE/MS-3FL-NS-Nurse-2-	04/12/22	11:16 AM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	Nurse-2
Flush	SRE/MS-3FL-WC-O/S Nur	04/12/22	11:17 AM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	O/S Nurse-1
Flush	SRE/MS-3FL-DW-Rm 320	04/12/22	11:18 AM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	Rm 320
Flush	SRE/MS-3FL-DW-Rm 318	04/12/22	11:19 AM	NPA	039	Pb EPA 200.8	1	PW	G	P	H	Rm 318
Flush	SRE/MS-3FL-S-Rm 319-1-	04/12/22	11:20 AM	NPA	040	Pb EPA 200.8	1	PW	G	P	H	Rm 319-1

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: 4/13/2022

Time: 17:00

Date: 4/14/22 Temp °C: 22.6

Time: 1038 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CDC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Maximum 50 containers match number on label? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	On Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Sample Type Key	H = Sodium Thiosulfate
	G = Grab	A = Ascorbic Acid
	RHC = 8 Hour Composite	H = HNO3
	R = Raw	C = HCl
	C = Check	S =
	S = Special	H2SO4
	M = Maximum Retention	Other = NaOH
		D = Other
		None Required

(10) 250 mL P HNO3



TESTING LABS

2D04110
Lisa F. Care

610-375-TEST - Fax: 610-375-4000

d 24hr 48hr 72hr Other

Held

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-3FL-S-Rm 319-2-F	04/12/22	11:21 AM	NPA	041	Pb EPA 200.8	1	PW	G	P	H	Rm 319-2
Flush	SRE/MS-3FL-DW-Rm 317-F	04/12/22	11:22 AM	NPA	042	Pb EPA 200.8	1	PW	G	P	H	Rm 317
Flush	SRE/MS-3FL-DW-Rm 316-F	04/12/22	11:23 AM	NPA	043	Pb EPA 200.8	1	PW	G	P	H	Rm 316
Flush	SRE/MS-3FL-DW-Rm 313-F	04/12/22	11:24 AM	NPA	044	Pb EPA 200.8	1	PW	G	P	H	Rm 313
Flush	SRE/MS-3FL-WC-Hall o/s E	04/12/22	11:25 AM	NPA	045	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Elevator-1
Flush	SRE/MS-1FL-DW-Rm 105-F	04/12/22	11:26 AM	NPA	046	Pb EPA 200.8	1	PW	G	P	H	Rm 105
Flush	SRE/MS-1FL-DW-Rm 104-F	04/12/22	11:27 AM	NPA	047	Pb EPA 200.8	1	PW	G	P	H	Rm 104
Flush	SRE/MS-1FL-DW-Rm 106-F	04/12/22	11:28 AM	NPA	048	Pb EPA 200.8	1	PW	G	P	H	Rm 106
Flush	SRE/MS-1FL-DW-Rm 109-F	04/12/22	11:29 AM	NPA	049	Pb EPA 200.8	1	PW	G	P	H	Rm 109
Flush	SRE/MS-1FL-DW-Rm 110-F	04/12/22	11:30 AM	NPA	050	Pb EPA 200.8	1	PW	G	P	H	Rm 110

Relinquished by:

Date: 4/13/2022

Time: 17:00

Received By:

Date: 4/14/22 Temp °C: 22.6

Time: 1030 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	PW = Raw Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/L) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	SWDA Reporting PW SD
containers match number on COC <input checked="" type="checkbox"/> Y/N		Preservative Key H = Sodium Thiosulfate A = Ascorbic Acid H = HNO3 C = HCl H2SO4 O = Other None Required	Fax Email
All containers intact <input checked="" type="checkbox"/> Y/N	Sample Type Key G = Grab B HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distillate E = Entry Point R = Raw C = Check S = Spec M = Maximum Residue	Other Return a copy of this form with Report
Tests within holding time <input checked="" type="checkbox"/> Y/N			
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N			

(10) 250 mL P HNO3



2D04110
Lisa F. Care

24hr 48hr 72hr

Other

141d



TESTING LABS

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-1FL-DW-Rm 111-	04/12/22	11:31 AM	NPA	051	Pb EPA 200.8	1	PW	G	P	H	Rm 111
Flush	SRE/MS-1FL-DW-Rm 113-	04/12/22	11:32 AM	NPA	052	Pb EPA 200.8	1	PW	G	P	H	Rm 113
Flush	SRE/MS-1FL-DW-Rm 114-	04/12/22	11:33 AM	NPA	053	Pb EPA 200.8	1	PW	G	P	H	Rm 114
Flush	SRE/MS-1FL-WC-Hall o/s F	04/12/22	11:34 AM	NPA	054	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 114-1
Flush	SRE/MS-1FL-WC-Aux Gym	04/12/22	11:35 AM	NPA	055	Pb EPA 200.8	1	PW	G	P	H	Aux Gym A
Flush	SRE/MS-1FL-WC-Hall o/s C	04/12/22	11:36 AM	NPA	056	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Girl's LR-1
Flush	SRE/MS-1FL-WC-Hall o/s 1	04/12/22	11:37 AM	NPA	057	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 100B-1
Flush	SRE/MS-1FL-DW-Rm 117-	04/12/22	11:38 AM	NPA	058	Pb EPA 200.8	1	PW	G	P	H	Rm 117
Flush	SRE/MS-1FL-DW-Rm 119-	04/12/22	11:39 AM	NPA	059	Pb EPA 200.8	1	PW	G	P	H	Rm 119
Flush	SRE/MS-1FL-DW-Rm 118-	04/12/22	11:40 AM	NPA	060	Pb EPA 200.8	1	PW	G	P	H	Rm 118

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: 4/13/2022

Time: 17:00

Date: 4/14/22 Temp °C: 22.4

Time: 1030 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Date: 4/14/22 Temp °C: 24.1

Time: 1550 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC	NPW = Non Potable Water	P = Plastic
	Solid = Raw Sludge, Sewerage	G = Glass
	Sludge, soil, etc. (reported as mg/l)	C = Other
Containers match	PW = Potable Water	
(not for SWDA compliance)	(not for SWDA compliance)	
All containers intact	SWDA = Safe Drinking Water Act	
	Potable Sample	
	Sample Type Key	Preservative Key
Tests within holding times	G = Grab	H = Sodium
40 mL VOA vials free of headspace?	8 HC = 8 Hour Composite	Thiosulfate
	24 HC = 24 Hour Composite	Acid
		H = HNO3
		C = HCl
		H2SO4
		CH = NaOH
		Q = Other
		None Required
		NA =

(10) 250 mL P HNO3



2D04110
Lisa F. Care

rd 24hr 48hr 72hr Other

Hold



TESTING LABS

1037F MacArthur Road, Reading, PA 19606
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Elementary/Middle
	West Chester, PA 19380	Email:	nabraham@westchestervironmental.com		3 Montgomery St, South River, NJ 08882
Contact Name:	Noel Abraham	Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	SRE/MS-1FL-DW-Rm 120-F	04/12/22	11:41 AM	NPA	61	Pb EPA 200.8	1	PW	G	P	H	Rm 120
Flush	SRE/MS-1FL-DW-Rm 121-F	04/12/22	11:42 AM	NPA	62	Pb EPA 200.8	1	PW	G	P	H	Rm 121
Flush	SRE/MS-1FL-DW-Rm 123-F	04/12/22	11:43 AM	NPA	63	Pb EPA 200.8	1	PW	G	P	H	Rm 123
Flush	SRE/MS-1FL-DW-Rm 122-F	04/12/22	11:44 AM	NPA	64	Pb EPA 200.8	1	PW	G	P	H	Rm 122
Flush	SRE/MS-1FL-DW-Rm 125-F	04/12/22	11:45 AM	NPA	65	Pb EPA 200.8	1	PW	G	P	H	Rm 125
Flush	SRE/MS-1FL-WC-Hall o/s Rm 125	04/12/22	11:46 AM	NPA	66	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 125-1

Relinquished by:

Date: 4/13/2022

Received By:

Time: 17:00

Date: 4/14/22 Temp °C: 22.6

Time: 10:30 Acceptable Y/N

Relinquished by:

Date: 4/14/22 Temp °C: 24.1

Time: 15:50 Acceptable Y/N

Received in Lab By:

Date: 4/14/22 Temp °C: 24.1

Time: 15:50 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC	NPA = Non-Potable Water	P = Plastic
Submitted in container	Gold = Free Storage, Discontinued	G = Glass
match number on label	Sample bag, etc. (reported as req'd)	Or Other
	PW = Potable Water	
	(not for SWDA compliance)	
	SWDA = Safe Drinking Water Act	
	Potable Sample	
All containers intact	Sample Type Key	Preservative Key
	SWDA Sample Type	H = Sodium
	G = Grab	Thiosulphate
	B HC = 8 Hour Composite	A = Ascorbic Acid
	D = Distribution	H = HNO3
	E = Entry Point	C = HCl
	R = Raw	H2SO4
	C = Check	Q = Other
	S = Special	
	IM = Maximum Incubation	
	Residence	

(6) 250 mL P HNO3



Results Report

Order ID: 2D04113

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD
11 Montgomery St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04113-09
Collector: NPA

Site: SRHS-1FL-FP-Kitchen-1-F
Collect Date: 04/12/2022 9:41 am

Sample ID: Kitchen-1
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/26/22	RPV	05/26/22 13:31	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/27/2022 2:09 pm
STL_Results Revision #2.0

2D04113
Effective: 04/20/2022





2D04113
Lisa F. Care

COC Pg 1



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other _____

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	South River High
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		11 Montgomery St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
	Hall o/s Rm 141	06/10/17	09:33 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Rm 141-F
Flush	Hall o/s Rm 213-1	06/10/17	09:34 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRHS-2FL-WC-Hall o/s Rm 213-1-F
Flush	Teachers Lounge	06/10/17	09:35 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FS-Teachers Lounge-F
Flush	Main Office Kitchen	06/10/17	09:36 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Main Office Kitchen-F
Flush	Nurse Office	06/10/17	09:37 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-NS-Nurse Office-F
Flush	Hall o/s Auditorium	06/10/17	09:38 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Auditorium-F
Flush	Hall o/s Cust. Office	06/10/17	09:39 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Cust. Office-F
Flush	Cafeteria	06/10/17	09:40 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Cafeteria-F
Flush	Kitchen-1	06/10/17	09:41 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-1-F
Flush	Kitchen-2	06/10/17	09:42 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-2-F

Relinquished by:

[Signature]

Date: 2:15

Time: 4/13/22

Received By:

[Signature] 2:00 PM
16 AG

Date: 4/14/22 Temp °C: 22.6

Time: 10:30 Acceptable ☒ N

Relinquished by:

[Signature] 2:00 PM
16 AG

Date: 4/14/22 Temp °C: 24.1

Time: 1:50 Acceptable ☒ N

Received in Lab By:

[Signature]

Date: 4/14/22 Temp °C: 24.1

Time: 1:50 Acceptable ☒ N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic	SWDA Report
Residual is containers match <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SWD = Raw Surface, Disordered Surface soil, etc. (reported as mg/L)	G = Glass	For
All containers intact <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	Q = Other	Email
Tests within holding time <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key	H = Sodium	Other
	G = Grab	Thiosulfate	
	2 HC = 2 Hour Composite	Ascorbic Acid	
	24 HC = 24 Hour Composite	H = HNO3	
		S =	
		OH = NaOH	
		NA =	
		None Required	

(10) 250 mL P HNO₃



COC Pg 2

2D04113
Lisa F. Care

SUBURBAN TESTING LABS TESTING LABS		Chain of Custody Record 1037F MacArthur Road, Reading, PA 19605 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com		TAT (Check one) Standard 24hr 48hr 72hr <u>Other</u> <i>720 hr</i>	
Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane			Address:	South River High
	West Chester, PA 19380				11 Montgomery St., South River, NJ 08882
Contact Name:	Noel Abraham			Email:	nabraham@westchesterenviromental.com
				Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
Flush	Kitchen-3	06/10/17	09:43 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Kitchen-3-F
Flush	Life Skills Rm 110-1	06/10/17	09:44 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-1-F
Flush	Life Skills Rm 110-2	06/10/17	09:45 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-2-F
Flush	Life Skills Rm 110-3	06/10/17	09:46 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-FP-Life Skills Rm 110-3-F
Flush	Girls Locker	06/10/17	09:48 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-DW-Girls Locker-F
Flush	Hall o/s Gym	06/10/17	09:49 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-WC-Hall o/s Gym-F
Flush	Trainers Hose Bib	06/10/17	09:50 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-HB-Trainers Rm-F
Flush	Boys Locker	06/10/17	09:51 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	SRHS-1FL-DW-Boys Locker-F

Relinquished by:

Date: **2/15**Time: **4/13/22**

Received By:

2100ml
1 bagDate: **4/14/22** Temp °C: **22.6**Time: **1030** Acceptable ☒ N

Relinquished by:

2100ml
1 bagDate: **4/14/22** Temp °C: **24.1**Time: **1550** Acceptable ☒ N

Received in Lab By:

Date: **4/14/22** Temp °C: **24.1**Time: **1550** Acceptable ☒ N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sediment, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	<input type="checkbox"/> SWDA Reporting <input type="checkbox"/> Fax <input type="checkbox"/> Email
Number of containers match number on COC? <input checked="" type="checkbox"/> Y/N	Sample Type Key G = Grab E = Empty Point C = Check S = Special M = Medium R = Residue	Preservative Key H = Sodium Thiosulfate A = Ascorbic Acid C = HCl H ₂ SO ₄ O = Other None Required	<input type="checkbox"/> Other <input type="checkbox"/> NA <input type="checkbox"/> Mailing copy of this form
All containers intact <input checked="" type="checkbox"/> Y/N			
Tests within holding time <input checked="" type="checkbox"/> Y/N			
40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N			

(8) 250 mL P HNO₃



Results Report

Order ID: 2D04959

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: South River SD-Primary
22 David St
South River, NJ 08882

Attn: Noel Abraham

Regulatory ID:

Sample Number: 2D04959-01
Collector: NPA

Site: SRCS-1FL-S-Conc-F
Collect Date: 04/15/2022 8:00 am

Sample ID: Concession
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.95	µg/L	EPA 200.8	1.00	1	05/26/22	RPV	05/26/22 13:41	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 05/27/2022 2:07 pm
STL_Results Revision #2.0

2D04959
Effective: 04/20/2022



2D04959
Lisa F. Care



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr Other

1/6/18

Client Name:	Westchester Environmental LLC.			Project Name:	South River SD
Address:	1248 Wrights Lane	Phone:	610-883-3839	Address:	Sout River Primary School
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		22 David St., South River, NJ 08882
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Concession	04/15/22	08:00 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	SRCS-1FL-S-Conc-F
Flush	Hall O/S Rm 202	04/15/22	08:15 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	SRPS-2FL-WC-O/s Rm 202-F

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: 4/20/22
Time: 8:00
Date: 4/20/22 Temp °C: 19.8
Time: 10:15 Acceptable Y/N
Date: 4/20/22 Temp °C: 16.3
Time: 16:15 Acceptable Y/N

2 Coolers

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SWDA Report
Returned in original container with label? <input checked="" type="checkbox"/> Y/N	Sed = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l)	G = Glass	<input type="checkbox"/> Fax
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	Other	<input type="checkbox"/> Email
Tests within holding time <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	
40 ml VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Sample Type Key	H = Sodium Thiosulfate	
	D = Distribution	A = Ascorbic Acid	
	E = Entry Point	H = HNO3	
	R = Raw	S =	
	C = Check	OH = NaOH	
	S = Special	NA =	
	M = Maximum Residence	None Required	

(2) 250 mL P HNO3

19.8