



Assessment Results Exceedance Table

Of the 35 samples collected at Carrie E. Tompkins Elementary School, 11 (31.43%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Carrie E. Tompkins Elementary School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
09/24/16	CTES-03	First	Sink in Unisex Toilet on the right near Room 17	45.9
09/24/16	CTES-11	First	Fountain in Room 3	25.0
09/24/16	CTES-23	Ground	Sink in Room 108	52.4
09/24/16	CTES-25	Exterior	Hose bib outside Boiler Room	57.5
09/24/16	CTES-26	Exterior	Hose bib outside Room 210	221
09/24/16	CTES-28	Exterior	Hose bib outside District Storage	35.9
09/24/16	CTES-29	Exterior	Hose bib outside Room 18	54.0
09/24/16	CTES-30	Exterior	Hose bib outside Multipurpose Room	626
09/24/16	CTES-32	Exterior	Hose bib outside Cafeteria	36.6
09/24/16	CTES-34	Exterior	Hose bib outside Room 114	59.0
09/24/16	CTES-35	Exterior	Sink near Field Hot Dog Stand	19.4

Of the 42 samples collected at Pierre Van Cortlandt Middle School, 8 (19.05%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Pierre Van Cortlandt Middle School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
09/24/16	PVMS-03	Second	Sink in Room 223	15.1
09/24/16	PVMS-08	Second	Sink in Room 217	22.8
09/24/16	PVMS-11	Second	Sink in Room 219	109
09/24/16	PVMS-12	Second	Sink in Room 219 (left corner)	72.8
09/24/16	PVMS-21	Second	Sink in Room 201 (left side)	25.9
09/24/16	PVMS-40	Exterior	Hose bib outside gym	113
09/24/16	PVMS-41	Exterior	Hose bib outside cafeteria	417
09/24/16	PVMS-42	Exterior	Hose bib outside basement	83.9