



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Joseph Sbarra
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005**

11/2/2016

Phone: (212) 612-7900
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/20/2016. The results are tabulated on the attached data pages for the following client designated project:

Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

The reference number for these samples is EMSL Order #011606967. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

Report amended 11/02/2016 13:54:55 Replaces initial report from 10/25/2016 15:34:05 Sample descriptions corrected for samples -0079 through -0084 at the client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

Analytical Results

Client Sample Description CHHS-01
1-S-STAFF RESTROOM L
Collected: 10/19/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.42	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-02
1-S-STAFF RESTROOM R
Collected: 10/19/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.2	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-03
1-S-RM 103 BATH RM
Collected: 10/19/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	37.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-04
1-S-RM 103
Collected: 10/19/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	83.7	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-05
1-F-CORRIDOR BY ROOM 102
Collected: 10/19/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.43	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-06
1-F-CORRIDOR BY ROOM 102 (30 SEC DRAW)
Collected: 10/19/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.29	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-07
1-F-CORRIDOR BY RM 102 (BOTTLE REFILL)
Collected: 10/19/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.10	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description CHHS-08
 1-S-BATH RM BY RM 105
Collected: 10/19/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.8	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-09
 1-S-CCAY RM L (ART STUDIO)
Collected: 10/19/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.54	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-10
 1-S-CCAY RM R (ART STUDIO)
Collected: 10/19/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.59	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-11
 1-S-ART STUDIO
Collected: 10/19/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-12
 1-S-RM 106 BATH RM L
Collected: 10/19/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.5	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-13
 1-S-RM 106 BATH RM R
Collected: 10/19/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	855	20.0	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-14
 1-S-RM 114 BATH RM (FACULTY RM)
Collected: 10/19/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.12	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description CHHS-15
 1-SHOWER RM HOSE **Collected:** 10/19/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	37.2	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-16
 1-RM 172 ICE MACHINE **Collected:** 10/19/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-17
 1-RM 172 WATER LINE **Collected:** 10/19/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.50	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-18
 1-RM 172 WATER LINE (30 SEC DRAW) **Collected:** 10/19/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-19
 2-S-ROOM 200B BY ENT **Collected:** 10/19/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.0	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-20
 2-S-ROOM 200B WALL L L **Collected:** 10/19/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	23.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-21
 2-S-ROOM 200B WALL L R **Collected:** 10/19/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description CHHS-22
 2-S-ROOM 200B WALL C L **Collected:** 10/19/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.2	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-23
 2-S-ROOM 200B WALL C R **Collected:** 10/19/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.0	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-24
 2-S-ROOM 200B WALL R L **Collected:** 10/19/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-25
 2-S-ROOM 200B WALL R R **Collected:** 10/19/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.9	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-26
 2-SCIENCE EXHAUST HOOD **Collected:** 10/19/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.9	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-27
 2-S-ROOM 200B WINDOW L L **Collected:** 10/19/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-28
 2-S-ROOM 200B WINDOW L R **Collected:** 10/19/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	70.6	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0029</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	37.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0030</i>
CHHS-30 2-S-ROOM 200B WINDOW LC R								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	13.8	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0031</i>
CHHS-31 2-S-ROOM 200B WINDOW C L								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	14.2	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0032</i>
CHHS-32 2-S-ROOM 200B WINDOW C R								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	11.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0033</i>
CHHS-33 2-S-ROOM 200B WINDOW RC L								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	21.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0034</i>
CHHS-34 2-S-ROOM 200B WINDOW RC R								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	22.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS
<i>Client Sample Description</i>					<i>Collected:</i>	<i>10/19/2016</i>	<i>Lab ID:</i>	<i>0035</i>
CHHS-35 2-S-ROOM 200B WINDOW R L								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	46.2	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

Analytical Results

Client Sample Description CHHS-36
2-S-ROOM 200B WINDOW R R
Collected: 10/19/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	50.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-37
2-S-ROOM 200C
Collected: 10/19/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	39.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-38
2-S-ROOM 200A BY DESK
Collected: 10/19/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.11	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-39
2-S-ROOM 200A WINDOW L L
Collected: 10/19/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	122	2.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-40
2-S-ROOM 200A WINDOW L R
Collected: 10/19/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-41
2-S-ROOM 200A WINDOW LC L
Collected: 10/19/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.6	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-42
2-S-ROOM 200A WINDOW LC R
Collected: 10/19/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.01	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description CHHS-43
 2-S-ROOM 200A WINDOW C L **Collected:** 10/19/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-44
 2-S-ROOM 200A WINDOW C R **Collected:** 10/19/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.47	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-45
 2-S-ROOM 200A WINDOW RC L **Collected:** 10/19/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-46
 2-S-ROOM 200A WINDOW RC R **Collected:** 10/19/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.43	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-47
 2-S-ROOM 200A WINDOW R L **Collected:** 10/19/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-48
 2-S-ROOM 200A WINDOW R R **Collected:** 10/19/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-49
 2-S-ROOM 200A EXHAUST HOOD **Collected:** 10/19/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	161	4.00	µg/L	10/21/2016	JS	10/25/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description CHHS-50
 2-S-ROOM 200A WALL L L **Collected:** 10/19/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.6	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-51
 2-S-ROOM 200A WALL L R **Collected:** 10/19/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-52
 2-S-ROOM 200A WALL C L **Collected:** 10/19/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-53
 2-S-ROOM 200A WALL C R **Collected:** 10/19/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	28.4	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-54
 2-S-ROOM 200A WALL R L **Collected:** 10/19/2016 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.0	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-55
 2-S-ROOM 200A WALL R R **Collected:** 10/19/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.97	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-56
 2-S-RM 201 F **Collected:** 10/19/2016 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	27.7	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

Analytical Results

Client Sample Description CHHS-57
2-S-RM 204
Collected: 10/19/2016
Lab ID: 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	25.0	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-58
2-S-BATH RM LADIES L
Collected: 10/19/2016
Lab ID: 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.46	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-59
2-S-BATH RM LADIES R
Collected: 10/19/2016
Lab ID: 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.54	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-60
3-S-BATH RM BOYS/MEN L
Collected: 10/19/2016
Lab ID: 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.03	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-61
3-S-BATH RM BOYS/MEN R
Collected: 10/19/2016
Lab ID: 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.79	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-62
3-S-RM 301 BY ENT
Collected: 10/19/2016
Lab ID: 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.9	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-63
3-S-RM 301 (FACING 3 WINDOWS)
Collected: 10/19/2016
Lab ID: 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

Analytical Results

Client Sample Description CHHS-64
 3-S-RM 301 (FACING DESK) **Collected:** 10/19/2016 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.3	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-65
 3-S-RM 306 L **Collected:** 10/19/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	70.8	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-66
 3-S-RM 306 C **Collected:** 10/19/2016 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	71.9	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-67
 3-S-RM 306 R **Collected:** 10/19/2016 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	108	2.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-68
 3-S-BATH RM (WM) L **Collected:** 10/19/2016 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.20	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-69
 3-S-BATH RM (WM) C **Collected:** 10/19/2016 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.06	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-70
 3-S-BATH RM (WM) R **Collected:** 10/19/2016 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.67	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606967
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School**

Analytical Results

Client Sample Description		CHHS-71 3-S-RM 309 L	Collected:		10/19/2016	Lab ID:		0071
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	110	2.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-72 3-S-RM 309 R	Collected:		10/19/2016	Lab ID:		0072
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	207	4.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-73 3-S-RM 311 #2	Collected:		10/19/2016	Lab ID:		0073
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	201	4.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-74 3-S-RM 311 #3	Collected:		10/19/2016	Lab ID:		0074
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	177	4.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-75 3-S-RM 311 #4	Collected:		10/19/2016	Lab ID:		0075
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	179	4.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-76 3-S-RM 311 #5	Collected:		10/19/2016	Lab ID:		0076
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	218	4.00	µg/L	10/21/2016	JS	10/25/2016	JS
Client Sample Description		CHHS-77 3-S-RM 311 #6	Collected:		10/19/2016	Lab ID:		0077
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	352	10.0	µg/L	10/21/2016	JS	10/25/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School

Analytical Results

Client Sample Description CHHS-78
3-S-RM 311 WASH SINK
Collected: 10/19/2016 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	247	4.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-79
3-S-RM 312 PREP RM
Collected: 10/19/2016 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	133	2.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-80
3-S-RM 312 #1
Collected: 10/19/2016 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	234	4.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-81
3-S-RM 312 #2
Collected: 10/19/2016 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	155	4.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-82
3-S-RM 312 #3
Collected: 10/19/2016 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	203	4.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-83
3-S-RM 312
Collected: 10/19/2016 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	111	2.00	µg/L	10/21/2016	JS	10/25/2016	JS

Client Sample Description CHHS-84
3-S-RM 312 HOSE
Collected: 10/19/2016 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606967

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/20/16 7:45 AM

Project: **Croton-Harmon Schools Lead Testing / 2041420.035.00 / Croton-Harmon High School****Analytical Results**

Client Sample Description CHHS-85
 1-HB-EXT RM 103
Collected: 10/19/2016 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	96.8	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-86
 1-HB-EXT BASEBALL FIELD
Collected: 10/19/2016 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.22	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Client Sample Description CHHS-87
 1-HB-EXT BOILER RM
Collected: 10/19/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	55.1	1.00	µg/L	10/21/2016	JS	10/21/2016	JS

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)