Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-01
Name: 3-4 Hall Fountain Left A
Matrix: Drinking Water

Sampled: 05/24/23 09:20
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 11:57	JMW	EPA 200.8 REV 5.4

Sample: GE05176-02
Name: 3-4 Hall Fountain Left B
Matrix: Drinking Water

Sampled: 05/24/23 09:23
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 11:59	JMW	EPA 200.8 REV 5.4

Sample: GE05176-03
Name: 3-4 Hall Fountain Right A
Matrix: Drinking Water

Sampled: 05/24/23 09:21
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:05	JMW	EPA 200.8 REV 5.4

Sample: GE05176-04
Name: 3-4 Hall Fountain Right B
Matrix: Drinking Water

Sampled: 05/24/23 09:25
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:07	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-05
Name: Library Left A
Matrix: Drinking Water

Sampled: 05/24/23 09:09
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:09	JMW	EPA 200.8 REV 5.4

Sample: GE05176-06
Name: Library Left B
Matrix: Drinking Water

Sampled: 05/24/23 09:10
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:13	JMW	EPA 200.8 REV 5.4

Sample: GE05176-07
Name: Library Right A
Matrix: Drinking Water

Sampled: 05/24/23 09:12
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:15	JMW	EPA 200.8 REV 5.4

Sample: GE05176-08
Name: Library Right B
Matrix: Drinking Water

Sampled: 05/24/23 09:14
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:16	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-09
Name: Nurses Left A
Matrix: Drinking Water
Sampled: 05/24/23 09:00
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:21	JMW	EPA 200.8 REV 5.4

Sample: GE05176-10
Name: Nurses Left B
Matrix: Drinking Water
Sampled: 05/24/23 09:03
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:23	JMW	EPA 200.8 REV 5.4

Sample: GE05176-11
Name: 1-2 Hall Left A
Matrix: Drinking Water
Sampled: 05/25/23 07:15
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:24	JMW	EPA 200.8 REV 5.4

Sample: GE05176-12
Name: 1-2 Hall Left B
Matrix: Drinking Water
Sampled: 05/25/23 07:16
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:26	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-13
Name: 1-2 Hall Right A
Matrix: Drinking Water

Sampled: 05/25/23 07:18
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:27	JMW	EPA 200.8 REV 5.4

Sample: GE05176-14
Name: 1-2 Hall Right B
Matrix: Drinking Water

Sampled: 05/25/23 07:19
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:32	JMW	EPA 200.8 REV 5.4

Sample: GE05176-15
Name: Fema Left A
Matrix: Drinking Water

Sampled: 05/25/23 08:49
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:34	JMW	EPA 200.8 REV 5.4

Sample: GE05176-16
Name: Fema Left B
Matrix: Drinking Water

Sampled: 05/25/23 08:51
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:35	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-17
Name: Fema Right A
Matrix: Drinking Water
Sampled: 05/25/23 08:49
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:40	JMW	EPA 200.8 REV 5.4

Sample: GE05176-18
Name: Fema Right B
Matrix: Drinking Water
Sampled: 05/25/23 08:51
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:41	JMW	EPA 200.8 REV 5.4

Sample: GE05176-19
Name: Adams ECC - A
Matrix: Drinking Water
Sampled: 05/25/23 08:29
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:43	JMW	EPA 200.8 REV 5.4

Sample: GE05176-20
Name: Adams ECC - B
Matrix: Drinking Water
Sampled: 05/25/23 08:30
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:45	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-21
Name: Kinder ECC - A
Matrix: Drinking Water

Sampled: 05/25/23 08:25
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:46	JMW	EPA 200.8 REV 5.4

Sample: GE05176-22
Name: Kinder ECC - B
Matrix: Drinking Water

Sampled: 05/25/23 08:26
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:51	JMW	EPA 200.8 REV 5.4

Sample: GE05176-23
Name: Chowning ECC - A
Matrix: Drinking Water

Sampled: 05/25/23 08:32
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:52	JMW	EPA 200.8 REV 5.4

Sample: GE05176-24
Name: Chowning ECC - B
Matrix: Drinking Water

Sampled: 05/25/23 08:33
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:54	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-25
Name: Wiggs ECC - A
Matrix: Drinking Water

Sampled: 05/25/23 08:21
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:55	JMW	EPA 200.8 REV 5.4

Sample: GE05176-26
Name: Wiggs ECC - B
Matrix: Drinking Water

Sampled: 05/25/23 08:22
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:57	JMW	EPA 200.8 REV 5.4

Sample: GE05176-27
Name: Inside Fema A
Matrix: Drinking Water

Sampled: 05/25/23 08:53
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 12:59	JMW	EPA 200.8 REV 5.4

Sample: GE05176-28
Name: Inside Fema B
Matrix: Drinking Water

Sampled: 05/25/23 08:54
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:00	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-29
Name: Kit. DW A
Matrix: Drinking Water

Sampled: 05/25/23 09:00
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	19.6	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:02	JMW	EPA 200.8 REV 5.4

Sample: GE05176-30
Name: Kit. DW B
Matrix: Drinking Water

Sampled: 05/25/23 09:02
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.72	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:03	JMW	EPA 200.8 REV 5.4

Sample: GE05176-31
Name: Kit. West A
Matrix: Drinking Water

Sampled: 05/25/23 09:05
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.41	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:05	JMW	EPA 200.8 REV 5.4

Sample: GE05176-32
Name: Kit. West B
Matrix: Drinking Water

Sampled: 05/25/23 09:07
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:10	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-33
Name: Kit. North Left A
Matrix: Drinking Water

Sampled: 05/25/23 09:10
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	5.79	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:13	JMW	EPA 200.8 REV 5.4

Sample: GE05176-34
Name: Kit. North Left B
Matrix: Drinking Water

Sampled: 05/25/23 09:12
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:14	JMW	EPA 200.8 REV 5.4

Sample: GE05176-35
Name: Kit. North Right A
Matrix: Drinking Water

Sampled: 05/25/23 09:15
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:16	JMW	EPA 200.8 REV 5.4

Sample: GE05176-36
Name: Kit. North Right B
Matrix: Drinking Water

Sampled: 05/25/23 09:18
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:18	JMW	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: GE05176-37
Name: Nurses Right A
Matrix: Drinking Water

Sampled: 05/24/23 00:00
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:19	JMW	EPA 200.8 REV 5.4

Sample: GE05176-38
Name: Nurses Right B
Matrix: Drinking Water

Sampled: 05/24/23 00:00
Received: 05/30/23 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		06/08/23 12:06	1	1.00	06/09/23 13:21	JMW	EPA 200.8 REV 5.4