



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410  
PH (973) 636-9145 FAX (973) 636-9144  
Email: [Envirovision@optonline.net](mailto:Envirovision@optonline.net)

CLIENT: Tenafly Public Schools Project Number 21-217  
PROJECT: Lead in Drinking Water Maugham Elementary School  
ADDRESS: 111 Magnolia Avenue, Tenafly, NJ 07670 Report Date: May 5, 2022  
Field Technician: Leonardo Bitondo

As per your request, EnviroVision Consultants, Inc. was contracted by Tenafly School District to conduct Lead (Pb) in drinking water sampling at the Maugham Elementary School on April 14, 2022. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The sample was analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Five samples were collected from the Maugham Elementary School. All of the samples analyzed were either "None Detected" or less than the US EPA threshold for Lead in drinking water. In addition, a required blank was collected for Quality Assurance purposes.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,  
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, associated data sheets

