

## Westview High School

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen - Dish	22434200-001KF23A	6/20/2023	1.89
Kitchen - Pot Filler	22434200-002KF23A	6/20/2023	1.84
Kitchen - Center Sink	22434200-003KF23A	6/20/2023	4.54
Kitchen - E Sink	22434200-004KF23A	6/20/2023	2.21
Food Serv. - S Sink	22434200-005KF23A	6/20/2023	7.35
Food Serv. - N Sink	22434200-006KF23A	6/20/2023	6.59
Staff Dining - E Sink	22434200-007WB23A	6/20/2023	2.72
Staff Dining	22434200-008SF23A	6/20/2023	1.39
Student Center - SE	22434200-009WB23A	6/20/2023	0.234
Student Center - SE	22434200-010DW23A	6/20/2023	0.223
Concession	22434200-011KF23A	6/20/2023	4.63
S143	22434200-012SF23A	6/20/2023	14.5
S145	22434200-013CF23A	6/20/2023	3.54
Gym Hall - Left	22434200-014DW23A	6/20/2023	0.812
Gym Hall - Right	22434200-015DW23A	6/20/2023	0.618
S141 - Left	22434200-016CF23A	6/20/2023	2.89
S141 - Right	22434200-017CF23A	6/20/2023	1.03
S134 - Move Clockwise from Door, Starting on Left Hand Side	22434200-018KF23A	6/20/2023	0.398
S134 - as above	22434200-019KF23A	6/20/2023	0.61
S134 - as above	22434200-020KF23A	6/20/2023	1.46
S134 - as above	22434200-021KF23A	6/20/2023	0.52
S134 - as above	22434200-022KF23A	6/20/2023	0.547
S134 - as above	22434200-023KF23A	6/20/2023	1.22
S134 - as above	22434200-024KF23A	6/20/2023	0.446
S134 - Pot Filler	22434200-025KF23A	6/20/2023	0.259
S131	22434200-026CF23A	6/20/2023	1.57
SW Hall	22434200-027DW23A	6/20/2023	7.34
S111	22434200-028SF23A	6/20/2023	2.58
Outside Room 104	22434200-029SF23A	6/20/2023	0.56
Workroom	22434200-030SF23A	6/20/2023	4.16
103B	22434200-031NS23A	6/20/2023	4.41
Office Hall	22434200-032SF23A	6/20/2023	0.594
N111	22434200-033SF23A	6/20/2023	0.805
NW Hall	22434200-034DW23A	6/20/2023	0.366
Hall Outside Admin N Side - Left	22434200-035DW23A	6/20/2023	ND
Hall Outside Admin N Side - Right	22434200-036DW23A	6/20/2023	ND
Hall Outside Admin N Side	22434200-037WB23A	6/20/2023	ND
Student Center NE	22434200-038DW23A	6/20/2023	1.38
N140	22434200-039CF23A	6/20/2023	1.07
Student Store	22434200-040KF23A	6/20/2023	0.739
Auditorium Hall	22434200-041WB23A	6/20/2023	ND
Auditorium Hall - Left	22434200-042DW23A	6/20/2023	ND
Auditorium Hall - Right	22434200-043DW23A	6/20/2023	1.21
N138	22434200-044CF23A	6/20/2023	1.97
Dressing Room - Left	22434200-045DW23A	6/20/2023	0.27
Dressing Room - Right	22434200-046DW23A	6/20/2023	0.243
S153	22434200-047DW23A	6/20/2023	3.12
Gym 2nd Floor	22434200-048DW23A	6/20/2023	0.564
Outside Mat/Gym	22434200-049DW23A	6/20/2023	0.54
S151	22434200-050DW23A	6/20/2023	0.898
S150	22434200-051DW23A	6/20/2023	1.68

Main Gym Lobby (1st Floor) - Left	22434200-052DW23A	6/20/2023	ND
Main Gym Lobby (1st Floor) - Right	22434200-053DW23A	6/20/2023	0.515
Gym 1st Floor West Fountain	22434200-054DW23A	6/20/2023	0.668
Gym 1st Floor East Fountain	22434200-055DW23A	6/20/2023	0.683
Boys Locker - North Sink	22434200-056DW23A	6/20/2023	0.719
Boys Locker - South Sink	22434200-057DW23A	6/20/2023	0.351
Room 30	22434200-058CF23A	6/20/2023	0.551
Girls Locker - North Sink	22434200-059DW23A	6/20/2023	ND
Girls Locker - South Sink	22434200-060DW23A	6/20/2023	ND
2nd Floor Outside N230 - Left	22434200-061DW23A	6/20/2023	0.425
2nd Floor Outside N230 - Right	22434200-062DW23A	6/20/2023	ND
N211	22434200-063SF23A	6/20/2023	0.482
2nd Floor North Hall	22434200-064DW23A	6/20/2023	ND
S223	22434200-065CF23A	6/20/2023	1.09
Outside S230 - Left	22434200-066DW23A	6/20/2023	1.32
Outside S230 - Right	22434200-067DW23A	6/20/2023	0.26
2nd Floor South Hall	22434200-068DW23A	6/20/2023	1.43
S211	22434200-069SF23A	6/20/2023	2.38
Library Office	22434200-070SF23A	6/20/2023	0.77