

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 11:57 PM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-001**

**Client Sample ID. : CITY WATER SUPPLY-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 43	*	1	ug/L	15	07/13/2016 1:48 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:11 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-002**

**Client Sample ID. : ROOM A15 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.3		1	ug/L	15	07/13/2016 1:51 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:12 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-003**

**Client Sample ID. : ROOM A15 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.6		1	ug/L	15	07/13/2016 1:54 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:09 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-004**

**Client Sample ID. : ROOM A15 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 1:57 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:10 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-005**

**Client Sample ID. : ROOM A15 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 2:00 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:10 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-006**

**Client Sample ID. : ROOM A15 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 2:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:13 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-007**

**Client Sample ID. : ROOM A18 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.5		1	ug/L	15	07/13/2016 2:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-008**

**Client Sample ID. : ROOM A18 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9		1	ug/L	15	07/13/2016 2:23 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:15 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-009**

**Client Sample ID. : ROOM A18 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	07/13/2016 2:26 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:17 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-010**

**Client Sample ID. : ROOM A18 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 2:29 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:19 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-011**

**Client Sample ID. : ROOM A18 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 2:32 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:21 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-012**

**Client Sample ID. : ROOM A13 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.5		1	ug/L	15	07/13/2016 2:35 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:22 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-013**

**Client Sample ID. : ROOM A13 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.3		1	ug/L	15	07/13/2016 2:38 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:23 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-014**

**Client Sample ID. : ROOM A13 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.7		1	ug/L	15	07/13/2016 2:40 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:25 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-015**

**Client Sample ID. : ROOM A13 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.2		1	ug/L	15	07/13/2016 2:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-016**

**Client Sample ID. : ROOM A13 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	07/13/2016 2:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:29 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-017**

**Client Sample ID. : ROOM A16 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 3:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:30 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-018**

**Client Sample ID. : ROOM A16 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 3:04 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:31 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-019**

**Client Sample ID. : ROOM A16 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.8		1	ug/L	15	07/13/2016 3:07 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:33 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-020**

**Client Sample ID. : ROOM A16 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 3:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:34 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-021**

**Client Sample ID. : ROOM A16 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	07/13/2016 3:13 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:36 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-022**

**Client Sample ID. : ROOM A14 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 3:15 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:39 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-023**

**Client Sample ID. : ROOM A14 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.7		1	ug/L	15	07/13/2016 3:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:42 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-024**

**Client Sample ID. : ROOM A14 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	07/13/2016 3:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:43 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-025**

**Client Sample ID. : ROOM A14 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	07/13/2016 3:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:46 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-026**

**Client Sample ID. : ROOM A11 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	07/13/2016 3:39 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:47 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-027**

**Client Sample ID. : ROOM A11 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.0		1	ug/L	15	07/13/2016 3:42 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-028**

**Client Sample ID. : ROOM A11 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.8		1	ug/L	15	07/13/2016 3:45 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:50 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-029**

**Client Sample ID. : ROOM A11 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	07/13/2016 3:48 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:51 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-030**

**Client Sample ID. : ROOM A11 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	07/13/2016 3:50 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:53 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-031**

**Client Sample ID. : AWING / MENS FACULTY BATHROOM /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.3		1	ug/L	15	07/13/2016 3:53 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:55 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-032**

**Client Sample ID. : AWING / MENS FACULTY BATHROOM /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	07/13/2016 4:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:56 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-033**

**Client Sample ID. : AWING / LADIES FACULTY BATHROOM /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.2		1	ug/L	15	07/13/2016 4:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:57 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-034**

**Client Sample ID. : AWING / LADIES FACULTY BATHROOM /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	07/13/2016 4:14 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 12:59 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-035**

**Client Sample ID. : ROOM A12 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 71	*	1	ug/L	15	07/13/2016 4:17 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:00 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-036**

**Client Sample ID. : ROOM A12 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 72	*	1	ug/L	15	07/13/2016 4:20 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-037**

**Client Sample ID. : ROOM A12 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.3		1	ug/L	15	07/13/2016 4:23 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-038**

**Client Sample ID. : ROOM A12 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.2		1	ug/L	15	07/13/2016 4:26 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-039**

**Client Sample ID. : ROOM A12 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.8		1	ug/L	15	07/13/2016 4:28 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-040**

**Client Sample ID. : ROOM A9 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 4:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:08 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-041**

**Client Sample ID. : ROOM A9 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	07/13/2016 4:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:09 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-042**

**Client Sample ID. : ROOM A9 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 4:49 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:11 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-043**

**Client Sample ID. : ROOM A9 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.5		1	ug/L	15	07/13/2016 4:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:12 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-044**

**Client Sample ID. : ROOM A9 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	07/13/2016 4:55 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-045**

**Client Sample ID. : ROOM A7 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	07/13/2016 4:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:15 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-046**

**Client Sample ID. : ROOM A7 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	07/13/2016 5:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:16 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-047**

**Client Sample ID. : ROOM A7 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.7		1	ug/L	15	07/13/2016 5:04 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:18 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-048**

**Client Sample ID. : ROOM A7 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.3		1	ug/L	15	07/13/2016 5:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:20 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-049**

**Client Sample ID. : ROOM A7 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	07/13/2016 5:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:23 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-050**

**Client Sample ID. : ROOM A10 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	07/13/2016 5:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:24 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-051**

**Client Sample ID. : ROOM A10 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 5:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:25 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-052**

**Client Sample ID. : ROOM A10 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.2		1	ug/L	15	07/13/2016 5:30 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-053**

**Client Sample ID. : ROOM A10 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	07/13/2016 5:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-054**

**Client Sample ID. : ROOM A10 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	07/13/2016 5:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:28 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-055**

**Client Sample ID. : ROOM A5 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 48	*M-	1	ug/L	15	07/13/2016 5:39 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:30 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-056**

**Client Sample ID. : ROOM A5 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	07/13/2016 5:53 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:31 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-057**

**Client Sample ID. : ROOM A5 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 5:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:33 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-058**

**Client Sample ID. : ROOM A5 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 5:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:34 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-059**

**Client Sample ID. : ROOM A5 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 6:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:37 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-060**

**Client Sample ID. : ROOM A8 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 36	*	1	ug/L	15	07/13/2016 6:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:38 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-061**

**Client Sample ID. : ROOM A8 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	07/13/2016 6:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:39 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-062**

**Client Sample ID. : ROOM A8 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.7		1	ug/L	15	07/13/2016 6:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:41 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-063**

**Client Sample ID. : ROOM A8 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.9		1	ug/L	15	07/13/2016 6:14 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:45 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-064**

**Client Sample ID. : ROOM A3 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 32	*	1	ug/L	15	07/13/2016 6:28 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:47 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-065**

**Client Sample ID. : ROOM A3 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	07/13/2016 6:31 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-066**

**Client Sample ID. : ROOM A3 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	07/13/2016 6:34 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:50 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-067**

**Client Sample ID. : ROOM A3 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 6:37 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:51 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-068**

**Client Sample ID. : ROOM A3 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 6:40 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
unless otherwise noted.

This report shall not be reproduced except in full,  
without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:54 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-069**

**Client Sample ID. : ROOM A1 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.1		1	ug/L	15	07/13/2016 6:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:55 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-070**

**Client Sample ID. : ROOM A1 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	07/13/2016 6:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:56 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-071**

**Client Sample ID. : ROOM A1 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	10		1	ug/L	15	07/13/2016 6:49 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 1:58 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-072**

**Client Sample ID. : ROOM A1 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.5		1	ug/L	15	07/13/2016 7:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
unless otherwise noted.

This report shall not be reproduced except in full,  
without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:00 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-073**

**Client Sample ID. : ROOM A1 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	07/13/2016 7:06 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-074**

**Client Sample ID. : ROOM A6 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	07/13/2016 7:09 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-075**

**Client Sample ID. : ROOM A6 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 15	*	1	ug/L	15	07/13/2016 7:12 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:05 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-076**

**Client Sample ID. : ROOM A6 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 16	*	1	ug/L	15	07/13/2016 7:15 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:06 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-077**

**Client Sample ID. : ROOM A6 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.9		1	ug/L	15	07/13/2016 7:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-078**

**Client Sample ID. : ROOM A6 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 7:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:11 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-079**

**Client Sample ID. : ROOM A4 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 23	*M+	1	ug/L	15	07/13/2016 7:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:12 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-080**

**Client Sample ID. : ROOM A4 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.3		1	ug/L	15	07/13/2016 12:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-081**

**Client Sample ID. : ROOM A4 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	07/13/2016 12:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:15 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-082**

**Client Sample ID. : ROOM A4 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.8		1	ug/L	15	07/13/2016 12:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:16 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-083**

**Client Sample ID. : ROOM A4 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.5		1	ug/L	15	07/13/2016 12:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:24 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-084**

**Client Sample ID. : MEDIA CENTER / BATHROOM SINK / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 30	*	1	ug/L	15	07/13/2016 12:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:25 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-085**

**Client Sample ID. : MEDIA CENTER / BATHROOM SINK / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	07/13/2016 12:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:27 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-086**

**Client Sample ID. : ROOM A2 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 56	*	1	ug/L	15	07/13/2016 12:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:28 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-087**

**Client Sample ID. : ROOM A2 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 20	*	1	ug/L	15	07/13/2016 12:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:30 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-088**

**Client Sample ID. : ROOM A2 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 20	*	1	ug/L	15	07/13/2016 1:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:33 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-089**

**Client Sample ID. : ROOM A2 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.4		1	ug/L	15	07/13/2016 1:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:34 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-090**

**Client Sample ID. : ROOM A2 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 1:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:36 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-091**

**Client Sample ID. : ROOM B8 / NURSES OFFICE /  
 BATHROOM SINK / CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	07/13/2016 1:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:38 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-092**

**Client Sample ID. : ROOM B8 / NURSES OFFICE /  
 BATHROOM SINK / HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 1:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:40 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-093**

**Client Sample ID. : ROOM B8 / NURSES OFFICE SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.8		1	ug/L	15	07/13/2016 1:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:41 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-094**

**Client Sample ID. : ROOM B8 / NURSES OFFICE SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.3		1	ug/L	15	07/13/2016 1:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:44 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-095**

**Client Sample ID. : ROOM B7 / MAIN OFFICE BATHROOM**  
**SINK / CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	07/13/2016 1:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:45 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-096**

**Client Sample ID. : ROOM B7 / MAIN OFFICE BATHROOM**  
**SINK / HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.7		1	ug/L	15	07/13/2016 1:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-097**

**Client Sample ID. : ROOM C15 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	07/13/2016 1:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-098**

**Client Sample ID. : ROOM C15 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.1		1	ug/L	15	07/13/2016 1:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:51 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-099**

**Client Sample ID. : ROOM D1.5 / FAMILY BATHROOM / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	07/13/2016 1:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:52 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-100**

**Client Sample ID. : ROOM D1.5 / FAMILY BATHROOM / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	07/13/2016 1:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:57 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-101**

**Client Sample ID. : ROOM D3 / HANDSINK BY 3 BAY / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.1		1	ug/L	15	07/13/2016 1:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 2:58 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-102**

**Client Sample ID. : ROOM D3 / HANDSINK BY 3 BAY / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	07/13/2016 2:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:00 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-103**

**Client Sample ID. : ROOM D3 / 3 BAY SINK #1 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	15	M+	1	ug/L	15	07/13/2016 2:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:01 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-104**

**Client Sample ID. : ROOM D3 / 3 BAY SINK #1 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.6		1	ug/L	15	07/13/2016 2:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-105**

**Client Sample ID. : ROOM D3 / 3 BAY SINK #2 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	07/13/2016 2:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-106**

**Client Sample ID. : ROOM D3 / 3 BAY SINK #2 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 2:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:06 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-107**

**Client Sample ID. : ROOM D3 / STEAMER / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	07/13/2016 2:27 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-108**

**Client Sample ID. : ROOM D3 / STEAMER / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 2:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:09 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-109**

**Client Sample ID. : ROOM D3 / SERVING LINKE SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 290	*	1	ug/L	15	07/13/2016 2:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:10 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-110**

**Client Sample ID. : ROOM D3 / SERVING LINKE SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	07/13/2016 2:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:13 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-111**

**Client Sample ID. : ROOM D4 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.8		1	ug/L	15	07/13/2016 2:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-112**

**Client Sample ID. : ROOM D4 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.8		1	ug/L	15	07/13/2016 2:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:16 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-113**

**Client Sample ID. : ROOM D7 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 20	*	1	ug/L	15	07/13/2016 2:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:17 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-114**

**Client Sample ID. : ROOM D7 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 2:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:19 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-115**

**Client Sample ID. : D19 / HALLWAY DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	07/13/2016 3:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:23 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-116**

**Client Sample ID. : D20 / HALLWAY DF #1-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 3:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:24 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-117**

**Client Sample ID. : D20 / HALLWAY DF #2-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 3:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:29 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-118**

**Client Sample ID. : ROOM D8 / GIRLS ROOM CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 35	*	1	ug/L	15	07/13/2016 3:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-119**

**Client Sample ID. : ROOM D8 / BOYS ROOM CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 44	*	1	ug/L	15	07/13/2016 3:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:36 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-120**

**Client Sample ID. : ROOM D8 / OFFICE BATHROOM SINK /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.0		1	ug/L	15	07/13/2016 3:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:37 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-121**

**Client Sample ID. : ROOM D8 / OFFICE BATHROOM SINK /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	07/13/2016 3:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:39 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-122**

**Client Sample ID. : ROOM D9 / LOCKER ROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	07/13/2016 3:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:41 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-123**

**Client Sample ID. : ROOM D9 / LOCKER ROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9		1	ug/L	15	07/13/2016 3:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:44 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-124**

**Client Sample ID. : ROOM D14 / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	07/13/2016 3:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:44 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-125**

**Client Sample ID. : ROOM D14 / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	07/13/2016 3:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:47 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-126**

**Client Sample ID. : ROOM D13 / LOCKER ROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	07/13/2016 3:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-127**

**Client Sample ID. : ROOM D13 / LOCKER ROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9		1	ug/L	15	07/13/2016 3:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:52 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-128**

**Client Sample ID. : CELC / CORRIDOR DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:55 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-129**

**Client Sample ID. : CELC / PRE K / BATHROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	07/13/2016 4:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:56 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-130**

**Client Sample ID. : CELC / PRE K / BATHROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	07/13/2016 4:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:58 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-131**

**Client Sample ID. : CELC / PRE K / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 3:59 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-132**

**Client Sample ID. : CELC / PRE K / CLASSROOM SINK / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:00 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-133**

**Client Sample ID. : CELC / PRE K / CLASSROOM SINK / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-134**

**Client Sample ID. : CELC / PRE SCHOOL / BATHROOM SINK**  
**/ CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 4:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-135**

**Client Sample ID. : CELC / PRE SCHOOL / BATHROOM SINK  
 / HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	07/13/2016 4:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:05 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-136**

**Client Sample ID. : CELC / PRE SCHOOL / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-137**

**Client Sample ID. : CELC / PRE SCHOOL / CLASSROOM**  
**SINK / CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:08 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-138**

**Client Sample ID. : CELC / PRE SCHOOL / CLASSROOM**  
**SINK / HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/13/2016 4:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:15 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-139**

**Client Sample ID. : CELC / TODDLER #1 / CLASSROOM**  
**SINK / CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 4:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:16 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-140**

**Client Sample ID. : CELC / TODDLER #1 / CLASSROOM**  
**SINK / HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	07/13/2016 4:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:13 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-141**

**Client Sample ID. : CELC / TODDLER #1 / BATHROOM SINK /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	07/13/2016 4:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-142**

**Client Sample ID. : CELC / TODDLER #1 / BATHROOM SINK /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	07/13/2016 4:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:23 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-143**

**Client Sample ID. : CELC / TODDLER #2 / CLASSROOM**  
**SINK / CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	07/13/2016 5:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:24 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-144**

**Client Sample ID. : CELC / TODDLER #2 / CLASSROOM**  
**SINK / HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.0		1	ug/L	15	07/13/2016 6:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:20 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-145**

**Client Sample ID. : CELC / TODDLER #2 / BATHROOM SINK /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 6:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:21 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-146**

**Client Sample ID. : CELC / TODDLER #2 / BATHROOM SINK /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	07/13/2016 6:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:25 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-147**

**Client Sample ID. : CELC / UTILITY SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 6:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-148**

**Client Sample ID. : CELC / UTILITY SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	07/13/2016 6:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:31 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-149**

**Client Sample ID. : ROOM D10.5 / OUTSIDE BATHROOM /  
 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 6:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:32 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-150**

**Client Sample ID. : ROOM D10.5 / OUTSIDE BATHROOM /  
 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 6:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To :** Brad Preston

Federal ID :

Collected : 06/25/2016 4:37 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-151**

**Client Sample ID. : C16 / DF BETWEEN BOYS & GIRLS**  
**ROOM-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/13/2016 6:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:41 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-152**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #1 / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.1		1	ug/L	15	07/13/2016 6:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:44 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-153**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #1 / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	07/13/2016 6:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:43 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-154**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #2 / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.5		1	ug/L	15	07/13/2016 6:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:46 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-155**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #2 / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.5		1	ug/L	15	07/13/2016 6:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:47 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-156**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #3 / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	07/13/2016 6:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-157**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #3 / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.5		1	ug/L	15	07/13/2016 6:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:49 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-158**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #4 / CW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.2		1	ug/L	15	07/13/2016 7:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:50 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-159**

**Client Sample ID. : ROOM C10 / CLASSROOM SINK #4 / HW-  
 R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 7:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:57 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-160**

**Client Sample ID. : BETWEEN C12 & C1 / BOYS BATHROOM**  
**SINK # 1 CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	07/13/2016 7:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:58 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-161**

**Client Sample ID. : BETWEEN C12 & C1 / BOYS BATHROOM**  
**SINK # 1 HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	07/13/2016 7:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:00 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-162**

**Client Sample ID. : BETWEEN C12 & C1 / BOYS BATHROOM**  
**SINK # 2 CW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	07/13/2016 7:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:01 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-163**

**Client Sample ID. : BETWEEN C12 & C1 / BOYS BATHROOM**  
**SINK # 2 HW-R**  
**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.7		1	ug/L	15	07/13/2016 7:27 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-164**

**Client Sample ID. : BETWEEN C12 & C1 / GIRLS  
 BATHROOM SINK # 1 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.4		1	ug/L	15	07/13/2016 7:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:06 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-165**

**Client Sample ID. : BETWEEN C12 & C1 / GIRLS  
 BATHROOM SINK # 1 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.2		1	ug/L	15	07/13/2016 7:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-166**

**Client Sample ID. : BETWEEN C12 & C1 / GIRLS  
 BATHROOM SINK # 2 CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 7:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:08 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-167**

**Client Sample ID. : BETWEEN C12 & C1 / GIRLS  
 BATHROOM SINK # 2 HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	07/13/2016 7:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:11 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-168**

**Client Sample ID. : ROOM C4 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	07/13/2016 7:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:12 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-169**

**Client Sample ID. : ROOM C4 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 41	*	1	ug/L	15	07/13/2016 7:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-170**

**Client Sample ID. : ROOM C4 / CLASSROOM DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.0		1	ug/L	15	07/13/2016 8:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:17 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-171**

**Client Sample ID. : ROOM C1 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.0		1	ug/L	15	07/13/2016 8:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:16 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-172**

**Client Sample ID. : ROOM C1 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.0		1	ug/L	15	07/13/2016 8:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:26 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-173**

**Client Sample ID. : ROOM C3 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.8		1	ug/L	15	07/13/2016 8:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:28 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-174**

**Client Sample ID. : ROOM C3 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	07/13/2016 8:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:22 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-175**

**Client Sample ID. : ROOM C3 / CLASSROOM DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.3		1	ug/L	15	07/13/2016 8:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:38 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-176**

**Client Sample ID. : ROOM C5 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.9		1	ug/L	15	07/13/2016 8:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:39 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-177**

**Client Sample ID. : ROOM C5 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.2		1	ug/L	15	07/13/2016 8:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:36 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-178**

**Client Sample ID. : ROOM C5 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.9		1	ug/L	15	07/13/2016 8:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:20 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-179**

**Client Sample ID. : ROOM C6 / CLASSROOM SINK CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	07/13/2016 8:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:33 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-180**

**Client Sample ID. : ROOM C8 / CLASSROOM SINK CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	07/13/2016 8:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:34 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-181**

**Client Sample ID. : ROOM C8 / CLASSROOM SINK HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	07/13/2016 8:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:35 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-182**

**Client Sample ID. : ROOM C8 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	07/13/2016 8:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:46 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-183**

**Client Sample ID. : ROOM 201 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.8		1	ug/L	15	07/13/2016 8:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:47 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-184**

**Client Sample ID. : ROOM 201 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 9:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:51 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-185**

**Client Sample ID. : ROOM 202 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.0		1	ug/L	15	07/13/2016 9:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:52 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-186**

**Client Sample ID. : ROOM 202 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	07/13/2016 9:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:54 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-187**

**Client Sample ID. : ROOM 202 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.0		1	ug/L	15	07/13/2016 9:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:15 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-188**

**Client Sample ID. : ROOM 203 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.8		1	ug/L	15	07/13/2016 9:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:21 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-189**

**Client Sample ID. : ROOM 204 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 9:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:24 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-190**

**Client Sample ID. : ROOM 204 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	07/13/2016 9:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:20 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-191**

**Client Sample ID. : ROOM 204 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	07/13/2016 9:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:37 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-192**

**Client Sample ID. : ROOM 205 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.0		1	ug/L	15	07/13/2016 9:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:37 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-193**

**Client Sample ID. : ROOM 205 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	07/13/2016 9:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:30 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-194**

**Client Sample ID. : ROOM 205 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.0		1	ug/L	15	07/13/2016 9:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:43 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-195**

**Client Sample ID. : ROOM 206 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.8		1	ug/L	15	07/13/2016 9:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:44 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-196**

**Client Sample ID. : ROOM 206 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	07/13/2016 9:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:41 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-197**

**Client Sample ID. : ROOM 206 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	07/13/2016 9:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:27 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-198**

**Client Sample ID. : ROOM 207 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.5		1	ug/L	15	07/13/2016 10:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:28 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-199**

**Client Sample ID. : ROOM 207 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 16	*	1	ug/L	15	07/13/2016 10:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:25 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-200**

**Client Sample ID. : ROOM 207 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	07/13/2016 10:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:35 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-201**

**Client Sample ID. : ROOM 208 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 10:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:36 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-202**

**Client Sample ID. : ROOM 208 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	07/13/2016 10:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:46 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-203**

**Client Sample ID. : ROOM 209 / CLASSROOM SINK / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.1		1	ug/L	15	07/13/2016 10:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:48 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-204**

**Client Sample ID. : ROOM 209 / CLASSROOM SINK / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 31	*	1	ug/L	15	07/13/2016 10:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:45 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-205**

**Client Sample ID. : ROOM 209 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.0		1	ug/L	15	07/13/2016 10:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:07 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-206**

**Client Sample ID. : ROOM 215 / DF-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.1		1	ug/L	15	07/13/2016 10:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:03 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-207**

**Client Sample ID. : ROOM 211 / BATHROOM SINK #1 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.4		1	ug/L	15	07/13/2016 10:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:04 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-208**

**Client Sample ID. : ROOM 211 / BATHROOM SINK #1 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	07/13/2016 10:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:05 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-209**

**Client Sample ID. : ROOM 211 / BATHROOM SINK #2 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.2		1	ug/L	15	07/13/2016 10:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:06 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-210**

**Client Sample ID. : ROOM 211 / BATHROOM SINK #2 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.0		1	ug/L	15	07/13/2016 11:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:09 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-211**

**Client Sample ID. : ROOM 212 / BATHROOM SINK #1 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 51	*	1	ug/L	15	07/13/2016 11:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:11 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-212**

**Client Sample ID. : ROOM 212 / BATHROOM SINK #1 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.4		1	ug/L	15	07/13/2016 11:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:13 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-213**

**Client Sample ID. : ROOM 212 / BATHROOM SINK #2 / CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.9		1	ug/L	15	07/13/2016 10:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 6:14 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-214**

**Client Sample ID. : ROOM 212 / BATHROOM SINK #2 / HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.3		1	ug/L	15	07/13/2016 11:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:58 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-215**

**Client Sample ID. : 2ND FLOOR / TEACHERS LOUNGE /  
 BATH SINK / CW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.9		1	ug/L	15	07/13/2016 11:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 5:59 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-216**

**Client Sample ID. : 2ND FLOOR / TEACHERS LOUNGE /  
 BATH SINK / HW-R  
 ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	07/13/2016 11:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC  
 unless otherwise noted.

This report shall not be reproduced except in full,  
 without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:45 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-217**

**Client Sample ID. : ROOM C2/CLASSROOM SINK/CW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/13/2016 11:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**Sample Information:**

Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Clinton Central School District**  
**75 Chenango Ave.**

**Clinton, NY 13323**

**Attn To : Brad Preston**

Federal ID :

Collected : 06/25/2016 4:55 AM Point No

Received : 06/29/2016 10:40 AM Location:

Collected By : CLIENT

**Lab No. : 1606S22-218**

**Client Sample ID. : ROOM C2/CLASSROOM SINK/HW-R**

**ELEMENTARY SCHOOL**

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	07/13/2016 11:34 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/14/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL  
575 Broad Hollow Road  
Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
Website: [www.pacelabs.com](http://www.pacelabs.com)

## QC SUMMARY REPORT

WO#: 1606S22

14-Jul-16

**Client:** Clinton Central School District  
**Project:** Clinton Central School District

**BatchID:** R101605

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L	Prep Date:			RunNo: 101605		
Client ID:	PBW	Batch ID: R101605	TestNo: E200.8			Analysis Date: 7/13/2016			SeqNo: 2238834			
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0	1.0									

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit	
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits	
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified		



PACE ANALYTICAL  
575 Broad Hollow Road  
Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
Website: [www.pacelabs.com](http://www.pacelabs.com)

## QC SUMMARY REPORT

WO#: 1606S22

14-Jul-16

**Client:** Clinton Central School District  
**Project:** Clinton Central School District

**BatchID:** R101671

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L	Prep Date:			RunNo: 101671		
Client ID:	PBW	Batch ID: R101671	TestNo: E200.8			Analysis Date: 7/13/2016			SeqNo: 2240442			
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0	1.0									

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit	
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits	
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified		



PACE ANALYTICAL  
575 Broad Hollow Road  
Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
Website: [www.pacelabs.com](http://www.pacelabs.com)

## QC SUMMARY REPORT

WO#: 1606S22

14-Jul-16

**Client:** Clinton Central School District  
**Project:** Clinton Central School District

**BatchID:** R101682

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L	Prep Date:			RunNo: 101682		
Client ID:	PBW	Batch ID: R101682	TestNo: E200.8			Analysis Date: 7/13/2016			SeqNo: 2240697			
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0	1.0									

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit	
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits	
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified		



PACE ANALYTICAL  
575 Broad Hollow Road  
Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
Website: [www.pacelabs.com](http://www.pacelabs.com)

## Sample Receipt Checklist

Client Name **CLINTON**

Date and Time Received: **6/29/2016 10:40:00 AM**

Work Order Number: **1606S22**

RcptNo: **1**

Received by **George Cappadona**

Completed by:

*George A. Cappadona*

Reviewed by:

*Elizabeth Harrison*

Completed Date: 6/29/2016 2:45:51 PM

Reviewed Date: 7/5/2016 8:30:07 AM

Carrier name: FedEx

Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Are matrices correctly identified on Chain of custody?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Is it clear what analyses were requested?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody seals intact on sample bottles?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	Not Present <input checked="" type="checkbox"/>	
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were correct preservatives used and noted?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
Preservative added to bottles:				
Sample Condition?	Intact <input checked="" type="checkbox"/>	Broken <input type="checkbox"/>	Leaking <input type="checkbox"/>	
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were container labels complete (ID, Pres, Date)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Was an attempt made to cool the samples?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
All samples received at a temp. of > 0° C to 6.0° C?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Response when temperature is outside of range:				
Sample Temp. taken and recorded upon receipt?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	To ° <input type="checkbox"/>	
Water - Were bubbles absent in VOC vials?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No Vials <input checked="" type="checkbox"/>	
Water - Was there Chlorine Present?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	No Water <input type="checkbox"/>	
Are Samples considered acceptable?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody Seals present?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>		
Airbill or Sticker?	Air Bil <input checked="" type="checkbox"/>	Sticker <input type="checkbox"/>	Not Present <input type="checkbox"/>	
Airbill No:	7766-2707-0790			

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? ☐ Yes ☐ No ☒ NA Person Contacted:  
Contact Mode: ☐ Phone: ☐ Fax: ☐ Email: ☐ In Person:  
Client Instructions:  
Date Contacted: Contacted By:  
Regarding:  
Comments:  
CorrectiveAction:

WorkOrder :  
1606S22

## Certifications

---

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MASSACHUSETTS	MINY026
NEW HAMPSHIRE	2987
RHODE ISLAND	LAO00340
PENNSYLVANIA	68-00350