



Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.

Clinton, NY 13323

Attn To : Brad Preston

Federal ID :

Collected : 06/24/2016 12:04 AM Point No

Received : 06/30/2016 4:55 PM Location:

Collected By : JM03

Lab No. : 1606T84-001

Client Sample ID. : METER ROOM / 1ST FLOOR / F

MIDDLE SCHOOL

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	07/19/2016 8:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.
Clinton, NY 13323

Lab No. : 1606T84-007
Client Sample ID. : ROOM 206 / SINK #1 / HW-F

Attn To : Brad Preston
 Federal ID :
 Collected : 06/24/2016 12:19 AM Point No
 Received : 06/30/2016 4:55 PM Location:
 Collected By : JM03

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> CM <u>Container:</u>
Lead	9.3		1	ug/L	15	07/19/2016 8:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.
Clinton, NY 13323

Lab No. : 1606T84-009
Client Sample ID. : ROOM 206 / SINK #2 / HW-F

Attn To : Brad Preston
 Federal ID :
 Collected : 06/24/2016 12:21 AM Point No
 Received : 06/30/2016 4:55 PM Location:
 Collected By : JM03

<u>Analytical Method:</u> E200.8 : IOC							<u>Analyst:</u> CM
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	07/19/2016 8:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.
Clinton, NY 13323

Lab No. : 1606T84-019
Client Sample ID. : ROOM 215 / SINK #2 / CW-F

Attn To : Brad Preston
 Federal ID :
 Collected : 06/24/2016 12:40 AM Point No
 Received : 06/30/2016 4:55 PM Location:
 Collected By : JM03

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> CM <u>Container:</u>
Lead	4.7		1	ug/L	15	07/19/2016 8:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.
Clinton, NY 13323

Lab No. : 1606T84-020
Client Sample ID. : ROOM 215 / SINK #2 / HW-F

Attn To : Brad Preston
 Federal ID :
 Collected : 06/24/2016 12:42 AM Point No
 Received : 06/30/2016 4:55 PM Location:
 Collected By : JM03

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> CM <u>Container:</u>
Lead	6.4		1	ug/L	15	07/19/2016 8:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.

Clinton, NY 13323

Attn To : Brad Preston

Federal ID :

Collected : 06/24/2016 1:11 AM Point No

Received : 06/30/2016 4:55 PM Location:

Collected By : JM03

Lab No. : 1606T84-036

Client Sample ID. : ROOM 2105 / SINK 2 / HW-F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	15		1	ug/L	15	07/19/2016 8:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.

Clinton, NY 13323

Attn To : Brad Preston

Federal ID :

Collected : 06/24/2016 1:29 AM Point No

Received : 06/30/2016 4:55 PM Location:

Collected By : JM03

Lab No. : 1606T84-046

Client Sample ID. : ROOM 2106 / SINK 1 / CW-F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.2		1	ug/L	15	07/19/2016 8:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.
Clinton, NY 13323

Lab No. : 1606T84-048
Client Sample ID. : ROOM 2106 / SINK #2 / CW-F

Attn To : Brad Preston

Federal ID :

Collected : 06/24/2016 1:33 AM Point No

Received : 06/30/2016 4:55 PM Location:

Collected By : JM03

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	07/19/2016 8:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Clinton Central School District
75 Chenango Ave.

Clinton, NY 13323

Attn To : Brad Preston

Federal ID :

Collected : 06/24/2016 2:01 AM Point No

Received : 06/30/2016 4:55 PM Location:

Collected By : JM03

Lab No. : 1606T84-065

Client Sample ID. : ROOM 121 / SINK / CW-F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	07/19/2016 8:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/20/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: **1606T84**
20-Jul-16

Client: Clinton Central School District
Project: Clinton Central School District

BatchID: R102027

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 102027
Client ID:	PBW	Batch ID: R102027	TestNo: E200.8	Analysis Date: 7/19/2016	SeqNo: 2249245	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

Qualifiers:

* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **CLINTON**

Date and Time Received: **6/30/2016 4:55:00 PM**

Work Order Number: **1606T84**

RcptNo: **1**

Received by **Erick Johnson**

Completed by: *Ramon S. De...*

Reviewed by: *Elizabeth Harrison*

Completed Date: 7/13/2016 1:01:15 PM

Reviewed Date: 7/13/2016 1:04:59 PM

Carrier name: FedEx

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Are matrices correctly identified on Chain of custody? Yes No
- Is it clear what analyses were requested? Yes No
- Custody seals intact on sample bottles? Yes No Not Present
- Samples in proper container/bottle? Yes No
- Were correct preservatives used and noted? Yes No NA
- Preservative added to bottles:
- Sample Condition? Intact Broken Leaking
- Sufficient sample volume for indicated test? Yes No
- Were container labels complete (ID, Pres, Date)? Yes No
- All samples received within holding time? Yes No
- Was an attempt made to cool the samples? Yes No NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes No NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes No To °
- Water - Were bubbles absent in VOC vials? Yes No No Vials
- Water - Was there Chlorine Present? Yes No NA
- Water - pH acceptable upon receipt? Yes No No Water
- Are Samples considered acceptable? Yes No
- Custody Seals present? Yes No
- Airbill or Sticker? Air Bil Sticker Not Present
- Airbill No: 7766-5305-2273

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? Yes No NA Person Contacted:
 Contact Mode: Phone: Fax: Email: In Person:
 Client Instructions:
 Date Contacted: Contacted By:
 Regarding:
 Comments:
 CorrectiveAction:

WorkOrder :
1606T84

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350