



ADDENDUM

ADDENDUM NO.: 2

PROJECT: WAYNE RESA
BEACON DAY TREATMENT CENTER RELOCATION
Taylor, MI

PROJECT NO: 2023-052
OWNER: Wayne RESA

DOCUMENTS ISSUED: July 14th, 2023

ADDENDUM ISSUED: August 3rd, 2023

CONSTRUCTION MANAGER: Barton Malow

This Addendum is issued before the receiving of bids to clarify or to include certain revisions to the plans or specifications. All work required by this Addendum shall be in accordance with the original plans and apply to this project.

It is requested to include the work hereinafter described, in the proposal by the contractor for the complete work.

SPECIFICATIONS

Specification Changes:

1. **Revised spec section 26 3213.13 DIESEL-ENGINE-DRIVEN GENERATOR SETS (re-issued):**
 1. Revised to include approved manufacturers/model numbers.
2. **Revised spec section 26 3600 – TRANSFER SWITCHES (re-issued):**
Revised to include approved manufacturers/model numbers.
3. **Revised spec section 23 8223 – UNIT VENTILATORS (not re-issued):**
 1. Revised to remove any supply air discharge grills on the Acoustic Plenum (2.12, C). The top Acoustic Plenum is to be provided to continue unit casing above ceiling.

DRAWING REVISIONS

MECHANICAL

1. **Refer to Sheet M310 - OVERALL FIRST FLOOR SHEET METAL PLAN (re-issued):**
 1. Removed ECH-3, VUV-A113, and VUV-B117.
2. **Refer to Sheet M320 - OVERALL SECOND FLOOR SHEET METAL PLAN (re-issued):**
 1. Removed VUV-B233.
3. **Refer to Sheet M330 - MECHANICAL ROOF PLAN (re-issued):**
 1. Added MAU-1.
4. **Refer to Sheet M701 - MECHANICAL SCHEDULES (re-issued):**
 1. Removed GRILLE, REGISTER, DIFFUSER SCHEDULE.
 2. Added MAKE-UP AIR UNIT SCHEDULE and EXHAUST FAN SCHEDULE.
 3. Revised VERTICAL UNIT VENTILATOR SCHEDULE, ELECTRIC CABINET HEATER SCHEDULE, and NATURAL GAS SCHEDULE

ELECTRICAL

5. **Refer to Sheet E110 – OVERALL FIRST FLOOR POWER PLAN (re-issued):**
 1. Added ATS-MDP, panel NB1B, and UPS1 panel UB1A.

6. **Refer to Sheet E120 – OVERALL SECOND FLOOR POWER PLAN (re-issued):**
 1. Added panel NB2B, panel NL2B, panel NB2D and UPS2 panel UB2A.

7. **Refer to Sheet E401 – ELECTRICAL ONE LINE DIAGRAM (re-issued):**
 1. Revised base design one line diagram to show added panels.
 2. Added metering to panels NS1A, ND2A, and NS2B.
 3. Added Temporary Generator Connection Cabinet to Generator.
 4. Added surge protection device to Fieldhouse Panel.

8. **Refer to Sheet E402 – ELECTRICAL ONE LINE DIAGRAM – ALTERNATE #1 (re-issued):**
 1. Revised base design one line diagram to show added panels.
 2. Added metering to panels NS1A, ND2A, and NS2B.
 3. Added surge protection device to Fieldhouse Panel.

9. **Refer to Sheet E501 – ELECTRICAL PANEL LOAD SCHEDULES (issued):**
 1. Added sheet for electrical panel clarification.

10. **Refer to Sheet E502 – ELECTRICAL PANEL LOAD SCHEDULES (issued):**
 1. Added sheet for electrical panel clarification.

11. **Refer to Sheet E503 – ELECTRICAL PANEL LOAD SCHEDULES (issued):**
 1. Added sheet for electrical panel clarification.

12. **Refer to Sheet E504 – ELECTRICAL PANEL LOAD SCHEDULES (issued):**
 1. Added sheet for electrical panel clarification.

13. **Refer to Sheet E505 – ELECTRICAL PANEL LOAD SCHEDULES (issued):**
 1. Added sheet for electrical panel clarification.