

March 22, 2021

Mike Reifsteck
Phelps-Clifton Springs School District
1490 State Route 488
Clifton Springs, NY 14432

RE: Project: PHELPS-CLIFTON MIDDLE SCHOOL
Pace Project No.: 70165643

Dear Mike Reifsteck:


Enclosed are the analytical results for sample(s) received by the laboratory on March 11, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Elizabeth Harrison
betty.harrison@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Pace Analytical Services Long Island

Delaware Certification # NY10478

Virginia Certification # 460302

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-CR-S1		Lab ID: 70165643001	Collected: 03/10/21 04:23	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-100-S1		Lab ID: 70165643002	Collected: 03/10/21 04:25	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-100-S2		Lab ID: 70165643003	Collected: 03/10/21 04:25	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-102-S1		Lab ID: 70165643004	Collected: 03/10/21 04:25	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		03/19/21 11:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-102-S2		Lab ID: 70165643005	Collected: 03/10/21 04:26	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-102-S3		Lab ID: 70165643006		Collected: 03/10/21 04:26		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.7	ug/L	1.0	1		03/19/21 11:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-HW1-DF1		Lab ID: 70165643007	Collected: 03/10/21 04:27	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MB-S1		Lab ID: 70165643008		Collected: 03/10/21 04:30		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		03/19/21 11:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MB-S2		Lab ID: 70165643009	Collected: 03/10/21 04:30	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		03/19/21 11:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MB-S3		Lab ID: 70165643010	Collected: 03/10/21 04:30	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		03/19/21 11:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WB-S1		Lab ID: 70165643011	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		03/19/21 11:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WB-S2		Lab ID: 70165643012	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		03/19/21 11:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WB-S3		Lab ID: 70165643013	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		03/19/21 11:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-112-S1		Lab ID: 70165643014	Collected: 03/10/21 04:32	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-113-S1		Lab ID: 70165643015		Collected: 03/10/21 04:33		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		03/19/21 11:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-114-S1		Lab ID: 70165643016		Collected: 03/10/21 04:33		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		03/19/21 11:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-115-S1		Lab ID: 70165643017		Collected: 03/10/21 04:34		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	307	ug/L	1.0	1		03/19/21 11:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-116-S1		Lab ID: 70165643018		Collected: 03/10/21 04:37		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		03/19/21 11:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-117-S1		Lab ID: 70165643019		Collected: 03/10/21 04:35		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		03/19/21 11:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-119-S1		Lab ID: 70165643020		Collected: 03/10/21 04:35		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.9	ug/L	1.0	1		03/19/21 11:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-122-S1		Lab ID: 70165643021	Collected: 03/10/21 04:39	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		03/19/21 11:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-LB-S1		Lab ID: 70165643022	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		03/19/21 11:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-LB-S2		Lab ID: 70165643023	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-123-S1		Lab ID: 70165643024	Collected: 03/10/21 04:41	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-123-S2		Lab ID: 70165643025	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-127-S1		Lab ID: 70165643026	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		03/19/21 11:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-127-S2		Lab ID: 70165643027	Collected: 03/10/21 04:44	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-130-S1		Lab ID: 70165643028	Collected: 03/10/21 04:46	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-130-S2		Lab ID: 70165643029	Collected: 03/10/21 04:46	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-130A-S1		Lab ID: 70165643030	Collected: 03/10/21 04:47	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		03/19/21 11:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-134-DF1		Lab ID: 70165643031	Collected: 03/10/21 04:48	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 11:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-132-S1		Lab ID: 70165643032		Collected: 03/10/21 04:51		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		03/19/21 11:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-132-S2		Lab ID: 70165643033	Collected: 03/10/21 04:51	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		03/19/21 12:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-132-S3		Lab ID: 70165643034	Collected: 03/10/21 04:51	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		03/19/21 12:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-132-S4		Lab ID: 70165643035	Collected: 03/10/21 04:50	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		03/19/21 12:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-134-S1		Lab ID: 70165643036		Collected: 03/10/21 04:53		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		03/19/21 12:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-134-S2		Lab ID: 70165643037	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-134-S3		Lab ID: 70165643038	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		03/19/21 12:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-134-S4		Lab ID: 70165643039	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-139-S1		Lab ID: 70165643040		Collected: 03/10/21 04:56		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		03/19/21 12:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-138-S1		Lab ID: 70165643041		Collected: 03/10/21 04:56		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		03/19/21 12:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-141-S1		Lab ID: 70165643042		Collected: 03/10/21 04:57		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		03/19/21 12:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-141-S2		Lab ID: 70165643043	Collected: 03/10/21 04:57	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-145-S1		Lab ID: 70165643044		Collected: 03/10/21 04:58		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/19/21 12:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-145-S2		Lab ID: 70165643045	Collected: 03/10/21 04:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-147-S1		Lab ID: 70165643046		Collected: 03/10/21 04:59		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.1	ug/L	1.0	1		03/19/21 12:20	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S1		Lab ID: 70165643047	Collected: 03/10/21 05:02	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	87.4	ug/L	1.0	1		03/19/21 12:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S2		Lab ID: 70165643048	Collected: 03/10/21 05:03	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	46.4	ug/L	1.0	1		03/19/21 12:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S3		Lab ID: 70165643049	Collected: 03/10/21 05:07	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.8	ug/L	1.0	1		03/19/21 12:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S4		Lab ID: 70165643050	Collected: 03/10/21 05:04	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	149	ug/L	1.0	1		03/19/21 12:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S5		Lab ID: 70165643051	Collected: 03/10/21 05:01	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	925	ug/L	1.0	1		03/19/21 12:25	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-146-S6		Lab ID: 70165643052	Collected: 03/10/21 05:08	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	200	ug/L	1.0	1		03/19/21 12:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MGBR-S1		Lab ID: 70165643053	Collected: 03/10/21 05:10	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MGBR-S2		Lab ID: 70165643054		Collected: 03/10/21 05:10		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		03/19/21 12:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WGBR-S1		Lab ID: 70165643055	Collected: 03/10/21 05:11	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WGBR-S2		Lab ID: 70165643056	Collected: 03/10/21 05:11	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	547	ug/L	1.0	1		03/19/21 12:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-155-S1		Lab ID: 70165643057		Collected: 03/10/21 05:13		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		03/19/21 12:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-155-S2		Lab ID: 70165643058		Collected: 03/10/21 05:13		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	108	ug/L	1.0	1		03/19/21 12:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-155-S3		Lab ID: 70165643059	Collected: 03/10/21 05:14	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		03/19/21 12:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-155-S4		Lab ID: 70165643060	Collected: 03/10/21 05:14	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		03/19/21 12:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-157-S1		Lab ID: 70165643061	Collected: 03/10/21 05:15	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-157-S2		Lab ID: 70165643062	Collected: 03/10/21 05:15	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		03/19/21 12:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-203-S1		Lab ID: 70165643063		Collected: 03/10/21 05:21		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.5	ug/L	1.0	1		03/19/21 12:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-203-S2		Lab ID: 70165643064	Collected: 03/10/21 05:21	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.0	ug/L	1.0	1		03/19/21 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-203-S3		Lab ID: 70165643065	Collected: 03/10/21 05:21	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.4	ug/L	1.0	1		03/19/21 12:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-203-S4		Lab ID: 70165643066	Collected: 03/10/21 05:22	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.4	ug/L	1.0	1		03/19/21 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-203-S5		Lab ID: 70165643067	Collected: 03/10/21 05:22	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	45.3	ug/L	1.0	1		03/19/21 12:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-210-S1		Lab ID: 70165643068	Collected: 03/10/21 05:27	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		03/19/21 12:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-212-S1		Lab ID: 70165643069	Collected: 03/10/21 05:28	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		03/19/21 12:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-HALL-2FL-DF1		Lab ID: 70165643070	Collected: 03/10/21 05:28	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 12:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MFB-2FL-S1		Lab ID: 70165643071		Collected: 03/10/21 05:30		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		03/19/21 12:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MFB-2FL-S2		Lab ID: 70165643072		Collected: 03/10/21 05:30		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		03/19/21 12:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WFB-2FL-S1		Lab ID: 70165643073		Collected: 03/10/21 05:31		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		03/19/21 12:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WFB-2FL-S2		Lab ID: 70165643074		Collected: 03/10/21 05:31		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		03/19/21 13:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-CC-2FL-S1		Lab ID: 70165643075	Collected: 03/10/21 05:33	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.8	ug/L	1.0	1		03/19/21 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MGBR-2FL-S1		Lab ID: 70165643076	Collected: 03/10/21 05:34	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		03/19/21 13:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MGBR-2FL-S2		Lab ID: 70165643077	Collected: 03/10/21 05:34	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 13:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MGBR-2FL-S3		Lab ID: 70165643078	Collected: 03/10/21 05:34	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		03/19/21 13:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WGBR-2FL-S1		Lab ID: 70165643079	Collected: 03/10/21 05:36	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 13:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WGBR-2FL-S2		Lab ID: 70165643080	Collected: 03/10/21 05:36	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/19/21 13:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WGBR-2FL-S3		Lab ID: 70165643081	Collected: 03/10/21 05:36	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		03/19/21 13:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-215-S1		Lab ID: 70165643082	Collected: 03/10/21 05:37	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.3	ug/L	1.0	1		03/19/21 13:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-223-S1		Lab ID: 70165643083		Collected: 03/10/21 05:38		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		03/19/21 13:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MLR-S1		Lab ID: 70165643084		Collected: 03/10/21 05:42		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	27.5	ug/L	1.0	1		03/19/21 13:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-MFBR-MH-S1		Lab ID: 70165643085	Collected: 03/10/21 05:41	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		03/19/21 13:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Sample: MS-WFBR-MH-S1		Lab ID: 70165643086	Collected: 03/10/21 05:41	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		03/19/21 13:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

QC Batch:	200830	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165643001, 70165643002, 70165643003, 70165643004, 70165643005, 70165643006, 70165643007, 70165643008, 70165643009, 70165643010, 70165643011, 70165643012, 70165643013, 70165643014, 70165643015, 70165643016, 70165643017, 70165643018, 70165643019, 70165643020		

METHOD BLANK:	988557	Matrix:	Water
Associated Lab Samples:	70165643001, 70165643002, 70165643003, 70165643004, 70165643005, 70165643006, 70165643007, 70165643008, 70165643009, 70165643010, 70165643011, 70165643012, 70165643013, 70165643014, 70165643015, 70165643016, 70165643017, 70165643018, 70165643019, 70165643020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/19/21 11:10	

LABORATORY CONTROL SAMPLE:	988558					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.5	107	85-115	

MATRIX SPIKE SAMPLE:		988561					
		70165643001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	57.9	114	70-130	

MATRIX SPIKE SAMPLE:		988563					
		70165643011	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.2	50	59.5	117	70-130	

SAMPLE DUPLICATE:	988560				
Parameter	Units	70165643001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	988562				
Parameter	Units	70165643011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.2	1.2	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

QC Batch:	200831	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165643021, 70165643022, 70165643023, 70165643024, 70165643025, 70165643026, 70165643027, 70165643028, 70165643029, 70165643030, 70165643031, 70165643032, 70165643033, 70165643034, 70165643035, 70165643036, 70165643037, 70165643038, 70165643039, 70165643040		

METHOD BLANK:	988564	Matrix:	Water
Associated Lab Samples:	70165643021, 70165643022, 70165643023, 70165643024, 70165643025, 70165643026, 70165643027, 70165643028, 70165643029, 70165643030, 70165643031, 70165643032, 70165643033, 70165643034, 70165643035, 70165643036, 70165643037, 70165643038, 70165643039, 70165643040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/19/21 11:39	

LABORATORY CONTROL SAMPLE:	988565					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.6	105	85-115	

MATRIX SPIKE SAMPLE:		988567					
		70165643021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.0	50	57.0	110	70-130	

MATRIX SPIKE SAMPLE:		988569					
		70165643031	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	54.7	109	70-130	

SAMPLE DUPLICATE: 988566					
		70165643021	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	2.0	2.0	0	

SAMPLE DUPLICATE: 988568

Parameter	Units	70165643031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

QC Batch:	200832	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165643041, 70165643042, 70165643043, 70165643044, 70165643045, 70165643046, 70165643047, 70165643048, 70165643049, 70165643050, 70165643051, 70165643052, 70165643053, 70165643054, 70165643055, 70165643056, 70165643057, 70165643058, 70165643059, 70165643060		

METHOD BLANK:	988570	Matrix:	Water
Associated Lab Samples:	70165643041, 70165643042, 70165643043, 70165643044, 70165643045, 70165643046, 70165643047, 70165643048, 70165643049, 70165643050, 70165643051, 70165643052, 70165643053, 70165643054, 70165643055, 70165643056, 70165643057, 70165643058, 70165643059, 70165643060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/19/21 12:10	

LABORATORY CONTROL SAMPLE:	988571					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.6	105	85-115	

MATRIX SPIKE SAMPLE:		988573					
		70165643041	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.2	50	56.0	110	70-130	

MATRIX SPIKE SAMPLE:		988575					
		70165643051	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	925	50	945	40	70-130	M1

SAMPLE DUPLICATE: 988572					
		70165643041	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	1.2	1.2	3	

SAMPLE DUPLICATE: 988574

Parameter	Units	70165643051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	925	937	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

QC Batch:	200833	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165643061, 70165643062, 70165643063, 70165643064, 70165643065, 70165643066, 70165643067, 70165643068, 70165643069, 70165643070, 70165643071, 70165643072, 70165643073, 70165643074, 70165643075, 70165643076, 70165643077, 70165643078, 70165643079, 70165643080		

METHOD BLANK: 988576

Matrix: Water

Associated Lab Samples: 70165643061, 70165643062, 70165643063, 70165643064, 70165643065, 70165643066, 70165643067, 70165643068, 70165643069, 70165643070, 70165643071, 70165643072, 70165643073, 70165643074, 70165643075, 70165643076, 70165643077, 70165643078, 70165643079, 70165643080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/19/21 12:38	

LABORATORY CONTROL SAMPLE: 988577

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.3	107	85-115	

MATRIX SPIKE SAMPLE: 988579

Parameter	Units	70165643061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.6	114	70-130	

MATRIX SPIKE SAMPLE: 988581

Parameter	Units	70165643071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.5	50	56.7	110	70-130	

SAMPLE DUPLICATE: 988578

Parameter	Units	70165643061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 988580

Parameter	Units	70165643071 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.5	1.5	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

QC Batch: 200834

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70165643081, 70165643082, 70165643083, 70165643084, 70165643085, 70165643086

METHOD BLANK: 988582

Matrix: Water

Associated Lab Samples: 70165643081, 70165643082, 70165643083, 70165643084, 70165643085, 70165643086

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/19/21 13:08	

LABORATORY CONTROL SAMPLE: 988583

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.6	105	85-115	

MATRIX SPIKE SAMPLE: 988585

Parameter	Units	70165643081 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.6	50	56.9	109	70-130	

SAMPLE DUPLICATE: 988584

Parameter	Units	70165643081 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.6	2.6	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

WORKORDER QUALIFIERS

WO: 70165643

[1] Client did not provide time of collection on COC for sample MS-132-S4. Client was notified see Sample Condition Upon Receipt Form

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70165643001	MS-CR-S1	EPA 200.8	200830		
70165643002	MS-100-S1	EPA 200.8	200830		
70165643003	MS-100-S2	EPA 200.8	200830		
70165643004	MS-102-S1	EPA 200.8	200830		
70165643005	MS-102-S2	EPA 200.8	200830		
70165643006	MS-102-S3	EPA 200.8	200830		
70165643007	MS-HW1-DF1	EPA 200.8	200830		
70165643008	MS-MB-S1	EPA 200.8	200830		
70165643009	MS-MB-S2	EPA 200.8	200830		
70165643010	MS-MB-S3	EPA 200.8	200830		
70165643011	MS-WB-S1	EPA 200.8	200830		
70165643012	MS-WB-S2	EPA 200.8	200830		
70165643013	MS-WB-S3	EPA 200.8	200830		
70165643014	MS-112-S1	EPA 200.8	200830		
70165643015	MS-113-S1	EPA 200.8	200830		
70165643016	MS-114-S1	EPA 200.8	200830		
70165643017	MS-115-S1	EPA 200.8	200830		
70165643018	MS-116-S1	EPA 200.8	200830		
70165643019	MS-117-S1	EPA 200.8	200830		
70165643020	MS-119-S1	EPA 200.8	200830		
70165643021	MS-122-S1	EPA 200.8	200831		
70165643022	MS-LB-S1	EPA 200.8	200831		
70165643023	MS-LB-S2	EPA 200.8	200831		
70165643024	MS-123-S1	EPA 200.8	200831		
70165643025	MS-123-S2	EPA 200.8	200831		
70165643026	MS-127-S1	EPA 200.8	200831		
70165643027	MS-127-S2	EPA 200.8	200831		
70165643028	MS-130-S1	EPA 200.8	200831		
70165643029	MS-130-S2	EPA 200.8	200831		
70165643030	MS-130A-S1	EPA 200.8	200831		
70165643031	MS-134-DF1	EPA 200.8	200831		
70165643032	MS-132-S1	EPA 200.8	200831		
70165643033	MS-132-S2	EPA 200.8	200831		
70165643034	MS-132-S3	EPA 200.8	200831		
70165643035	MS-132-S4	EPA 200.8	200831		
70165643036	MS-134-S1	EPA 200.8	200831		
70165643037	MS-134-S2	EPA 200.8	200831		
70165643038	MS-134-S3	EPA 200.8	200831		
70165643039	MS-134-S4	EPA 200.8	200831		
70165643040	MS-139-S1	EPA 200.8	200831		
70165643041	MS-138-S1	EPA 200.8	200832		
70165643042	MS-141-S1	EPA 200.8	200832		
70165643043	MS-141-S2	EPA 200.8	200832		
70165643044	MS-145-S1	EPA 200.8	200832		
70165643045	MS-145-S2	EPA 200.8	200832		
70165643046	MS-147-S1	EPA 200.8	200832		
70165643047	MS-146-S1	EPA 200.8	200832		
70165643048	MS-146-S2	EPA 200.8	200832		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PHELPS-CLIFTON MIDDLE SCHOOL

Pace Project No.: 70165643

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70165643049	MS-146-S3	EPA 200.8	200832		
70165643050	MS-146-S4	EPA 200.8	200832		
70165643051	MS-146-S5	EPA 200.8	200832		
70165643052	MS-146-S6	EPA 200.8	200832		
70165643053	MS-MGBR-S1	EPA 200.8	200832		
70165643054	MS-MGBR-S2	EPA 200.8	200832		
70165643055	MS-WGBR-S1	EPA 200.8	200832		
70165643056	MS-WGBR-S2	EPA 200.8	200832		
70165643057	MS-155-S1	EPA 200.8	200832		
70165643058	MS-155-S2	EPA 200.8	200832		
70165643059	MS-155-S3	EPA 200.8	200832		
70165643060	MS-155-S4	EPA 200.8	200832		
70165643061	MS-157-S1	EPA 200.8	200833		
70165643062	MS-157-S2	EPA 200.8	200833		
70165643063	MS-203-S1	EPA 200.8	200833		
70165643064	MS-203-S2	EPA 200.8	200833		
70165643065	MS-203-S3	EPA 200.8	200833		
70165643066	MS-203-S4	EPA 200.8	200833		
70165643067	MS-203-S5	EPA 200.8	200833		
70165643068	MS-210-S1	EPA 200.8	200833		
70165643069	MS-212-S1	EPA 200.8	200833		
70165643070	MS-HALL-2FL-DF1	EPA 200.8	200833		
70165643071	MS-MFB-2FL-S1	EPA 200.8	200833		
70165643072	MS-MFB-2FL-S2	EPA 200.8	200833		
70165643073	MS-WFB-2FL-S1	EPA 200.8	200833		
70165643074	MS-WFB-2FL-S2	EPA 200.8	200833		
70165643075	MS-CC-2FL-S1	EPA 200.8	200833		
70165643076	MS-MGBR-2FL-S1	EPA 200.8	200833		
70165643077	MS-MGBR-2FL-S2	EPA 200.8	200833		
70165643078	MS-MGBR-2FL-S3	EPA 200.8	200833		
70165643079	MS-WGBR-2FL-S1	EPA 200.8	200833		
70165643080	MS-WGBR-2FL-S2	EPA 200.8	200833		
70165643081	MS-WGBR-2FL-S3	EPA 200.8	200834		
70165643082	MS-215-S1	EPA 200.8	200834		
70165643083	MS-223-S1	EPA 200.8	200834		
70165643084	MS-MLR-S1	EPA 200.8	200834		
70165643085	MS-MFBR-MH-S1	EPA 200.8	200834		
70165643086	MS-WFBR-MH-S1	EPA 200.8	200834		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be

WO#: 70165643



70165643

Section A

Required Client Information:

Company: Phelps-Clifton Springs CSD
Address: 1490 State Route 488
Clifton Springs, NY 14432
Email: mreifsteck@midlakes.org
Phone: 315-548-6455 Fax:
Requested Due Date:

Section B

Required Project Information:

Report To: Mike Reifsteck
Copy To:
Purchase Order #:
Project Name: PHELPS-CLIFTON MIDDLE SCHOOL
Project #:

Section C

Invoice Information:

Attention:
Company Name:
Address:
Pace Quote:
Pace Project Manager: betty.harrison@pacelabs.com,
Pace Profile #: 6079

Page: 1 Of 1

Regulatory Agency

State / Location

NY

Requested Analysis Filtered (Y/N)

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives										Analyses Test Y/N	200.8 LEAD	Residual Chlorine (Y/N)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
						DATE	TIME	DATE	TIME																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
1	MS-CR-S1			DW				3/10	4:03		1			X																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
Crossed off sample ID were not sampled NS - Not Sampled	Klajdi Macolli	3/10	10:30	Klajdi Macolli	3/11/21	9:55	15.9	N	Y	Y

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

Klajdi Macolli

Klajdi Macolli

DATE Signed:

3/10/21

TEMP in C

Received on
ice (Y/N)

Custody
Sealed
Cooler
(Y/N)

Samples
Intact
(Y/N)



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A

Required Client Information:

Company: Phelps-Clifton Springs CSD
Address: 1490 State Route 488
Clifton Springs, NY 14432
Email: mreifeleck@midlakes.org
Phone: 315-548-6455 Fax:
Requested Due Date:

Section B

Required Project Information:

Report To: Mike Reifeleck
Copy To:
Purchase Order #:
Project Name: PHELPS-CLIFTON MIDDLE SCHOOL
Project #:

Section C

Invoice Information:

Attention:
Company Name:
Address:
Pace Quote:
Pace Project Manager: betty.harrison@pacelabs.com,
Pace Profile #: 6079

Page : 4 Of 4

Regulatory Agency

State / Location

NY

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other		Analyses Test	200.8 LEAD																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
NS - Not Sampled				Matthew R. Smith Inc L.T.	3/11/20	9:55	15.9	N	Y	Y
Pa										

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:


DATE Signed:

TEMP in C

Received on
Ice (Y/N)

Custody
Sealed
Cooler (Y/N)

Samples
Intact (Y/N)





CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A

Required Client Information:

Company: Phelps-Clifton Springs CSD
Address: 1490 State Route 488
Clifton Springs, NY 14432
Email: mreife@midlakes.org
Phone: 315-548-6455 Fax:
Requested Due Date:

Section B

Required Project Information:

Report To: Mike Reifsteck
Copy To:
Purchase Order #:
Project Name: PHELPS-CLIFTON MIDDLE SCHOOL
Project #:

Section C

Invoice Information:

Attention:
Company Name:
Address:
Pace Quote:
Pace Project Manager: betty.harrison@pacelabs.com,
Pace Profile #: 6079

Page : 10 Of 10

Regulatory Agency

State / Location

NY

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives										Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	Analyses Test	200.8		LEAD																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
				<i>Matthew Smith</i> for LI	3/10/21	4:55	15.9	N	Y	Y

SAMPLER NAME AND SIGNATURE		TEMP in C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
PRINT Name of SAMPLER:					
SIGNATURE of SAMPLER:	DATE Signed:				



Sample Condition Upon Receipt

WO#: 70165643

Client Name:

Project:

PM: EMH

Due Date: 03/25/21

CLIENT: PHELPS

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 7845 8489 1347

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No Seals intact: ☒ Yes ☐ NoPacking Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Thermometer Used: TH091

Correction Factor: +0.0

Cooler Temperature(°C): 15.9

Cooler Temperature Corrected(°C): 15.9

Temperature Blank Present: ☐ Yes ☒ NoType of Ice: Wet Blue ☒ None☐ Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil ☒ N/A, water sample

Date and Initials of person examining contents: MN 3/11/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

Did samples originate from a foreign source

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ Noincluding Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

COMMENTS:	
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2. Time of collection for sample MS-134-S4 taken off bottle.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11. Note if sediment is visible in the dissolved container.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	12.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
-Includes date/time/ID, Matrix: SL WT OIL	Sample #
All containers needing preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
pH paper Lot # H6025486	14. Positive for Res. Chlorine? Y N
All containers needing preservation are found to be in compliance with method recommendation? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15.
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NAOH > 12 Cyanide)	16.
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	17.
Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
KI starch test strips Lot #	
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sulfide? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Lead Acetate Strips Lot #	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):	

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: