

March 19, 2021

Mike Reifsteck  
Phelps-Clifton Springs School District  
1490 State Route 488  
Clifton Springs, NY 14432

RE: Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

Dear Mike Reifsteck:


Enclosed are the analytical results for sample(s) received by the laboratory on March 11, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Elizabeth Harrison  
betty.harrison@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

---

### **Pace Analytical Services Long Island**

Delaware Certification # NY10478

Virginia Certification # 460302

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-91-S1		Lab ID: 70165633001	Collected: 03/10/21 04:38	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.2</b>	ug/L	1.0	1		03/18/21 14:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-91-S2	Lab ID: 70165633002	Collected: 03/10/21 04:38	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/18/21 14:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-185-S1		Lab ID: 70165633003	Collected: 03/10/21 04:46	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.1</b>	ug/L	1.0	1		03/18/21 14:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-185-S2		Lab ID: 70165633004	Collected: 03/10/21 04:46	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		03/18/21 14:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBM-S1	Lab ID: 70165633005	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>2.3</b>	ug/L	1.0	1		03/18/21 14:11	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBM-S2		Lab ID: 70165633006	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		03/18/21 14:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-PBM-S3</b>		<b>Lab ID: 70165633007</b>	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.5</b>	ug/L	1.0	1		03/18/21 14:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBM-S4		Lab ID: 70165633008	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.3</b>	ug/L	1.0	1		03/18/21 14:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBM-S5		Lab ID: 70165633009	Collected: 03/10/21 04:43	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>10.7</b>	ug/L	1.0	1		03/18/21 14:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBW-S1		Lab ID: 70165633010	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		03/18/21 14:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBW-S2	Lab ID: 70165633011	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>3.3</b>	ug/L	1.0	1		03/18/21 14:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBW-S3	Lab ID: 70165633012	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.3</b>	ug/L	1.0	1		03/18/21 14:21	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBW-S4		Lab ID: 70165633013	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.8</b>	ug/L	1.0	1		03/18/21 14:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-PBW-S5		Lab ID: 70165633014	Collected: 03/10/21 04:40	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.8</b>	ug/L	1.0	1		03/18/21 14:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-90-S1	Lab ID: 70165633015	Collected: 03/10/21 04:37	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.6</b>	ug/L	1.0	1		03/18/21 14:26	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-90-S2	Lab ID: 70165633016	Collected: 03/10/21 04:37	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/18/21 14:27	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-178A-S1		Lab ID: 70165633017	Collected: 03/10/21 04:34	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		03/18/21 14:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-178B-S1		Lab ID: 70165633018	Collected: 03/10/21 04:34	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.1</b>	ug/L	1.0	1		03/18/21 14:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-178-S1		Lab ID: 70165633019	Collected: 03/10/21 04:33	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 14:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-170-S1		Lab ID: 70165633020	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		03/18/21 14:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-170-S2	Lab ID: 70165633021	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.8</b>	ug/L	1.0	1		03/18/21 14:33	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-170-S3		Lab ID: 70165633022	Collected: 03/10/21 04:31	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		03/18/21 14:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-165-S1		Lab ID: 70165633023	Collected: 03/10/21 04:26	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		03/18/21 14:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-165-S2		Lab ID: 70165633024	Collected: 03/10/21 04:26	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		03/18/21 14:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-165-S3		Lab ID: 70165633025	Collected: 03/10/21 04:26	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>863</b>	ug/L	1.0	1		03/18/21 14:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-160A-DF-2	Lab ID: 70165633026	Collected: 03/10/21 04:25	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/18/21 14:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-166-S1		Lab ID: 70165633027	Collected: 03/10/21 04:30	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.2</b>	ug/L	1.0	1		03/18/21 14:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-160-S1		Lab ID: 70165633028	Collected: 03/10/21 04:21	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.8</b>	ug/L	1.0	1		03/18/21 14:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-159-S1</b>		<b>Lab ID: 70165633029</b>	Collected: 03/10/21 04:20	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>51.4</b>	ug/L	1.0	1		03/18/21 14:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-105-S1		Lab ID: 70165633030	Collected: 03/10/21 05:05	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 14:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-100-S1		Lab ID: 70165633031	Collected: 03/10/21 05:03	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		03/18/21 14:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-100-S2		Lab ID: 70165633032	Collected: 03/10/21 05:03	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		03/18/21 14:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-LIBRARY-DF1		Lab ID: 70165633033	Collected: 03/10/21 05:07	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 14:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-S1	Lab ID: 70165633034	Collected: 03/10/21 05:09	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		03/18/21 14:53	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-S2		Lab ID: 70165633035	Collected: 03/10/21 05:09	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>44.7</b>	ug/L	1.0	1		03/18/21 14:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-S3		Lab ID: 70165633036	Collected: 03/10/21 05:09	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>178</b>	ug/L	1.0	1		03/18/21 14:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-S4	Lab ID: 70165633037	Collected: 03/10/21 05:09	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>344</b>	ug/L	1.0	1		03/18/21 14:56	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-S5		Lab ID: 70165633038		Collected: 03/10/21 05:09	Received: 03/11/21 09:55	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.5</b>	ug/L	1.0	1		03/18/21 14:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-124-S1		Lab ID: 70165633039	Collected: 03/10/21 05:15	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		03/18/21 15:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-S1	Lab ID: 70165633040	Collected: 03/10/21 05:30	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		03/18/21 15:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-S2		Lab ID: 70165633041	Collected: 03/10/21 05:30	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>48.7</b>	ug/L	1.0	1		03/18/21 15:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-S3	Lab ID: 70165633042	Collected: 03/10/21 05:30	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.3</b>	ug/L	1.0	1		03/18/21 15:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-S4	Lab ID: 70165633043	Collected: 03/10/21 05:30	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>171</b>	ug/L	1.0	1		03/18/21 15:08	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-S5		Lab ID: 70165633044	Collected: 03/10/21 05:30	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>43.2</b>	ug/L	1.0	1		03/18/21 15:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-143-S1		Lab ID: 70165633045		Collected: 03/10/21 05:32		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		03/18/21 15:11	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-143-S2		Lab ID: 70165633046	Collected: 03/10/21 05:32	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.1</b>	ug/L	1.0	1		03/18/21 15:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-146-S1		Lab ID: 70165633047	Collected: 03/10/21 05:35	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 15:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-141-S1	Lab ID: 70165633048	Collected: 03/10/21 05:26	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.3</b>	ug/L	1.0	1		03/18/21 15:14	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-141-S2		Lab ID: 70165633049	Collected: 03/10/21 05:26	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.0</b>	ug/L	1.0	1		03/18/21 15:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-OSR138-DF2	Lab ID: 70165633050	Collected: 03/10/21 05:26	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/18/21 15:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WSBR-D-WING-S1	Lab ID: 70165633051	Collected: 03/10/21 05:25	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/18/21 15:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS-WSBR-D-WING-S2      Lab ID: 70165633052      Collected: 03/10/21 05:25      Received: 03/11/21 09:55      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	5.8	ug/L	1.0	1		03/18/21 15:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS-WSBR-D-WING-S3      Lab ID: 70165633053      Collected: 03/10/21 05:25      Received: 03/11/21 09:55      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>3.2</b>	ug/L	1.0	1		03/18/21 15:23	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WSBR-D-WING-S4	Lab ID: 70165633054	Collected: 03/10/21 05:25	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		03/18/21 15:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-135-S1		Lab ID: 70165633055	Collected: 03/10/21 05:23	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.3</b>	ug/L	1.0	1		03/18/21 15:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MSBR-D-WING-S1	Lab ID: 70165633056	Collected: 03/10/21 05:21	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.6</b>	ug/L	1.0	1		03/18/21 15:26	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MSBR-D-WING-S2		Lab ID: 70165633057	Collected: 03/10/21 05:21	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.1	ug/L	1.0	1		03/18/21 15:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MSBR-D-WING-S3		Lab ID: 70165633058	Collected: 03/10/21 05:21	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 15:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-131-S1		Lab ID: 70165633059	Collected: 03/10/21 05:15	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.1</b>	ug/L	1.0	1		03/18/21 15:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-MGBR-2FL-S1</b>		<b>Lab ID: 70165633060</b>	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		03/18/21 15:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-2FL-S2		Lab ID: 70165633061	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>540</b>	ug/L	1.0	1		03/18/21 15:34	7439-92-1	M1

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-2FL-S3		Lab ID: 70165633062	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		03/18/21 15:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-2FL-S4	Lab ID: 70165633063	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>797</b>	ug/L	1.0	1		03/18/21 15:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MGBR-2FL-S5		Lab ID: 70165633064	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.9</b>	ug/L	1.0	1		03/18/21 15:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-2FL-S1		Lab ID: 70165633065		Collected: 03/10/21 05:42		Received: 03/11/21 09:55		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.3</b>	ug/L	1.0	1		03/18/21 15:40	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-2FL-S2		Lab ID: 70165633066	Collected: 03/10/21 05:42	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>17.5</b>	ug/L	1.0	1		03/18/21 15:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-2FL-S3		Lab ID: 70165633067	Collected: 03/10/21 05:42	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		03/18/21 15:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-2FL-S4		Lab ID: 70165633068	Collected: 03/10/21 05:42	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>13.5</b>	ug/L	1.0	1		03/18/21 15:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WGBR-2FL-S5		Lab ID: 70165633069	Collected: 03/10/21 05:42	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.0</b>	ug/L	1.0	1		03/18/21 15:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-DR-S1		Lab ID: 70165633070	Collected: 03/10/21 05:45	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>17.1</b>	ug/L	1.0	1		03/18/21 15:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS-NHW-2FL-DF1</b>								
<b>Lab ID: 70165633071</b>								
Collected: 03/10/21 06:04								
Received: 03/11/21 09:55								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/18/21 15:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-231-S1		Lab ID: 70165633072	Collected: 03/10/21 05:57	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		03/18/21 15:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-231-S2		Lab ID: 70165633073	Collected: 03/10/21 05:57	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		03/18/21 15:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-231-S3		Lab ID: 70165633074	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>28.2</b>	ug/L	1.0	1		03/18/21 15:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-231-S4	Lab ID: 70165633075	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.3</b>	ug/L	1.0	1		03/18/21 15:53	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-231-S5		Lab ID: 70165633076	Collected: 03/10/21 05:58	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.5</b>	ug/L	1.0	1		03/18/21 15:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-202-S1		Lab ID: 70165633077	Collected: 03/10/21 05:50	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.7	ug/L	1.0	1		03/18/21 15:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-203-S1		Lab ID: 70165633078	Collected: 03/10/21 05:47	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		03/18/21 15:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-OS-R210-DF1	Lab ID: 70165633079	Collected: 03/10/21 05:51	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/18/21 15:59	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-OSR216-DF1		Lab ID: 70165633080	Collected: 03/10/21 05:54	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 16:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-218-S1		Lab ID: 70165633081	Collected: 03/10/21 05:55	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.3</b>	ug/L	1.0	1		03/18/21 16:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S1		Lab ID: 70165633082	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>88.6</b>	ug/L	1.0	1		03/18/21 16:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S2		Lab ID: 70165633083	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.3</b>	ug/L	1.0	1		03/18/21 16:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-187-S3</b>		<b>Lab ID: 70165633084</b>	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.4</b>	ug/L	1.0	1		03/18/21 16:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-187-S4</b>		<b>Lab ID: 70165633085</b>	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.1</b>	ug/L	1.0	1		03/18/21 16:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S5		Lab ID: 70165633086	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 16:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S6		Lab ID: 70165633087	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		03/18/21 16:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S7		Lab ID: 70165633088	Collected: 03/10/21 04:53	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		03/18/21 16:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187B-S1	Lab ID: 70165633089	Collected: 03/10/21 04:54	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.8</b>	ug/L	1.0	1		03/18/21 16:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MFBR-S1		Lab ID: 70165633090	Collected: 03/10/21 06:01	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		03/18/21 16:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-MBR-1FL-S1	Lab ID: 70165633091	Collected: 03/10/21 05:35	Received: 03/11/21 09:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/18/21 16:16	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-CAFE-BR-S1	Lab ID: 70165633092	Collected: 03/10/21 04:50	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/18/21 16:21	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-CAFE-BR-S2</b>		<b>Lab ID: 70165633093</b>	Collected: 03/10/21 04:50	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		03/18/21 16:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-CAFE-DF1		Lab ID: 70165633094	Collected: 03/10/21 04:50	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 16:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-187-S8</b>		<b>Lab ID: 70165633095</b>		Collected: 03/10/21 05:00	Received: 03/11/21 09:55	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		03/18/21 16:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-187-S9	Lab ID: 70165633096	Collected: 03/10/21 05:00	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>40.2</b>	ug/L	1.0	1		03/18/21 16:25	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-221-DF1		Lab ID: 70165633097	Collected: 03/10/21 05:57	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 16:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-131-S2		Lab ID: 70165633098	Collected: 03/10/21 05:15	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		03/18/21 16:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-208-S2		Lab ID: 70165633099	Collected: 03/10/21 05:51	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		03/18/21 16:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

<b>Sample: HS-208-S1</b>		<b>Lab ID: 70165633100</b>	Collected: 03/10/21 05:51	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		03/18/21 16:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-218-S2		Lab ID: 70165633101	Collected: 03/10/21 05:55	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/18/21 16:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WBR-S1	Lab ID: 70165633102	Collected: 03/10/21 06:02	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/18/21 16:36	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-WBR-1FL-S1	Lab ID: 70165633103	Collected: 03/10/21 05:38	Received: 03/11/21 09:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/18/21 16:37	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-232-S1		Lab ID: 70165633104	Collected: 03/10/21 06:03	Received: 03/11/21 09:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>239</b>	ug/L	1.0	1		03/18/21 16:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Sample: HS-133-DF-1	Lab ID: 70165633105	Collected: 03/10/21 05:20	Received: 03/11/21 09:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/18/21 16:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

QC Batch:	200664	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70165633001, 70165633002, 70165633003, 70165633004, 70165633005, 70165633006, 70165633007, 70165633008, 70165633009, 70165633010, 70165633011, 70165633012, 70165633013, 70165633014, 70165633015, 70165633016, 70165633017, 70165633018, 70165633019, 70165633020

METHOD BLANK: 987695 Matrix: Water  
Associated Lab Samples: 70165633001, 70165633002, 70165633003, 70165633004, 70165633005, 70165633006, 70165633007, 70165633008, 70165633009, 70165633010, 70165633011, 70165633012, 70165633013, 70165633014, 70165633015, 70165633016, 70165633017, 70165633018, 70165633019, 70165633020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 14:02	

LABORATORY CONTROL SAMPLE: 987696

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.5	105	85-115	

MATRIX SPIKE SAMPLE: 987699

Parameter	Units	70165633001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	9.2	50	63.4	108	70-130	

MATRIX SPIKE SAMPLE: 987701

Parameter	Units	70165633011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	50	57.3	108	70-130	

SAMPLE DUPLICATE: 987698

Parameter	Units	70165633001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	9.2	9.3	1	

SAMPLE DUPLICATE: 987700

Parameter	Units	70165633011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.3	3.3	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

QC Batch:	200666	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165633021, 70165633022, 70165633023, 70165633024, 70165633025, 70165633026, 70165633027, 70165633028, 70165633029, 70165633030, 70165633031, 70165633032, 70165633033, 70165633034, 70165633035, 70165633036, 70165633037, 70165633038, 70165633039, 70165633040		

METHOD BLANK:	987704	Matrix:	Water
Associated Lab Samples:	70165633021, 70165633022, 70165633023, 70165633024, 70165633025, 70165633026, 70165633027, 70165633028, 70165633029, 70165633030, 70165633031, 70165633032, 70165633033, 70165633034, 70165633035, 70165633036, 70165633037, 70165633038, 70165633039, 70165633040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 14:32	

LABORATORY CONTROL SAMPLE:	987705					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.9	104	85-115	

MATRIX SPIKE SAMPLE:	987707						
Parameter	Units	70165633021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	58.1	113	70-130	

MATRIX SPIKE SAMPLE:	987709						
Parameter	Units	70165633031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	54.3	105	70-130	

SAMPLE DUPLICATE:	987706					
Parameter	Units	70165633021 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.8	1.8	1		

SAMPLE DUPLICATE:	987708					
Parameter	Units	70165633031 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.8	1.8	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

QC Batch:	200668	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70165633041, 70165633042, 70165633043, 70165633044, 70165633045, 70165633046, 70165633047, 70165633048, 70165633049, 70165633050, 70165633051, 70165633052, 70165633053, 70165633054, 70165633055, 70165633056, 70165633057, 70165633058, 70165633059, 70165633060		

METHOD BLANK:	987710	Matrix:	Water
Associated Lab Samples:	70165633041, 70165633042, 70165633043, 70165633044, 70165633045, 70165633046, 70165633047, 70165633048, 70165633049, 70165633050, 70165633051, 70165633052, 70165633053, 70165633054, 70165633055, 70165633056, 70165633057, 70165633058, 70165633059, 70165633060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 15:02	

LABORATORY CONTROL SAMPLE:	987711					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.4	105	85-115	

MATRIX SPIKE SAMPLE:	987713						
Parameter	Units	70165633041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	48.7	50	101	105	70-130	

MATRIX SPIKE SAMPLE:	987715						
Parameter	Units	70165633051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	54.5	107	70-130	

SAMPLE DUPLICATE:	987712					
Parameter	Units	70165633041 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	48.7	47.8	2		

SAMPLE DUPLICATE:	987714					
Parameter	Units	70165633051 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

QC Batch:	200669	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70165633061, 70165633062, 70165633063, 70165633064, 70165633065, 70165633066, 70165633067, 70165633068, 70165633069, 70165633070, 70165633071, 70165633072, 70165633073, 70165633074, 70165633075, 70165633076, 70165633077, 70165633078, 70165633079, 70165633080

METHOD BLANK: 987716 Matrix: Water  
Associated Lab Samples: 70165633061, 70165633062, 70165633063, 70165633064, 70165633065, 70165633066, 70165633067, 70165633068, 70165633069, 70165633070, 70165633071, 70165633072, 70165633073, 70165633074, 70165633075, 70165633076, 70165633077, 70165633078, 70165633079, 70165633080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 15:31	

LABORATORY CONTROL SAMPLE: 987717

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.3	105	85-115	

MATRIX SPIKE SAMPLE: 987719

Parameter	Units	70165633061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	540	50	568	55	70-130	M1

MATRIX SPIKE SAMPLE: 987721

Parameter	Units	70165633071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.3	111	70-130	

SAMPLE DUPLICATE: 987718

Parameter	Units	70165633061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	540	533	1	

SAMPLE DUPLICATE: 987720

Parameter	Units	70165633071 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

QC Batch:	200670	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70165633081, 70165633082, 70165633083, 70165633084, 70165633085, 70165633086, 70165633087, 70165633088, 70165633089, 70165633090, 70165633091, 70165633092, 70165633093, 70165633094, 70165633095, 70165633096, 70165633097, 70165633098, 70165633099, 70165633100

METHOD BLANK: 987722 Matrix: Water  
Associated Lab Samples: 70165633081, 70165633082, 70165633083, 70165633084, 70165633085, 70165633086, 70165633087, 70165633088, 70165633089, 70165633090, 70165633091, 70165633092, 70165633093, 70165633094, 70165633095, 70165633096, 70165633097, 70165633098, 70165633099, 70165633100

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 16:01	

LABORATORY CONTROL SAMPLE: 987723

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE: 987725

Parameter	Units	70165633081 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	50	55.8	109	70-130	

MATRIX SPIKE SAMPLE: 987727

Parameter	Units	70165633091 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.7	114	70-130	

SAMPLE DUPLICATE: 987724

Parameter	Units	70165633081 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.3	1.3	2	

SAMPLE DUPLICATE: 987726

Parameter	Units	70165633091 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

QC Batch: 200671 Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
Laboratory: Pace Analytical Services - Melville  
Associated Lab Samples: 70165633101, 70165633102, 70165633103, 70165633104, 70165633105

METHOD BLANK: 987728 Matrix: Water  
Associated Lab Samples: 70165633101, 70165633102, 70165633103, 70165633104, 70165633105

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/18/21 16:31	

LABORATORY CONTROL SAMPLE: 987729

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.1	104	85-115	

MATRIX SPIKE SAMPLE: 987731

Parameter	Units	70165633101 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.5	110	70-130	

SAMPLE DUPLICATE: 987730

Parameter	Units	70165633101 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### WORKORDER QUALIFIERS

WO: 70165633

[1] Client did not list sample HS-133-DF-1 on COC. Client was notified see Sample Condition Upon Receipt Form.

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PHELPS-CLIFTON HIGH SCHOOL

Pace Project No.: 70165633

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70165633001	HS-91-S1	EPA 200.8	200664		
70165633002	HS-91-S2	EPA 200.8	200664		
70165633003	HS-185-S1	EPA 200.8	200664		
70165633004	HS-185-S2	EPA 200.8	200664		
70165633005	HS-PBM-S1	EPA 200.8	200664		
70165633006	HS-PBM-S2	EPA 200.8	200664		
70165633007	HS-PBM-S3	EPA 200.8	200664		
70165633008	HS-PBM-S4	EPA 200.8	200664		
70165633009	HS-PBM-S5	EPA 200.8	200664		
70165633010	HS-PBW-S1	EPA 200.8	200664		
70165633011	HS-PBW-S2	EPA 200.8	200664		
70165633012	HS-PBW-S3	EPA 200.8	200664		
70165633013	HS-PBW-S4	EPA 200.8	200664		
70165633014	HS-PBW-S5	EPA 200.8	200664		
70165633015	HS-90-S1	EPA 200.8	200664		
70165633016	HS-90-S2	EPA 200.8	200664		
70165633017	HS-178A-S1	EPA 200.8	200664		
70165633018	HS-178B-S1	EPA 200.8	200664		
70165633019	HS-178-S1	EPA 200.8	200664		
70165633020	HS-170-S1	EPA 200.8	200664		
70165633021	HS-170-S2	EPA 200.8	200666		
70165633022	HS-170-S3	EPA 200.8	200666		
70165633023	HS-165-S1	EPA 200.8	200666		
70165633024	HS-165-S2	EPA 200.8	200666		
70165633025	HS-165-S3	EPA 200.8	200666		
70165633026	HS-160A-DF-2	EPA 200.8	200666		
70165633027	HS-166-S1	EPA 200.8	200666		
70165633028	HS-160-S1	EPA 200.8	200666		
70165633029	HS-159-S1	EPA 200.8	200666		
70165633030	HS-105-S1	EPA 200.8	200666		
70165633031	HS-100-S1	EPA 200.8	200666		
70165633032	HS-100-S2	EPA 200.8	200666		
70165633033	HS-LIBRARY-DF1	EPA 200.8	200666		
70165633034	HS-WGBR-S1	EPA 200.8	200666		
70165633035	HS-WGBR-S2	EPA 200.8	200666		
70165633036	HS-WGBR-S3	EPA 200.8	200666		
70165633037	HS-WGBR-S4	EPA 200.8	200666		
70165633038	HS-WGBR-S5	EPA 200.8	200666		
70165633039	HS-124-S1	EPA 200.8	200666		
70165633040	HS-MGBR-S1	EPA 200.8	200666		
70165633041	HS-MGBR-S2	EPA 200.8	200668		
70165633042	HS-MGBR-S3	EPA 200.8	200668		
70165633043	HS-MGBR-S4	EPA 200.8	200668		
70165633044	HS-MGBR-S5	EPA 200.8	200668		
70165633045	HS-143-S1	EPA 200.8	200668		
70165633046	HS-143-S2	EPA 200.8	200668		
70165633047	HS-146-S1	EPA 200.8	200668		
70165633048	HS-141-S1	EPA 200.8	200668		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70165633049	HS-141-S2	EPA 200.8	200668		
70165633050	HS-OSR138-DF2	EPA 200.8	200668		
70165633051	HS-WSBR-D-WING-S1	EPA 200.8	200668		
70165633052	HS-WSBR-D-WING-S2	EPA 200.8	200668		
70165633053	HS-WSBR-D-WING-S3	EPA 200.8	200668		
70165633054	HS-WSBR-D-WING-S4	EPA 200.8	200668		
70165633055	HS-135-S1	EPA 200.8	200668		
70165633056	HS-MSBR-D-WING-S1	EPA 200.8	200668		
70165633057	HS-MSBR-D-WING-S2	EPA 200.8	200668		
70165633058	HS-MSBR-D-WING-S3	EPA 200.8	200668		
70165633059	HS-131-S1	EPA 200.8	200668		
70165633060	HS-MGBR-2FL-S1	EPA 200.8	200668		
70165633061	HS-MGBR-2FL-S2	EPA 200.8	200669		
70165633062	HS-MGBR-2FL-S3	EPA 200.8	200669		
70165633063	HS-MGBR-2FL-S4	EPA 200.8	200669		
70165633064	HS-MGBR-2FL-S5	EPA 200.8	200669		
70165633065	HS-WGBR-2FL-S1	EPA 200.8	200669		
70165633066	HS-WGBR-2FL-S2	EPA 200.8	200669		
70165633067	HS-WGBR-2FL-S3	EPA 200.8	200669		
70165633068	HS-WGBR-2FL-S4	EPA 200.8	200669		
70165633069	HS-WGBR-2FL-S5	EPA 200.8	200669		
70165633070	HS-DR-S1	EPA 200.8	200669		
70165633071	HS-NHW-2FL-DF1	EPA 200.8	200669		
70165633072	HS-231-S1	EPA 200.8	200669		
70165633073	HS-231-S2	EPA 200.8	200669		
70165633074	HS-231-S3	EPA 200.8	200669		
70165633075	HS-231-S4	EPA 200.8	200669		
70165633076	HS-231-S5	EPA 200.8	200669		
70165633077	HS-202-S1	EPA 200.8	200669		
70165633078	HS-203-S1	EPA 200.8	200669		
70165633079	HS-OS-R210-DF1	EPA 200.8	200669		
70165633080	HS-OSR216-DF1	EPA 200.8	200669		
70165633081	HS-218-S1	EPA 200.8	200670		
70165633082	HS-187-S1	EPA 200.8	200670		
70165633083	HS-187-S2	EPA 200.8	200670		
70165633084	HS-187-S3	EPA 200.8	200670		
70165633085	HS-187-S4	EPA 200.8	200670		
70165633086	HS-187-S5	EPA 200.8	200670		
70165633087	HS-187-S6	EPA 200.8	200670		
70165633088	HS-187-S7	EPA 200.8	200670		
70165633089	HS-187B-S1	EPA 200.8	200670		
70165633090	HS-MFBR-S1	EPA 200.8	200670		
70165633091	HS-MBR-1FL-S1	EPA 200.8	200670		
70165633092	HS-CAFE-BR-S1	EPA 200.8	200670		
70165633093	HS-CAFE-BR-S2	EPA 200.8	200670		
70165633094	HS-CAFE-DF1	EPA 200.8	200670		
70165633095	HS-187-S8	EPA 200.8	200670		
70165633096	HS-187-S9	EPA 200.8	200670		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: PHELPS-CLIFTON HIGH SCHOOL  
Pace Project No.: 70165633

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70165633097	HS-221-DF1	EPA 200.8	200670		
70165633098	HS-131-S2	EPA 200.8	200670		
70165633099	HS-208-S2	EPA 200.8	200670		
70165633100	HS-208-S1	EPA 200.8	200670		
70165633101	HS-218-S2	EPA 200.8	200671		
70165633102	HS-WBR-S1	EPA 200.8	200671		
70165633103	HS-WBR-1FL-S1	EPA 200.8	200671		
70165633104	HS-232-S1	EPA 200.8	200671		
70165633105	HS-133-DF-1	EPA 200.8	200671		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

**Section A** Required Client Information: **Section B** Required Project Information: **Section C** Invoice Information:

Company: Phelps-Clifton Springs CSD  
 Address: 1490 State Route 488  
 Clifton Springs, NY 14432  
 Email: mreifsteck@midlakes.org  
 Phone: 315-548-6455  
 Fax: [ ]  
 Requested Due Date: [ ]

Report To: Mike Reifsteck  
 Copy To: [ ]  
 Purchase Order #: [ ]  
 Project Name: PHELPS-CLIFTON - HIGH SCHOOL  
 Project #: [ ]

Company Name: [ ]  
 Address: [ ]  
 Pace Quote: [ ]  
 Pace Project Manager: betty.harrison@pacelabs.com  
 Pace Profile #: 6079

Regulatory Agency: [ ]  
 State / Location: NY

Page: 2 Of 2

ITEM #	MATRIX CODE	COLLECTED	DATE	TIME	DATE	TIME	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on	Ice (Y/N)	Custody (Y/N)	Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)
13	HS-PBW-S3	DW	3/10	4:40	3/10	4:40	DW												
14	HS-PBW-S4	DW	3/10	4:40	3/10	4:40	DW												
15	HS-PBW-S5	DW	3/10	4:40	3/10	4:40	DW												
16	HS-PB-DF1	DW	3/10	4:37	3/10	4:37	DW												
17	HS-90-S1	DW	3/10	4:37	3/10	4:37	DW												
18	HS-90-S2	DW	3/10	4:34	3/10	4:34	DW												
19	HS-178A-S1	DW	3/10	4:34	3/10	4:34	DW												
20	HS-178B-S1	DW	3/10	4:33	3/10	4:33	DW												
21	HS-178-S1	DW					DW												
22	HS-179B-S1	DW					DW												
23	HS-GYM-DF1	DW					DW												
24	HS-GYM-DF2	DW					DW												















# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>	
<b>Required Client Information:</b>		<b>Required Project Information:</b>		<b>Invoice Information:</b>	
Company:	Phelps-Clifton Springs CSD	Report To:	Mike Reifsteck	Attention:	
Address:	1490 State Route 488 Clifton Springs, NY 14432	Copy To:		Company Name:	
Email:	mreifsteck@midstates.org	Purchase Order #:		Address:	
Phone:	315-548-6455	Project Name:	PHELPS-CLIFTON - HIGH SCHOOL	Pace Quote:	
Requested Due Date:		Project #:		Pace Project Manager:	betty.harrison@facelabs.com
				Pace Profile #:	6079
				State / Location:	NY
				Regulatory Agency:	

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Preservatives										Analyses Test Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	END DATE				H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	200.8 LEAD					
																TIME	DATE			
85	DW	HS-133-S7				DW	1	X												
86	DW	HS-133-S1				DW														
87	DW	HS-133-S2				DW														
88	DW	HS-133-S3				DW														
89	DW	HS-133-S4				DW														
90	DW	HS-134-S1				DW														
91	DW	HS-CC-S1				DW														
92	DW	HS-MGBR-2FL-S1	3/10	5:08		DW														
93	DW	HS-MGBR-2FL-S2		5:08		DW														
94	DW	HS-MGBR-2FL-S3		5:08		DW														
95	DW	HS-MGBR-2FL-S4		5:08		DW														
96	DW	HS-MGBR-2FL-S5		5:08		DW														

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on	Custody	Sealed	Cooler	Intact
				<i>Mike Reifsteck</i>	3/10	9:55	15.9	N	Y	Y	Y	Y
<b>SAMPLER NAME AND SIGNATURE</b>												
PRINT Name of SAMPLER:												
SIGNATURE of SAMPLER:												
DATE Signed:												





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

**Section A**  
**Required Client Information:**  
 Company: Phelps-Clifton Springs CSD  
 Address: 1490 State Route 488  
 Clifton Springs, NY 14432  
 Email: mreifsteck@midstates.org  
 Phone: 315-548-5455  
 Requested Due Date:

**Section B**  
**Required Project Information:**  
 Report To: Mike Reifsteck  
 Copy To:  
 Purchase Order #:  
 Project Name: PHELPS-CLIFTON - HIGH SCHOOL  
 Project #:

**Section C**  
**Invoice Information:**  
 Attention:  
 Company Name:  
 Address:  
 Pace Quote:  
 Pace Project Manager: bety.harrison@pacelabs.com.  
 Pace Profile #: 6079

**Regulatory Agency**  
**State / Location**  
 NY

ITEM #	MATRIX CODE <small>MATRIX</small> Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	SAMPLE TYPE (G-RAB C-COMP)	COLLECTED		DATE	TIME	DATE	TIME	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	DATE	TIME	TEMP in C	Received on (Y/N)	Custody (Y/N)	Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)		
				START	END																			
109	HS-NHW-2FL-DF1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
110	HS-231-S1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
111	HS-231-S2	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
112	HS-231-S3	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
113	HS-231-S4	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
114	HS-231-S5	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
115	HS-202-S1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
116	HS-203-S1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
117	HS-209-S1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
118	HS-OS-R210-DF1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
119	HS-OS-R210-DF2	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													
120	HS-210-S1	DW		DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME													

**Requested Analysis Filtered (Y/N)**

**Analyses Test**

200 & LEAD

Preservatives: H2SO4, HNO3, HCl, NaOH, Na2S2O3, Methanol, Other

# OF CONTAINERS

SAMPLE TEMP AT COLLECTION

RELINQUISHED BY / AFFILIATION

DATE

TIME

DATE

TIME

ACCEPTED BY / AFFILIATION

DATE

TIME

DATE

TIME

ADDITIONAL COMMENTS

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE Signed:













Sample Condition Upon Receipt

WO#: 70165633

Client Name:

Project

PM: EMH

Due Date: 03/25/21

CLIENT: PHELPS

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: 7845 8489 1347

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TH091 Correction Factor: +0.0

Cooler Temperature(°C): 15.9 Cooler Temperature Corrected(°C): 15.9

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Temperature Blank Present:  Yes  No

Type of Ice: Wet Blue ~~None~~

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: MN 3/11/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: SL <del>WT</del> OIL		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # Hc025486		Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Sample Hs-133-DF-1 not on

Date/Time:

Comments/ Resolution:

COC