



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA, 02633

**Order No.:** G20118285  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Lead & Copper - Monomoy Regional HS

**Laboratory ID#: 20118285-01**

Sample #: 01  
 Collection Address: MRHS Office Sink  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:30 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.33	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:26
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:26

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-02**

Sample #: 02  
 Collection Address: MRHS Sink near KAR  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:31 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.39	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:29
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:29

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-03**

Sample #: 03  
 Collection Address: MRHS bubbler  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:35 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.11	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:32
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:32

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-04**

Sample #: 04  
 Collection Address: MRHS bubbler  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:40 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.51	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:35
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:35

*Based on the results of the parameters tested, the water is suitable for drinking.*

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118285  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Lead & Copper - Monomoy Regional HS

**Laboratory ID#: 20118285-05**

Sample #: 05  
 Collection Address: MRHS faucet  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:44 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.23	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:38
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:38

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-06**

Sample #: 06  
 Collection Address: MRHS bubbler  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:50 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.26	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	12:50
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	12:50

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-07**

Sample #: 07  
 Collection Address: MRHS Culinary Sink  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:55 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.52	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:00
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:00

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-08**

Sample #: 08  
 Collection Address: MRHS Faucet  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:59 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.38	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:03
Lead	0.0011	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:03

*Based on the results of the parameters tested, the water is suitable for drinking.*

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118285  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Lead & Copper - Monomoy Regional HS

**Laboratory ID#: 20118285-09**

**Sample #:** 09  
**Collection Address:** MRHS Kitchen  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:20 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.23	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:06
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:06

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-10**

**Sample #:** 10  
**Collection Address:** MRHS Bubbler  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:20 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	1.1	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:09
Lead	0.0018	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:09

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-11**

**Sample #:** 11  
**Collection Address:** MRHS Bubbler  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:21 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.13	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:12
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:12

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-12**

**Sample #:** 12  
**Collection Address:** MRHS Bubbler  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:21 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.56	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:15
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:15

*Based on the results of the parameters tested, the water is suitable for drinking.*

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118285  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Lead & Copper - Monomoy Regional HS

**Laboratory ID#: 20118285-13**

**Sample #:** 13  
**Collection Address:** MRHS Bubbler  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:22 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.18	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:18
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:18

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-14**

**Sample #:** 14  
**Collection Address:** MRHS Faucet  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:22 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.31	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:21
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:21

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118285-15**

**Sample #:** 15  
**Collection Address:** MRHS Bubbler  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:24 By: Customer  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.30	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:24
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:24

*Based on the results of the parameters tested, the water is suitable for drinking.*

Attached please find the laboratory certified parameter list.

**Approved By:**   
 (Lab Manager)



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118288  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Monomoy Middle School - Pb & Cu

**Laboratory ID#: 20118288-01**

Sample #:   
 Collection Address: MRMS Kitchen  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:30 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.28	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	10:47
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	10:47

**Laboratory ID#: 20118288-02**

Sample #:   
 Collection Address: MRMS Teachers Lounge  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:31 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.19	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	10:56
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	10:56

**Laboratory ID#: 20118288-03**

Sample #:   
 Collection Address: MRMS - bubbler outside café  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:32 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	ND	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:00
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:00

**Laboratory ID#: 20118288-04**

Sample #:   
 Collection Address: MRMS - bubbler outside Admin  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:34 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.30	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:03
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:03

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd.  
 Chatham, MA 02633

**Order No.:** G20118288  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Monomoy Middle School - Pb & Cu

**Laboratory ID#: 20118288-05**

Sample #: \_\_\_\_\_  
 Collection Address: MRMS - bubbler custodian  
 Sample Location: \_\_\_\_\_

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:35 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.32	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:06
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:06

**Laboratory ID#: 20118288-06**

Sample #: \_\_\_\_\_  
 Collection Address: MRMS - bubbler sink library  
 Sample Location: \_\_\_\_\_

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:38 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.76	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:09
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:09

**Laboratory ID#: 20118288-07**

Sample #: \_\_\_\_\_  
 Collection Address: MRMS - bubbler 1st floor 5th grade  
 Sample Location: \_\_\_\_\_

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:40 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.29	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:12
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:12

**Laboratory ID#: 20118288-08**

Sample #: \_\_\_\_\_  
 Collection Address: MRMS - bubbler 2nd floor 5th grader  
 Sample Location: \_\_\_\_\_

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 6:42 By: RC  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.26	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:16
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:16

ND = None Detected.

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118288  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Monomoy Middle School - Pb & Cu

**Laboratory ID#: 20118288-09**

**Sample #:**  
**Collection Address:** MRMS - supers break room  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:44 By: RC  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.27	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:19
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:19

**Laboratory ID#: 20118288-10**

**Sample #:**  
**Collection Address:** MRMS - admin break room  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:45 By: RC  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.22	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:22
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:22

**Laboratory ID#: 20118288-11**

**Sample #:**  
**Collection Address:** MRMS - nurse  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:48 By: RC  
**Received:** 01/28/2020 15:15 By: PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.46	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:34
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:34

Attached please find the laboratory certified parameter list.

**Approved By:**   
 (Lab Manager)



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118286  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Chatham Elementary - Pb & Cu

**Laboratory ID#: 20118286-01**

Sample #: 01  
 Collection Address: Bubbler - Outside Gym  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 7:15 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.37	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:36
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:36

**Laboratory ID#: 20118286-02**

Sample #: 02  
 Collection Address: Hallway Bubbler  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 7:20 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.44	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:46
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:46

**Laboratory ID#: 20118286-03**

Sample #: 03  
 Collection Address: Bath/Bubbler  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 7:28 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.47	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:49
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:49

**Laboratory ID#: 20118286-04**

Sample #: 04  
 Collection Address: Work Room  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 7:34 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.42	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:52
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:52

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level





# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118286  
**Report Dated:** 02/06/2020  
**Submitter:** Rick Travers  
**Description:** Chatham Elementary - Pb & Cu

**Laboratory ID#: 20118286-05**

Sample #: 05  
 Collection Address: Kitchen Sink  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 7:37 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

**Lead & Copper**

<u>ITEM</u>	<u>RESULT</u>	<u>UNITS</u>	<u>RL</u>	<u>MCL</u>	<u>METHOD #</u>	<u>ANALYST</u>	<u>TESTED</u>	<u>TIME</u>
Copper	0.37	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:55
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:55

Attached please find the laboratory certified parameter list.

**Approved By:**   
 (Lab Manager)



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118287  
**Report Dated:** 02/10/2020  
**Submitter:** Rick Travers  
**Description:** Harwich Elemt. School - Pb & Cu

**Laboratory ID#: 20118287-01**

**Sample #:**  
**Collection Address:** Harwich Elemt. Café/Kitchen  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 5:42 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.20	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	13:58
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	13:58

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118287-02**

**Sample #:**  
**Collection Address:** Harwich Element - Teachers Room  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 5:44 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.16	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	14:01
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	14:01

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118287-03**

**Sample #:**  
**Collection Address:** MES Classroom  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 5:47 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.12	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	14:04
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	14:04

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118287-04**

**Sample #:**  
**Collection Address:** MES Health Office  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 5:50 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.27	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	14:07
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	14:07

*Based on the results of the parameters tested, the water is suitable for drinking.*

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

Recipient: Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

Order No.: G20118287  
 Report Dated: 02/10/2020  
 Submitter: Rick Travers  
 Description: Harwich Elemt. School - Pb & Cu

### Laboratory ID#: 20118287-05

Sample #:   
 Collection Address: MES Classroom  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 5:51 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

#### Lead & Copper

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.24	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	14:10
Lead	0.0024	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	14:10

*Based on the results of the parameters tested, the water is suitable for drinking.*

### Laboratory ID#: 20118287-06

Sample #:   
 Collection Address: MES Water Fountain  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 5:53 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

#### Lead & Copper

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.29	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:44
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:44

*Based on the results of the parameters tested, the water is suitable for drinking.*

### Laboratory ID#: 20118287-07

Sample #:   
 Collection Address: MES classroom  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 5:56 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

#### Lead & Copper

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.20	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:47
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:47

*Based on the results of the parameters tested, the water is suitable for drinking.*

### Laboratory ID#: 20118287-08

Sample #:   
 Collection Address: MES classroom  
 Sample Location:

Matrix: Water - Drinking Water  
 Sampled: 01/28/2020 5:57 By: Customer  
 Received: 01/28/2020 15:15 By: PalmerP  
 Turn Around: Standard

#### Lead & Copper

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	TIME
Copper	0.24	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:50
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:50

*Based on the results of the parameters tested, the water is suitable for drinking.*

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

**Recipient:** Rick Travers  
 Monomoy Regional School  
 425 Crowell Rd  
 Chatham, MA 02633

**Order No.:** G20118287  
**Report Dated:** 02/10/2020  
**Submitter:** Rick Travers  
**Description:** Harwich Elemt. School - Pb & Cu

**Laboratory ID#: 20118287-09**

**Sample #:**  
**Collection Address:** MES classroom  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 5:59 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

<u>ITEM</u>	<u>RESULT</u>	<u>UNITS</u>	<u>RL</u>	<u>MCL</u>	<u>METHOD #</u>	<u>ANALYST</u>	<u>TESTED</u>	<u>TIME</u>
Copper	0.19	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:53
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:53

*Based on the results of the parameters tested, the water is suitable for drinking.*

**Laboratory ID#: 20118287-10**

**Sample #:**  
**Collection Address:** MES Classroom  
**Sample Location:**

**Matrix:** Water - Drinking Water  
**Sampled:** 01/28/2020 6:01 **By:** Customer  
**Received:** 01/28/2020 15:15 **By:** PalmerP  
**Turn Around:** Standard

**Lead & Copper**

<u>ITEM</u>	<u>RESULT</u>	<u>UNITS</u>	<u>RL</u>	<u>MCL</u>	<u>METHOD #</u>	<u>ANALYST</u>	<u>TESTED</u>	<u>TIME</u>
Copper	0.27	mg/L	0.0010	1.3	EPA 200.8	CL	01/30/2020	11:56
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	CL	01/30/2020	11:56

*Based on the results of the parameters tested, the water is suitable for drinking.*

Attached please find the laboratory certified parameter list.

**Approved By:**   
 (Lab Manager)