



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC

P.O. Box 59203, Schaumburg, IL 60173

www.elementalsolutionsllc.com

Prepared For:	Will County D92
Report Attention To:	Gary Moser
Sample Collection Date(s):	5/9/2019
Sample Collection Volume:	250mL
Date & Time of Last System Use:	5/8/2019 6:30pm

Analysis Parameter:	Lead by EPA 200.8; MRL = 1ppb
Analysis Date(s):	5/24/2019
Laboratory:	PDC Labs
School:	Lugwig

Sampling Location	Sample ID	Result (µg/L)	Comments
LE DF OUTSIDE MUSIC	9052657-01	<2.00	under the action limit
LE DF OUTSIDE MUSIC 2D	9052657-02	<2.00	under the action limit
LE BF OUTSIDE RM 7	9052657-03	<2.00	under the action limit
LE BF OUTSIDE RM 7 2D	9052657-04	<2.00	under the action limit
LE DF OUTSIDE RM 7	9052657-05	<2.00	under the action limit
LE DF OUTSIDE RM 7 2D	9052657-06	<2.00	under the action limit
LE DF OUTSIDE RM 9/12	9052657-07	<2.00	under the action limit
LE DF OUTSIDE RM 9/12 2D	9052657-08	<2.00	under the action limit



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC
 P.O. Box 59203, Schaumburg, IL 60173
 www.elementalsolutionsllc.com

Prepared For:	Will County D92
Report Attention To:	Gary Moser
Sample Collection Date(s):	5/9/2019
Sample Collection Volume:	250mL
Date & Time of Last System Use:	5/8/2019 6:30pm

Analysis Parameter:	Lead by EPA 200.8; MRL = 1ppb
Analysis Date(s):	5/24/2019
Laboratory:	PDC Labs
School:	Walsh

Sampling Location	Sample ID	Result (µg/L)	Comments
WE KITCHEN 1	9052657-13	16.3	above the action limit
WE KITCHEN 1 2D	9052657-14	<2.00	below the action limit
WE KITCHEN 2	9052657-15	6.58	above the action limit
WE KITCHEN 2 2D	9052657-16	<2.00	below the action limit
WE KITCHEN 3	9052657-17	5.84	above the action limit
WE KITCHEN 3 2D	9052657-18	<2.00	below the action limit
WE DF OUTSIDE RM 1A	9052657-19	<2.00	below the action limit
WE DF OUTSIDE RM 1A 2D	9052657-20	<2.00	below the action limit
WE RM 14 DF	9052657-21	<2.00	below the action limit
WE RM 14 DF 2D	9052657-22	<2.00	below the action limit
WE RM 8 DF	9052657-23	<2.00	below the action limit
WE RM 8 DF 2D	9052657-24	<2.00	below the action limit
WE RM 7 DF	9052657-25	<2.00	below the action limit
WE RM 7 DF 2D	9052657-26	<2.00	below the action limit



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC

P.O. Box 59203, Schaumburg, IL 60173

www.elementalsolutionsllc.com

Prepared For:	Will County D92
Report Attention To:	Gary Moser
Sample Collection Date(s):	5/9/2019
Sample Collection Volume:	250mL
Date & Time of Last System Use:	5/8/2019 9pm

Analysis Parameter:	
Lead by EPA 200.8; MRL = 1ppb	
Analysis Date(s):	5/24/2019
Laboratory:	PDC Labs
School:	Oak Prairie

Sampling Location	Sample ID	Result (µg/L)	Comments
OP KITCHEN 7	9052657-09	2.40	above the action limit
OP KITCHEN 7 2D	9052657-10	<2.00	under the action limit
OP KITCHEN 6	9052657-11	7.12	above the action limit
OP KITCHEN 6 2D	9052657-12	<2.00	under the action limit