Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/31/2021
Received: 03/19/2021
Sampled By: Kevin Montague
Work Order: 1078020

CLIENT
Tigard-Tualatin SD
Attn: Kevin Montague
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078020-01	**Sample Name:** Classroom #3 Faucet **Sampled:** 3/18/21 7:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1078020-02	**Sample Name:** Classroom #6 Faucet **Sampled:** 3/18/21 7:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

***** The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.